

SAN FRANCISCO PUBLIC LIBRARY



3 1223 05956 5201



5/S



*San Francisco Public Library*

**GOVERNMENT INFORMATION CENTER  
SAN FRANCISCO PUBLIC LIBRARY  
REFERENCE BOOK**

*Not to be taken from the Library*


*[Faint, illegible text]*

*[Faint, illegible text]*

*[Faint, illegible text]*

*[Faint, illegible text]*

*[Faint, illegible text]*



Digitized by the Internet Archive  
in 2014

<http://archive.org/details/finalinterimrepo2919sanf>



**SCA PROJECT NO. B2243**

**OCTOBER 29, 1997**

**Final Interim Report:  
San Francisco Unified School District  
Lead in Drinking Water Survey**

**DOCUMENTS DEPT.**

**JUL 23 2001**

**SAN FRANCISCO  
PUBLIC LIBRARY**

San Francisco Unified School District

Final Interim Report  
San Francisco Unified School District  
Lead in Drinking Water Survey

DOCUMENTS DEPT.

JUL 1 1988

SAN FRANCISCO  
PUBLIC LIBRARY

3 1223 05956 5201



**Final Interim Report  
San Francisco Unified School District (SFUSD)  
Lead in Drinking Water Survey  
SCA Proj. No. B2243**

**Submitted to:**

Bruce Giannini, SFUSD  
1351 42nd Ave., Rm 102  
San Francisco, CA 94122

**Prepared by:**

Chuck Siu, CIH  
4 Embarcadero Center, Suite 480  
San Francisco, CA  
Tel: 415-397-9936  
Fax: 415-397-1406

David Kahane, CIH  
Forensic Analytical Specialties, Inc.  
3777 Depot Road  
Suite 409  
Hayward, CA 94545  
Tel: 510-887-8828  
Fax: 510-887-4218

Mr. Robert Bottome, CIH  
EORM  
2460 North First Street, Suite 260  
San Jose, CA 95131-1024  
Tel: 408-321-2850  
Fax: 408-436-1136

**Reviewed by:**

Regina Colbert  
Colbert and Associates  
2501 Coronet  
Belmont, CA 94002  
Tel: 650-654-0383

**Date:**

October 29, 1997





## Table of Contents

Volume	Title	Page
I.	1.0 Executive Summary.....	1
	2.0 Introduction .....	3
	2.1 Background.....	3
	2.2 Work Performed .....	3
	3.0 Project Participants.....	4
	4.0 Methodology.....	5
	4.1 Sample Collection.....	5
	4.2 Analytical Methods .....	5
	4.3 QA/QC Methods .....	5
	5.0 Regulations.....	6
	6.0 Interim Results and Discussion.....	7
	6.1 Lead Testing Results .....	7
	6.2 QA/QC Results.....	8
	6.3 Recommendations .....	8
	7.0 References.....	10
	Table 1 Interim Results Summary	
	Table 2 Interim Results	
	Table 3 Interim Spike Results	
	Table 4 Interim Inter-lab Re-analysis Results	
	Appendix A Sampling and Analysis Plan	
II.	Appendix B Lab Reports	
III.	Appendix C Sample Location Diagrams	
IV.	Appendix D Field Data Sheets	
	Appendix E Lab QA/QC Reports	





## 1.0 Executive Summary

This final interim report summarizes the preliminary data for the sampling of drinking water sources at 139 school sites in the San Francisco Unified School District (SFUSD, herein referred to as the District) and subsequent analysis for lead content. Note that a number of sites are not included for various reasons, including scheduling and access difficulties.

Sampling was performed according to the methods described in the project Sampling and Analysis Plan (SAP, see Appendix A). Samples were analyzed by state-certified laboratories by Graphite Furnace Atomic Absorption spectroscopy in accordance with EPA Method 239.2, with a detection limit of 5 ppb. EPA regulations require that drinking water sources contain less than 15 parts per billion (ppb) lead.

A total of 2495 initial samples (equivalent to the number of sources) were collected at 139 sites in the District. Interim results for these schools are summarized as follows:

	Some Results > 15 ppb	All Results < 15 ppb	All Results < Detection Limit*	Total
# of sites	62	61	13	139
% of sites	45%	44%	9%	100

\* Included on Table 1, but not in this summary are 3 sites which could not be accessed due to construction.

As of October 29, 1997, 55 sites have been re-sampled for the 192 sources whose initial results exceeded 15 ppb, with 30-second pre-sampling flushing. The results are summarized in the following table.

	First Draw <sup>(1)</sup> Results > 15 ppb	Second Draw <sup>(1)</sup> Results > 15 ppb	Third Draw <sup>(2)</sup> Results > 15 ppb	Total
# of sources	12	8	41	192

(1) Flushed for 30 seconds prior to sampling

(2) No flushing, waited for 4-6 hours of normal usage before sampling.

Of the 192 sources that had initial levels >15 ppb, only 12 (est. <1% of 2495 sources) still showed levels >15 ppb in the First Draw samples which were collected after a 30-second flushing period. This result substantiates the USEPA and SFDPH position that flushing is a satisfactory preventive measure if conducted in a regimented manner.

In addition to the 192 sources above, 56 sources which were between 12 and 15 ppb lead were re-sampled to confirm that the sources tested below 15 ppb lead. Re-sampling confirmed that these sources were below 15 ppb.

Quality Assurance/Quality Control (QA/QC) checks were set up to document the accuracy and reproducibility of the sample results:

- Field blanks showed that samples were not contaminated by sampling techniques (100% of field blanks were <5 ppb.)
- Field blanks also showed that samples were not contaminated by in-lab handling of samples (100% of field blanks were <5 ppb.)
- Sampling bottles were certified by manufacturers to contain <1 ppb of lead.





- One bottle from each lot was analyzed and confirmed to contain lead at <1 ppb.
- Spiked samples were masked as field samples and analyzed:
  - 77% of spiked samples analyzed within 15% of the expected values.
  - 85% of spiked samples analyzed within 25% of the expected values.
  - 2% of errors were most likely caused by human error (e.g. mislabeling of samples).
  - 11% of results differed with the expected values by 25%.
- 5% of samples were submitted to a second lab for re-analysis.
  - 70% of the re-analyzed samples were within 15% of the mean values.

Sources where sampling indicates elevated levels of lead (estimated at 41) should be addressed individually, on a case--by-case basis. No one solution is likely to lower lead levels at all sources. Possible actions include, but are not limited to the following:

- Adjust water arches at drinking fountains to be at least 2" above the bubbler;
- Install self-metering valve faucets;
- Replace units;
- Provide bottled water instead of tap; and
- Check internal plumbing for other possible lead sources.





## **2.0 Introduction**

### **2.1 BACKGROUND**

Drinking water sources at 139 school sites in the District were sampled and analyzed for lead content. Sources for water which are unlikely to be used for drinking (e.g. custodial slop sinks) were not sampled. Sampling was performed according to procedures outlined in the attached Sampling and Analysis Plan (SAP, Appendix A), with the analyses performed according to EPA methods. (See section 4 for more detail.)

### **2.2 WORK PERFORMED**

Samples were collected by surveyors at school sites throughout the District. A listing of sites and the surveyors responsible for sample collection at those sites are included in the SAP (Appendix A). Samples were analyzed by accredited labs for lead content. Quality Assurance/Quality Control (QA/QC) procedures, including the use of blanks, intra-lab re-analysis, inter-lab re-analysis, and spiked samples, were utilized to document the accuracy and reproducibility of the study.





### 3.0 Project Participants

Numerous organizations and their personnel were involved in the planning, implementation, analysis and data compilation of this study. The participants and their roles are tabulated as follows:

Title	Organization	Role
Project Manager	Bruce Giannini (SFUSD)	Overall Project Management
Coordinator & Final Report Consultant	Chuck Siu, CIH SCA Environmental, Inc.	<ul style="list-style-type: none"> <li>• Coordinated laboratories, consultants, etc.</li> <li>• Integrates field and lab data;</li> <li>• Generates final report.</li> </ul>
Laboratory QA/QC - Project Consultant	David Kahane, CIH Forensic Specialties, Inc.	<ul style="list-style-type: none"> <li>• Lab QA/QC</li> </ul>
Project Consultant	Robert Bottome, CIH EORM	remediation issues
Contract Laboratory 1	Sequoia Laboratory	analyzed field samples
Contract Laboratory 2	MicroAnalytical, Inc.	analyzed field samples
Field Consultant	SCA Environmental, Inc.	collected field samples
Field Consultant	SES Environmental, Inc.	collected field samples
Field Consultant	RGA Environmental, Inc.	collected field samples
Field Consultant	AAE Environmental, Inc.	collected field samples
Field Consultant	EnviroScience Environmental, Inc.	collected field samples
Field Consultant	North Tower Environmental, Inc.	collected field samples
Field Consultant	ATC Environmental, Inc.	collected field samples
Field Consultant	QST Environmental, Inc.	collected field samples
SFUSD In-house Technicians	SFUSD	collected field samples





## 4.0 Methodology

### 4.1 SAMPLE COLLECTION

A detailed description of the sampling procedure, including measures taken to prevent sample contamination, is described in the SAP (Appendix A).

A. Initial samples were collected according to the following general procedure:

- Dormant sites (sites that had not been in operations for the Summer holiday) were prepared by flushing 24 hours prior to sampling.
- Water samples were collected after water was standing in the system for a minimum of six hours, without any pre-flushing.
- One one-liter sample was collected from each accessible drinking water source.

B. Procedures for re-sampling were as follows:

- After > 6 hours of standing time, 1-liter "First draw" samples were collected after flushing for 30 seconds.
- "Second draw" samples are collected after flushing for an additional 30 seconds.
- "Third draw" samples are collected after a 4-6 hours lapse after the second sample (with no flushing).

### 4.2 ANALYTICAL METHODS

For standardization, all water samples were analyzed by Graphite Furnace Atomic Absorption (GFAA) in accordance with EPA Method 239.2, with a detection limit (defined as the Method Reporting Limit) of 1 to 5 ppb, depending on the laboratory and its instrumentation.

However, to simplify comparison of the results all results reported by the laboratories at <5 ppb (e.g., 2 ppb, <1 ppb) are shown as <5 ppb in tables 2 and 4.

### 4.3 QA/QC METHODS

QA/QC methods included certified sample containers; spiked samples and blank samples in submitted sample sets; in-house sample re-analysis; and inter-lab sample re-analysis. The details of the implementation of these methods is described in the SAP.





## **5.0 Regulations**

EPA regulations stipulate that the 90th percentile Action Level for lead levels in drinking water is 15 ppb, based on the 1991 EPA's final national primary drinking water regulations for lead and copper. (The 90th percentile cutoff indicates that 90% of the sample results must be below 15 ppb.)



## 6.0 Interim Results and Discussion

### 6.1 LEAD TESTING RESULTS

The results of the survey as of Oct. 29, 1997 are summarized by site in Table 1 and given in detail in Table 2.

Nine survey teams collected 2495 initial field samples (not including blanks, spiked samples, and samples from return site visits) at 139 sites in the District. A brief summary of the site distribution is tabulated below.

	Some Results > 15 ppb	All Results < 15 ppb	All Results < Detection Limit*	Total
# of sites	62	61	13	139
% of sites	45%	44%	9%	100

\* Included on Table 1, but not in this summary are 3 sites which could not be accessed due to construction.

Of the 139 sites sampled by October 29, 1997, 62 sites (or 45% of sites) had samples with lead content > 15 ppb. 61 sites (or 44% of sites) had all samples test below 15 ppb, but lead was still detected. 13 sites (or 9% of sites) had all samples tested below the detection limits for lead.

Of the 62 sites with samples above 15 ppb lead, as of October 29, 1997, 15 sites have been re-sampled for 192 sources which tested above 15 ppb lead in the initial sampling. Re-sampling was performed with 30-second pre-sampling flushing. The results are outlined below:

	First Draw <sup>(1)</sup> Results > 15 ppb	Second Draw <sup>(1)</sup> Results > 15 ppb	Third Draw <sup>(2)</sup> Results > 15 ppb	Total
# of sources	12	8	41	192

(1) Flushed for 30 seconds prior to sampling

(2) No flushing, waited for 4-6 hours of normal usage before sampling.

Of the 192 sources that had initial levels >15 ppb, only 12 (est. <1% of 2495 sources) still showed levels >15 ppb in the First Draw samples which were collected after a 30-second flushing. This result substantiates the USEPA and SFDPH position that flushing is a satisfactory preventive measure if conducted in a regimented manner.

Also, 56 sources between 12 and 15 ppb were re-sampled to confirm that they test lower than 15 ppb lead. All of these samples were confirmed as being below 15 ppb.





## 6.2 QA/QC RESULTS

### 6.2.1 Laboratory Certifications

Laboratories performing water quality analysis are certified by the California Department of Health Services (DOHS) under the Environmental Laboratory Accreditation Program (ELAP). The California Department of Health Services requires certified laboratories to participate in EPA water performance testing. Listed in the following table are the contracted laboratories and their certification numbers.

Forensic Analytical 3777 Depot Rd., Ste. 409, Hayward, CA 94545	ELAP Cert. # 1202
Sequoia Laboratory 680 Chesapeake Dr., Redwood City, CA 94063	ELAP Cert. # 1210
MicroAnalytical, Inc. 5900 Hollis St, #M, Emeryville, CA 94608	ELAP Cert. # 1037

### 6.2.2 Sampling Bottles

Sampling bottles were purchased from manufacturers providing certificates that the inherent lead contents of the bottles were below the detection limit (<5 ppb). One bottle from each lot was further tested for lead content to confirm such results.

### 6.2.3 Blanks, spikes, etc.

Blank samples were prepared at each site and submitted for analysis. 100% of these samples all tested below the detection limits.

In-house blanks were prepared at each lab and analyzed for lead. These samples all tested below detection limits.

- Spiked samples were masked as field samples and analyzed:
  - 77% of spiked samples analyzed within 15% of the expected values.
  - 85% of spiked samples analyzed within 25% of the expected values.
  - 2% of errors were most likely caused by human error (e.g. mislabeling of samples).

### 6.2.4 Inter-laboratory analysis

Results for inter-lab analysis are given in Table 4. 90 (5%) Samples were sent for inter-lab analysis:

- 70% of the re-analyzed samples were within 15% of the mean values

## 6.3 RECOMMENDATIONS

Sources where sampling indicates elevated levels of lead (estimated at 41) should be addressed individually, on a case-by-case basis. No one solution is likely to lower





lead levels at all sources. Possible actions include, but are not limited to the following:

- Adjust water arches at drinking fountains to be at least 2" above the bubbler;
- Install self-metering valve faucets;
- Replace units;
- Provide bottled water instead of tap; and
- Check internal plumbing for other possible lead sources.



## 7.0 References

- A. 40CFR141.2 defines first draw sample as a 1-Liter sample of tap water, collected in accordance with 1414.86(b)(2) that has been standing in plumbing pipes at least 6 hours and is collected without flushing the tap.

Note that for re-sampling the "first draw" samples were flushed for 30 seconds. For initial sampling, no flushing was performed prior to sampling.

- B. 40CFR141.86 specifies that acidification of the first draw sample may be done up to 14 days after the sample is collected, rather than using pre-acidified bottles. Acidification must be conducted in the original container for >16 hours.
- C. AWWA Standard Methods for the Examination of Water and Wastewater, 19th ed., 1995.
- D. Federal Register, June 7, 1991, p. 26460: Maximum Contaminant Level Goals and National Primary Drinking Water Regulations for Lead and Copper.





**Table 1**  
**Interim Results Summary**





Table 1-Interim Results Summary

SFUSD Lead in Drinking Water Survey - Draft Summary					
Summer / Fall 1997					
SCA Project B2243					
		<u>Initial Trip</u>		<u>Return Trips</u>	
Summary	Sites	Samples (F)	#>15 ppb	Samples (R)	#>15 ppb
Total	139	2069	253	735	61
<u>Initial Trip</u>				<u>Return Trips</u>	
Sites	Return	# Samples	#>15 ppb	# Samples	#>15 ppb
21st Century Acade		19	9		
	Ret. 1			10	4
	Ret. 2			10	3
	Ret. 3			10	5
Buena Vista ES		22	20		
	Ret. 1			19	1
	Ret. 2			19	0
	Ret. 3			19	5
Burnett CC/ES		17	3		
	Ret. 1			3	0
	Ret. 2			3	0
	Ret. 3			3	2
Burton HS		23	1		
	Ret. 1			3	0
	Ret. 2			3	0
	Ret. 3			3	0
Carmichael ES		9	1		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Carver ES		38	17		
	Ret. 1			20	2
	Ret. 2			20	1
	Ret. 3			20	4
Chin ES		5	2		
	Ret. 1			2	0
	Ret. 2			2	0
	Ret. 3			2	0
Chinese Ed. Ctr.		10	1		
	Ret. 1			3	0
	Ret. 2			3	1
	Ret. 3			3	3
Davis MS (Hudson)		9	1		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	1
Downtown HS		7	2		
	Ret. 1			1	1
	Ret. 2			1	0
	Ret. 3			1	1



Table 1-Interim Results Summary

SFUSD Lead in Drinking Water Survey - Draft Summary					
Summer / Fall 1997					
SCA Project B2243					
		<u>Initial Trip</u>		<u>Return Trips</u>	
Summary	Sites	Samples (F)	#>15 ppb	Samples (R)	#>15 ppb
Total	139	2069	253	735	61
Initial Trip				Return Trips	
Sites	Return	# Samples	#>15 ppb	# Samples	#>15 ppb
Edison ES		24	1		
	Ret. 1			2	0
	Ret. 2			2	0
	Ret. 3			2	0
El Dorado ES		23	8		
	Ret. 1			9	0
	Ret. 2			9	0
	Ret. 3			9	1
Fairmont E.S.		40	4		
	Ret. 1			5	0
	Ret. 2			5	0
	Ret. 3			5	0
Flynn E.S.		10	1		
	Ret. 1			2	0
	Ret. 2			2	0
	Ret. 3			2	0
Francisco M.S.		14	1		
Garfield E.S.		24	23		
Golden Gate ES		26	1		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Grattan ES		54	16		
	Ret. 1			15	0
	Ret. 2			15	1
	Ret. 3			15	1
Harte ES		34	9		
	Ret. 1			8	0
	Ret. 2			8	0
	Ret. 3			8	1
Hillcrest ES		8	2		
	Ret. 1			2	0
	Ret. 2			2	0
	Ret. 3			2	0
Jefferson CC		8	1		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Jefferson ES		26	2		
	Ret. 1			3	0
	Ret. 2			3	0
	Ret. 3			3	1





Table 1-Interim Results Summary

SFUSD Lead in Drinking Water Survey - Draft Summary					
Summer / Fall 1997					
SCA Project B2243					
		Initial Trip		Return Trips	
Summary	Sites	Samples (F)	#>15 ppb	Samples (R)	#>15 ppb
Total	139	2069	253	735	61
Initial Trip				Return Trips	
Sites	Return	# Samples	#>15 ppb	# Samples	#>15 ppb
Kennedy CC		10	1		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
King ES		12	3		
	Ret. 1			3	0
	Ret. 2			3	0
	Ret. 3			3	0
Lafayette ES		12	2		
	Ret. 1			2	0
	Ret. 2			2	0
	Ret. 3			2	0
Lick MS		15	1		
	Ret. 1			3	0
	Ret. 2			3	0
	Ret. 3			2	0
Marshall HS		17	4		
	Ret. 1			8	1
	Ret. 2			8	1
	Ret. 3			8	0
McAteer HS		16	1		
McCoppin ES		24	2		
	Ret. 1			5	0
	Ret. 2			5	0
	Ret. 3			5	0
McKinley ES		23	2		
	Ret. 1			3	0
	Ret. 2			3	0
	Ret. 3			3	0
Miraloma ES		19	7		
	Ret. 1			9	2
	Ret. 2			9	1
	Ret. 3			9	3
Mission Annex		3	2		
	Ret. 1			3	0
	Ret. 2			3	0
	Ret. 3			3	0
Mission HS		17	1		
New Traditions ES		8	1		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0



Table 1-Interim Results Summary

SFUSD Lead in Drinking Water Survey - Draft Summary					
Summer / Fall 1997					
SCA Project B2243					
		<u>Initial Trip</u>		<u>Return Trips</u>	
Summary	Sites	Samples (F)	#>15 ppb	Samples (R)	#>15 ppb
Total	139	2069	253	735	61
<b>Initial Trip</b>				<b>Return Trips</b>	
Sites	Return	# Samples	#>15 ppb	# Samples	#>15 ppb
Newcomer HS		7	2		
	Ret. 1			2	0
Ortega ES		29	4		
Peabody ES		18	3		
	Ret. 1			4	0
	Ret. 2			4	0
	Ret. 3			4	0
Potrero Hill JH		22	4		
	Ret. 1			3	0
	Ret. 2			3	0
	Ret. 3			3	0
Presidio CC		19	1		
Presidio MS		13	4		
	Ret. 1			4	1
	Ret. 2			4	0
	Ret. 3			4	0
Redding ES/PK		9	1		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Rooftop MS		3	1		
Roosevelt MS		28	4		
San Francisco Community ES		9	1		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Sanchez ES		7	1		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
School of the Arts (SOTA)		22	5		
Sheridan ES		24	8		
Sherman ES		13	1		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Sloat ES		26	7		
	Ret. 1			7	0
	Ret. 2			7	0
	Ret. 3			7	1





Table 1-Interim Results Summary

SFUSD Lead in Drinking Water Survey - Draft Summary					
Summer / Fall 1997					
SCA Project B2243					
		<u>Initial Trip</u>		<u>Return Trips</u>	
Summary	Sites	Samples (F)	#>15 ppb	Samples (R)	#>15 ppb
Total	139	2069	253	735	61
<b>Initial Trip</b>				<b>Return Trips</b>	
Sites	Return	# Samples	#>15 ppb	# Samples	#>15 ppb
Spring Valley ES		21	7		
	Ret. 1			9	0
	Ret. 2			9	0
	Ret. 3			9	3
Stevenson ES		16	1		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Sunnyside ES		12	1		
	Ret. 1			3	0
	Ret. 2			3	0
	Ret. 3			3	0
Sunset ES		11	5		
Sutro ES/CC		21	5		
	Ret. 1			10	0
	Ret. 2			10	0
	Ret. 3			10	0
Taylor ES/PK		18	3		
	Ret. 1			5	0
	Ret. 2			3	0
	Ret. 3			3	0
Treasure Island ES & Annex		36	6		
	Ret. 1			9	0
	Ret. 2			9	0
	Ret. 3			9	3
Tule Elk Park CC		16	3		
	Ret. 1			3	0
	Ret. 2			3	0
	Ret. 3			3	0
Ulloa ES		21	1		
	Ret. 1			2	0
	Ret. 2			2	0
	Ret. 3			2	0
Webster ES		24	8		
	Ret. 1			8	0
	Ret. 2			8	0
	Ret. 3			8	3
West Portal ES		25	3		
	Ret. 1			6	0
	Ret. 2			6	0
	Ret. 3			6	0
Wells HS (M. Bradshaw)		8	1		



Table 1-Interim Results Summary

SFUSD Lead in Drinking Water Survey - Draft Summary					
Summer / Fall 1997					
SCA Project B2243					
		<u>Initial Trip</u>		<u>Return Trips</u>	
Summary	Sites	Samples (F)	#>15 ppb	Samples (R)	#>15 ppb
Total	139	2069	253	735	61
Initital Trip				Return Trips	
Sites	Return	# Samples	#>15 ppb	# Samples	#>15 ppb
Wo ES		21	8		
	Ret. 1			13	0
	Ret. 2			13	0
	Ret. 3			13	3





Table 1-Interim Results Summary

SFUSD Lead in Drinking Water Survey - Draft Summary					
Summer / Fall 1997					
SCA Project B2243					
		<u>Initial Trip</u>		<u>Return Trips</u>	
Summary	Sites	Samples (F)	#>15 ppb	Samples (R)	#>15 ppb
Total	139	2069	253	735	61
			Initial Trip	Return Trips	
Sites	Return	# Samples	#>15 ppb	# Samples	#>15 ppb
<b>Sites with sources below 15 ppb in initial trip</b>					
Aptos MS		13	0		
Argonne CC		3	0		
Argonne ES		7	0		
Argonne ES--ESI		36	0		
Alamo ES		28	0		
Balboa HS		19	0		
Bay HS		6	0		
Bryant ES		23	0		
Cabrillo ES		21	0		
Central City Hospitality		8	0		
Chinatown Youth Center		4	0		
Clarendon ES		28	0		
Cleveland ES		24	0		
Cobb CC		2	0		
Cooper CC		6	0		
De Avila ES		12	0		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Denman MS		12	0		
Drew ES		21	0		
Everett MS		5	0		
Excelsior C.C.		13	0		
Filipino Ed. Ctr.		11	0		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Franklin M.S.		16	0		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Galileo HS		10	0		
Giannini J.H.		27	0		
Glen Park E. S.		5	0		
Guadalupe ES		17	0		
Hilltop Pregnancy Svcs. Ctr.		9	0		
Hoover MS		19	0		
Intl. Studies Academy		4	0		



Table 1-Interim Results Summary

SFUSD Lead in Drinking Water Survey - Draft Summary					
Summer / Fall 1997					
SCA Project B2243					
		<u>Initial Trip</u>		<u>Return Trips</u>	
Summary	Sites	Samples (F)	#>15 ppb	Samples (R)	#>15 ppb
Total	139	2069	253	735	61
Initial Trip				Return Trips	
Sites	Return	# Samples	#>15 ppb	# Samples	#>15 ppb
Key ES & Annex		6	0		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
King MS		9	0		
Larkin St. Youth Center		7	0		
Las Americas ES		4	0		
Lilienthal ES		23	0		
Longfellow ES		9	0		
Lowell HS		14	1		
Malcolm X Academy		8	0		
Mann MS		11	0		
Marina JH		18	0		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Marshall ES		18	0		
McLaren CC		7	0		
Milk ES		9	0		
Monroe ES		33	0		
Moscone ES		14	0		
Muir ES		9	0		
Noriega CC		13	0		
O'Connel HS		18	0		
Revere ES & Annex		33	0		
Rooftop ES		12	0		
San Francisco Charter Early C		8	0		
Serra Annex CC		15	0		
	Ret. 1			1	0
	Ret. 2			1	0
	Ret. 3			1	0
Serra ES		20	0		
Serra SA		18	0		
Stockton ES/CC/PK & Annex		3	0		
Sunshine HS (Mission Evenin		6	0		
Swett ES/PK		11	0		
Visitacion Valley MS		20	0		
Wallenberg HS		7	0		
Washington HS		37	0		
Weill ES (CC)		16	0		
Wells HS (Emmanuel)		5	0		





Table 1-Interim Results Summary

SFUSD Lead in Drinking Water Survey - Draft Summary					
Summer / Fall 1997					
SCA Project B2243					
		<b>Initial Trip</b>		<b>Return Trips</b>	
<b>Summary</b>	<b>Sites</b>	<b>Samples (F)</b>	<b>#&gt;15 ppb</b>	<b>Samples (R)</b>	<b>#&gt;15 ppb</b>
<b>Total</b>	<b>139</b>	2069	253	735	61
<b>Initial Trip</b>				<b>Return Trips</b>	
<b>Sites</b>	<b>Return</b>	<b># Samples</b>	<b>#&gt;15 ppb</b>	<b># Samples</b>	<b>#&gt;15 ppb</b>
<b>Sites with sources below detection limit in initial trip</b>					
Alvarado ES		6	0		
Chavez ES		13	0		
Cobb ES		5	0		
Davis MS (Evans)		3	0		
Golden Gate Annex ES		7	0		
Lakeshore ES		16	0		
Lawton E.S.		NOT SURVEYED--HEAVY CONSTRUCTION--NO ACCESS			
Mahler CC		3	0		
Martin CC		2	0		
Mission Annex CC		1	0		
Parker ES		27	0		
Parks E.S.		NOT SURVEYED--HEAVY CONSTRUCTION--NO ACCESS			
San Miguel CC		9	0		
St. Elizabeth Pregnancy Ctr.		1	0		
Visitation Valley E		NOT SURVEYED--HEAVY CONSTRUCTION--NO ACCESS			
Yoey CC		1	0		



**Table 2**  
**Interim Results**



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary																					
Site		Address		Sample ID	Source ID	Final Interim Report		Results	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
1	21st Century Academy	2055 Silver Ave., 94124		1	1	yes	yes	24	1st	SF	Kitchen	8/14/97	ESI	SEQ							
1A	21st Century Academy	2055 Silver Ave., 94124		1A	1	yes	yes	23	1st	SF	Kitchen	9/2/97	ESI	SEQ				1-1			
1B	21st Century Academy	2055 Silver Ave., 94124		1B	1	yes	yes	23	1st	SF	Kitchen	9/2/97	ESI	SEQ							
1C	21st Century Academy	2055 Silver Ave., 94124		1C	1	yes	yes	<5	3rd	SF	Kitchen	9/16/97	ESI	SEQ							
2	21st Century Academy	2055 Silver Ave., 94124		2	2	yes	yes	17	1st	SF	Kitchen	8/14/97	ESI	SEQ							
2A	21st Century Academy	2055 Silver Ave., 94124		2A	2	yes	yes	11	1st	SF	Kitchen	9/2/97	ESI	SEQ							
2B	21st Century Academy	2055 Silver Ave., 94124		2B	2	yes	yes	10	2nd	SF	Kitchen	9/2/97	ESI	SEQ				3-2			
2C	21st Century Academy	2055 Silver Ave., 94124		2C	2	yes	yes	<5	3rd	SF	Kitchen	9/16/97	ESI	SEQ							
3	21st Century Academy	2055 Silver Ave., 94124		3	3	yes	yes	8	1st	SF	Kitchen	8/14/97	ESI	SEQ							
4	21st Century Academy	2055 Silver Ave., 94124		4	4	yes	yes	11	1st	DF	Cafeteria	8/14/97	ESI	SEQ							
5	21st Century Academy	2055 Silver Ave., 94124		5	5	yes	yes	15	1st	DF	Hallway-100	8/14/97	ESI	SEQ							
5A	21st Century Academy	2055 Silver Ave., 94124		5A	5	yes	yes	9	1st	DF	Hall C91	9/2/97	ESI	SEQ							
5B	21st Century Academy	2055 Silver Ave., 94124		5B	5	yes	yes	6	2nd	DF	Hall C91	9/2/97	ESI	SEQ							
5C	21st Century Academy	2055 Silver Ave., 94124		5C	5	yes	yes	<5	3rd	DF	Hall C91	9/16/97	ESI	SEQ				3-3			
6	21st Century Academy	2055 Silver Ave., 94124		6	6	yes	yes	56	1st	DF	Hallway-C93	8/14/97	ESI	SEQ							
6A	21st Century Academy	2055 Silver Ave., 94124		6A	6	yes	yes	55	1st	DF	Hall C93	9/2/97	ESI	SEQ							
6B	21st Century Academy	2055 Silver Ave., 94124		6B	6	yes	yes	27	2nd	DF	Hall C93	9/2/97	ESI	SEQ				3-4			
6C	21st Century Academy	2055 Silver Ave., 94124		6C	6	yes	yes	38	3rd	DF	Hall C93	9/16/97	ESI	SEQ							
7	21st Century Academy	2055 Silver Ave., 94124		7	7	yes	yes	8	1st	SF	Lounge-016	8/14/97	ESI	SEQ			8				
8	21st Century Academy	2055 Silver Ave., 94124		8	8	yes	yes	<5	1st	SF	Classroom 008	8/14/97	ESI	SEQ							
8	21st Century Academy	2055 Silver Ave., 94124		8	8	yes	yes	<5	Duplicate	SF	Lounge-016	8/14/97	ESI	SEQ							
9	21st Century Academy	2055 Silver Ave., 94124		9	9	yes	yes	37	1st	DF	Hallway S84	8/14/97	ESI	SEQ							
9A	21st Century Academy	2055 Silver Ave., 94124		9A	9	yes	yes	<5	1st	DF	Hall S84	9/2/97	ESI	SEQ							
9A	21st Century Academy	2055 Silver Ave., 94124		9A	9	yes	yes	<5	Duplicate	DF	Hall S84	9/2/97	ESI	SEQ							
9B	21st Century Academy	2055 Silver Ave., 94124		9B	9	yes	yes	7	2nd	DF	Hall S84	9/2/97	ESI	SEQ							
9C	21st Century Academy	2055 Silver Ave., 94124		9C	9	yes	yes	22	3rd	DF	Hall S84	9/16/97	ESI	SEQ				4-5			
10	21st Century Academy	2055 Silver Ave., 94124		10	10	yes	yes	43	1st	DF	Classroom 006	8/14/97	ESI	SEQ							
10A	21st Century Academy	2055 Silver Ave., 94124		10A	10	yes	yes	64	1st	DF	Classroom 6	9/2/97	ESI	SEQ							
10B	21st Century Academy	2055 Silver Ave., 94124		10B	10	yes	yes	19	2nd	DF	Classroom 6	9/2/97	ESI	SEQ				4-6			
10C	21st Century Academy	2055 Silver Ave., 94124		10C	10	yes	yes	6	3rd	DF	Classroom 6	9/16/97	ESI	SEQ							
11	21st Century Academy	2055 Silver Ave., 94124		11	11	yes	yes	<5	1st	DF	Classroom 005	8/14/97	ESI	SEQ							
12	21st Century Academy	2055 Silver Ave., 94124		12	12	yes	yes	<5	1st	DF	Classroom 004	8/14/97	ESI	SEQ							
13	21st Century Academy	2055 Silver Ave., 94124		13	13	yes	yes	26	1st	DF	Hallway C93	8/14/97	ESI	SEQ							
13A	21st Century Academy	2055 Silver Ave., 94124		13A	13	yes	yes	<5	1st	DF	Hall C93	9/2/97	ESI	SEQ							
13B	21st Century Academy	2055 Silver Ave., 94124		13B	13	yes	yes	<5	2nd	DF	Hall C93	9/2/97	ESI	SEQ							
13C	21st Century Academy	2055 Silver Ave., 94124		13C	13	yes	yes	<5	3rd	DF	Hall C93	9/16/97	ESI	SEQ				4-7			
14	21st Century Academy	2055 Silver Ave., 94124		14	14	yes	yes	15	1st	DF	Classroom 003	8/14/97	ESI	SEQ							
15	21st Century Academy	2055 Silver Ave., 94124		15	15	yes	yes	22	1st	DF	Classroom 002	8/14/97	ESI	SEQ							
15A	21st Century Academy	2055 Silver Ave., 94124		15A	15	yes	yes	15	1st	DF	Classroom 2	9/2/97	ESI	SEQ							
15B	21st Century Academy	2055 Silver Ave., 94124		15B	15	yes	yes	11	2nd	DF	Classroom 2	9/16/97	ESI	SEQ							
15C	21st Century Academy	2055 Silver Ave., 94124		15C	15	yes	yes	<5	3rd	DF	Classroom 2	9/16/97	ESI	SEQ				4-8			
16	21st Century Academy	2055 Silver Ave., 94124		16	16	yes	yes	69	1st	DF	Hallway S81	8/14/97	ESI	SEQ							
16A	21st Century Academy	2055 Silver Ave., 94124		16A	16	yes	yes	25	1st	DF	Hall S81	9/2/97	ESI	SEQ							
16B	21st Century Academy	2055 Silver Ave., 94124		16B	16	yes	yes	19	2nd	DF	Hall S81	9/2/97	ESI	SEQ							
16C	21st Century Academy	2055 Silver Ave., 94124		16C	16	yes	yes	57	3rd	DF	Hall S81	9/16/97	ESI	SEQ				3-9			
17	21st Century Academy	2055 Silver Ave., 94124		17	17	yes	yes	<5	1st	DF	Hallway C92 (North)	8/14/97	ESI	SEQ							
17	21st Century Academy	2055 Silver Ave., 94124		17	17	yes	yes	<5	Duplicate	DF	Hallway C92 (North)	8/14/97	ESI	SEQ							
18	21st Century Academy	2055 Silver Ave., 94124		18	18	yes	yes	8	1st	DF	Hallway C92 (South)	8/14/97	ESI	SEQ							
19	21st Century Academy	2055 Silver Ave., 94124		19	19	yes	yes	74	1st	DF	Playground	8/14/97	ESI	SEQ							
19	21st Century Academy	2055 Silver Ave., 94124		19	19	yes	yes	74	Duplicate	DF	Playground	8/14/97	ESI	SEQ							
19A	21st Century Academy	2055 Silver Ave., 94124		19A	19	yes	yes	13	1st	DF	Playground	9/2/97	ESI	SEQ							
19A	21st Century Academy	2055 Silver Ave., 94124		19A	19	yes	yes	12	Duplicate	DF	Playground	9/2/97	ESI	SEQ							
19B	21st Century Academy	2055 Silver Ave., 94124		19B	19	yes	yes	9	2nd	DF	Playground	9/2/97	ESI	SEQ							
19C	21st Century Academy	2055 Silver Ave., 94124		19C	19	yes	yes	24	3rd	DF	Playground	9/16/97	ESI	SEQ				3-10			
19C	21st Century Academy	2055 Silver Ave., 94124		19C	19	yes	yes	23	Duplicate	DF	Playground	9/16/97	ESI	SEQ				3-10			
20	21st Century Academy	2055 Silver Ave., 94124		20	20	na	na	<5	1st	DF	Rm 15, Teachers' Work Room	9/2/97	ESI	SEQ				777?			
20	21st Century Academy	2055 Silver Ave., 94124		20	na	na	na	10	Spike	Blank		8/14/97	ESI	SEQ							
21	21st Century Academy	2055 Silver Ave., 94124		21	na	na	na	<5	Blank	Blank		8/14/97	ESI	SEQ							
BL	21st Century Academy	2055 Silver Ave., 94124		BL	na	na	na	<5	Blank	Blank		9/16/97	ESI	SEQ							
BL	21st Century Academy	2055 Silver Ave., 94124		BL	na	na	na	<5	Blank	Blank		9/2/97	ESI	SEQ							
NO1	21st Century Academy	2055 Silver Ave., 94124		NO1	na	na	na	NO	NO	DF	Room 100		ESI	SEQ				non-operational			





Page 2 of 128. Printed 10/29/97



### Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary										Final Interim Report										
Summer / Fall 1997 SCA Project B2243																				
Site	Address	Sample ID	Source ID	12 to 15 pph	>15 pph	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
Alvarado E.S.	625 Douglas St., 94114	1	1			9708C97-01	<5	1st	SF	Rm 070 Basement	8/24/97	RG A	SEQ							
Alvarado E.S.	625 Douglas St., 94114	1	1			9708C97-02	<5	Duplicate SF		Rm 070 Basement	8/24/97	RG A	SEQ							
Alvarado E.S.	625 Douglas St., 94114	2	2			9708C97-03	<5	1st	DF	Corr. 1st Flr. adjacent to 007	8/24/97	RG A	SEQ							
Alvarado E.S.	625 Douglas St., 94114	3	3			9708C97-04	<5	1st	DF	Corr. 1st Flr. adjacent to 003	8/24/97	RG A	SEQ							
Alvarado E.S.	625 Douglas St., 94114	4	4			9708C97-05	<5	1st	DF	2nd Flr. adjacent to 012	8/24/97	RG A	SEQ							
Alvarado E.S.	625 Douglas St., 94114	5	5			9708C97-06	<5	1st	SF	Kitchen, Rm 025A	8/24/97	RG A	SEQ							
Alvarado E.S.	625 Douglas St., 94114	6	6			9708C97-07	<5	1st	DF	Corr. 2nd Flr. adjacent to 016	8/24/97	RG A	SEQ							
Alvarado E.S.	625 Douglas St., 94114	7	na			9708C97-08	<5	Blank			8/24/97	RG A	SEQ							
Alvarado E.S.	625 Douglas St., 94114	8	na			9708C97-09	44	Spike			8/24/97	RG A	SEQ	97-W00765-10	50	49				





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project 10243													
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Aptos M.S.	105 Aptos Ave, 94127	1	1		48826-01	<5	1st	DF	1st Fl, C-91	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	2	2		48826-02	<5	1st	DF	1st Fl, C-90	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	3	3		48826-03	<5	1st	DF	Basement, C-90	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	4	4		48826-04	<5	1st	DF	1st Fl, Yard	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	5	5		48826-05	<5	1st	DF	1st Fl, C-92 Corr	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	6	6		48826-06	<5	1st	DF	Room 239 West	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	7	7		48826-07	<5	1st	DF	Room 239 East	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	8	8		48826-08	<5	1st	DF	2nd Fl, C-91 Corr	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	9	9		48826-09	<5	1st	DF	2nd Fl, C-90 Corr N	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	10	10		48826-10	<5	1st	DF	2nd Fl, C-90 Corr S	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	12	12		48826-12	<5	1st	DF	3rd Fl, C-91	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	13	13		48826-13	<5	1st	DF	3rd Fl, C-90 North	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	14	14		48826-14	<5	1st	DF	3rd Fl, C-90 South	9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	11	na		48826-11	20	Spike			9/20/97	SFUSD	MAL	20
Aptos M.S.	105 Aptos Ave, 94127	15	na		48826-15	<5	Blank			9/20/97	SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	NA1	na			NA	NA		1st Fl, Kitchen		SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	NA2	na			NO	NO		2nd Fl, Girl's Locker Room		SFUSD	MAL	
Aptos M.S.	105 Aptos Ave, 94127	NO1	na						outside Room 104		SFUSD	MAL	
												non-accessible non-accessible non-operational	



SFUSD Lead in Drinking Water Survey - Results Summary

Page 5 of 128. Printed 10/29/97



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report		Sample ID											
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up			
Balboa H.S.	1000 Cayuga Ave., 94112	2	2			48578-02	<5	1st	DF	Gym Bldg., 1st Flr., Rm 104	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	3	3			48578-03	<5	1st	DF	Gym Bldg., 1st Flr., Rm 102	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	4	4			48578-04	<5	1st	DF	1st Flr., C90B, by Rm 108	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	5	5			48578-05	<5	1st	DF	1st Flr., C90C, by Rm 100	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	6	6			48578-06	<5	1st	DF	Ext Walkway, C90, by T58A	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	7	7			48578-07	<5	1st	MDF	Ext Walkway, C90, by T58A	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	8	8			48578-08	5	1st	MDF	Ext Walkway, C90, by T58A	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	9	9			48578-09	<5	1st	DF	2nd Flr., C90A, by Rm 200	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	10	10			48578-10	<5	1st	DF	3rd Flr., C90A, by Rm 300	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	11	11			48578-11	<5	1st	DF	3rd Flr., C90, by Rm 309	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	12	12			48578-12	<5	1st	DF	3rd Flr., C92, by Rm 318	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	13	13			48578-13	8	1st	DF	3rd Flr., C92, by Rm 329	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	14	14			48578-14	<5	1st	DF	2nd Flr., C92, by Rm 229	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	15	15			48578-15	<5	1st	DF	2nd Flr., C92, by Rm 218	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	16	16			48578-16	<5	1st	DF	1st Flr., C91, by Rm 116	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	17	17			48578-17	<5	1st	DF	1st Flr., C92, by Rm T62	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	18	18			48578-18	11	1st	DF	Basement Flr., C91, by Rm 022	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	19	19			48578-19	<5	1st	DF	Basement Flr., C91, by Rm 023	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	21	21			48578-21	<5	1st	SF	Kitchen Faucet, 158D	9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	1	na			48578-01	20	Spike			9/17/97	SES	MAL	97-W00760-19	20								
Balboa H.S.	1000 Cayuga Ave., 94112	20	na			48578-20	<5	Blank			9/17/97	SES	MAL										
Balboa H.S.	1000 Cayuga Ave., 94112	NO1	na				NO	DF		outside Room T-63		SES	MAL				non-operational						
Balboa H.S.	1000 Cayuga Ave., 94112	NO2	na				NO	DF		outside Room 209		SES	MAL				non-operational						





Table 2 - Final Intern Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project 62243																				
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Final Interim Report	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inches)	Fill Time (seconds)	Follow-Up
Bay H.S.	1351 42nd Ave., 94122	1					<5	1st	DF	Restroom	8/26/97	SFUSD	MAL							
Bay H.S.	1351 42nd Ave., 94122	2					<5	1st	DF	Home Study Office	8/26/97	SFUSD	MAL							
Bay H.S.	1351 42nd Ave., 94122	3					<5	1st	SF	Main Office	8/26/97	SFUSD	MAL							
Bay H.S.	1351 42nd Ave., 94122	4					<5	1st	DF	Special Ed. Room	8/26/97	SFUSD	MAL							
Bay H.S.	1351 42nd Ave., 94122	5					5	1st	DF	Restroom	8/26/97	SFUSD	MAL							
Bay H.S.	1351 42nd Ave., 94122	6					<5	1st	DF	Regular Ed. Office	8/26/97	SFUSD	MAL							
Bay H.S.	1351 42nd Ave., 94122	7	na				<5	Blank			8/26/97	SFUSD	MAL							
Bay H.S.	1351 42nd Ave., 94122	8	na				<5	Not on FDS/COC			8/26/97	SFUSD	MAL							



Table 2 - Final Intern Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCCA Project B2243						Final Interim Report														
	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
Bryant E.S.	1050 York St., 94110	1	1			47482-01	8	Isd	SDF	Rm 12 (2nd Flr.)	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	2	2			47482-02	6	Isd	SDF	Rm 11	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	3	3			47482-03	<5	Isd	SDF	Rm 10	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	4	4			47482-04	6	Isd	SDF	Rm 9	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	5	5			47482-05	5	Isd	SDF	Rm 8	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	6	6			47482-06	5	Isd	SDF	Rm 7	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	7	7			47482-07	<5	Isd	SDF	Rm 6	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	8	8			47482-08	<5	Isd	DF	2nd Flr Ctr Library	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	9	9			47482-09	6	Isd	SDF	Rm 5	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	10	10			47482-10	<5	Isd	SDF	Rm 4	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	11	11			47482-11	8	Isd	SDF	Rm 2	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	12	12			47482-12	<5	Isd	SDF	Rm 3	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	13	13			47482-13	<5	Isd	SDF	Rm 1 (2nd Flr)	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	15	15			47482-15	<5	Isd	SF	M-purpose Rm Food Svc Off	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	17	17			47482-16	<5	Isd	DF	Child Care	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	18	18			47482-17	<5	Isd	SDF	Grls RR 1st Flr	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	19	19			47482-18	<5	Isd	SDF	Boys RR 1st Flr	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	20	20			47482-19	<5	Isd	SF	Faculty Lounge	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	21	21			47482-20	6	Isd	SF	Nurse's Off	8/17/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	23	23			48022-01	6	Isd	SDF	Kinderg. A	8/23/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	24	24			48022-02	7	Isd	SDF	Kinderg. B	8/23/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	25	25			48022-03	8	Isd	DF	1st Flr Entry Hall	8/23/97	ATC	MAL							
Bryant E.S.	1050 York St., 94110	14	na			47482-14	9	Spike			8/17/97	ATC	MAL		10					
Bryant E.S.	1050 York St., 94110	22	na			47482-21	<5	Blank			8/17/97	ATC	MAL							
																		</		





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243		Site	Address	Sample ID	Source ID	Final Interim Report	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inches)	Fill Time (second)	Follow-Up
		Buena Vista E.S.	2641 25th St., 94110	1					47484-01	22	1st	SF	Kitchen	8/17/97	ATC	MAL							
		Buena Vista E.S.	2641 25th St., 94110	1A	1			yes	49292-01	8	1st	SF	Kitchen	10/4/97	ATC	MAL							
		Buena Vista E.S.	2641 25th St., 94110	1B	1				49292-02	<5	2nd	SF	Kitchen	10/4/97	ATC	MAL							
		Buena Vista E.S.	2641 25th St., 94110	1C	1				49292-03	8	3rd	SF	Kitchen	10/4/97	ATC	MAL							
		Buena Vista E.S.	2641 25th St., 94110	2	2			yes	47484-02	44	1st	SF	Teachers' Lounge	8/17/97	ATC	MAL							
		Buena Vista E.S.	2641 25th St., 94110	2A	2				49292-04	<5	1st	SF	Teachers' Lounge	10/4/97	ATC	MAL							
		Buena Vista E.S.	2641 25th St., 94110	2B	2				49292-05	<5	2nd	SF	Teachers' Lounge	10/4/97	ATC	MAL							
		Buena Vista E.S.	2641 25th St., 94110	2C	2	yes			49292-06	16	1st	SF	Teachers' Lounge	10/4/97	ATC	MAL							
		Buena Vista E.S.	2641 25th St., 94110	3	3			yes	47484-03	14	1st	SDF	Rm 3 (1st Flr)	8/17/97	ATC	MAL							
		Buena Vista E.S.	2641 25th St., 94110	3A	3				49292-07	<5	1st	SDF	Rm 3 (1st Flr)	10/4/97	ATC	MAL							30
		Buena Vista E.S.	2641 25th St., 94110	3B	3				49292-08	<5	2nd	SDF	Rm 3 (1st Flr)	10/4/97	ATC	MAL							30
		Buena Vista E.S.	2641 25th St., 94110	3C	3				49292-09	7	3rd	SDF	Rm 3 (1st Flr)	10/4/97	ATC	MAL							30
		Buena Vista E.S.	2641 25th St., 94110	4	4			yes	47484-04	36	1st	SDF	Rm 1	8/17/97	ATC	MAL							20
		Buena Vista E.S.	2641 25th St., 94110	4A	4				49292-10	<5	1st	SDF	Rm 1	10/4/97	ATC	MAL							20
		Buena Vista E.S.	2641 25th St., 94110	4B	4				49292-11	<5	2nd	SDF	Rm 1	10/4/97	ATC	MAL							20
		Buena Vista E.S.	2641 25th St., 94110	4C	4				49292-12	9	3rd	SDF	Rm 1	10/4/97	ATC	MAL							20
		Buena Vista E.S.	2641 25th St., 94110	5	5			yes	47484-05	28	1st	DF	Rm 3 (1st Flr)	8/17/97	ATC	MAL							
		Buena Vista E.S.	2641 25th St., 94110	6	6			yes	47484-06	17	1st	SDF	Rm 5	8/17/97	ATC	MAL							25
		Buena Vista E.S.	2641 25th St., 94110	6A	6			yes	49292-13	13	1st	SDF	Rm 5	10/4/97	ATC	MAL							25
		Buena Vista E.S.	2641 25th St., 94110	6B	6				49292-14	<5	2nd	SDF	Rm 5	10/4/97	ATC	MAL							25
		Buena Vista E.S.	2641 25th St., 94110	6C	6				49292-15	10	3rd	SDF	Rm 5	10/4/97	ATC	MAL							25
		Buena Vista E.S.	2641 25th St., 94110	7	7			yes	47484-07	27	1st	SDF	Rm 4	8/17/97	ATC	MAL							40
		Buena Vista E.S.	2641 25th St., 94110	7A	7				49292-16	8	1st	SDF	Rm 4	10/4/97	ATC	MAL							40
		Buena Vista E.S.	2641 25th St., 94110	7B	7				49292-17	<5	2nd	SDF	Rm 4	10/4/97	ATC	MAL							40
		Buena Vista E.S.	2641 25th St., 94110	7C	7				49292-18	10	3rd	SDF	Rm 4	10/4/97	ATC	MAL							40
		Buena Vista E.S.	2641 25th St., 94110	8	8			yes	47484-08	86	1st	SDF	Nurse's Off	8/17/97	ATC	MAL							
		Buena Vista E.S.	2641 25th St., 94110	8A	8				49292-19	10	1st	SDF	Nurse's Off	10/4/97	ATC	MAL							22
		Buena Vista E.S.	2641 25th St., 94110	8B	8				49292-20	11	2nd	SDF	Nurse's Off	10/4/97	ATC	MAL							22
		Buena Vista E.S.	2641 25th St., 94110	8C	8			yes	49292-21	18	3rd	SDF	Nurse's Off	10/4/97	ATC	MAL							22
		Buena Vista E.S.	2641 25th St., 94110	9	9			yes	47484-09	37	1st	DF	by RR's 1st Flr Hall	8/17/97	ATC	MAL							35
		Buena Vista E.S.	2641 25th St., 94110	9A	9			yes	49292-22	18	1st	DF	by RR's 1st Flr Hall	10/4/97	ATC	MAL							35
		Buena Vista E.S.	2641 25th St., 94110	9B	9				49292-23	<5	2nd	DF	by RR's 1st Flr Hall	10/4/97	ATC	MAL							35
		Buena Vista E.S.	2641 25th St., 94110	9C	9				49292-24	13	3rd	DF	by RR's 1st Flr Hall	10/4/97	ATC	MAL							35
		Buena Vista E.S.	2641 25th St., 94110	10	10			yes	47484-10	41	1st	SDF	Rm 2	8/17/97	ATC	MAL							28
		Buena Vista E.S.	2641 25th St., 94110	10A	10				49292-25	5	1st	SDF	Rm 2	10/4/97	ATC	MAL							28
		Buena Vista E.S.	2641 25th St., 94110	10B	10				49292-26	7	2nd	SDF	Rm 2	10/4/97	ATC	MAL							28
		Buena Vista E.S.	2641 25th St., 94110	10C	10				49292-27	11	3rd	SDF	Rm 2	10/4/97	ATC	MAL							28
		Buena Vista E.S.	2641 25th St., 94110	11	11			yes	47484-11	76	1st	SDF	Rm 14 (2nd Flr)	8/17/97	ATC	MAL							24
		Buena Vista E.S.	2641 25th St., 94110	11A	11				49292-28	<5	1st	SDF	Rm 14 (2nd Flr)	10/4/97	ATC	MAL							24
		Buena Vista E.S.	2641 25th St., 94110	11B	11				49292-29	<5	2nd	SDF	Rm 14 (2nd Flr)	10/4/97	ATC	MAL							24
		Buena Vista E.S.	2641 25th St., 94110	11C	11				49292-30	<5	3rd	SDF	Rm 14 (2nd Flr)	10/4/97	ATC	MAL							24
		Buena Vista E.S.	2641 25th St., 94110	12	12			yes	47484-12	46	1st	SDF	Rm 16	8/17/97	ATC	MAL							22
		Buena Vista E.S.	2641 25th St., 94110	12A	12				49292-31	<5	1st	SDF	Rm 16	10/4/97	ATC	MAL							22
		Buena Vista E.S.	2641 25th St., 94110	12B	12			yes	49292-32	<5	2nd	SDF	Rm 16	10/4/97	ATC	MAL							22
		Buena Vista E.S.	2641 25th St., 94110	12C	12			yes	49292-33	12	3rd	SDF	Rm 16	10/4/97	ATC	MAL							22
		Buena Vista E.S.	2641 25th St., 94110	13	13			yes	47484-13	35	1st	SDF	Rm 18	8/17/97	ATC	MAL							24
		Buena Vista E.S.	2641 25th St., 94110	13A	13				49292-34	<5	1st	SDF	Rm 18	10/4/97	ATC	MAL							24
		Buena Vista E.S.	2641 25th St., 94110	13B	13				49292-35	<5	2nd	SDF	Rm 18	10/4/97	ATC	MAL							24
		Buena Vista E.S.	2641 25th St., 94110	13C	13			yes	49292-36	19	3rd	SDF	Rm 18	10/4/97	ATC	MAL							24
		Buena Vista E.S.	2641 25th St., 94110	14	14			yes	47484-14	101	1st	SDF	Rm 20	8/17/97	ATC	MAL							29
		Buena Vista E.S.	2641 25th St., 94110	14A	14				49292-37	8	1st	SDF	Rm 20	10/4/97	ATC	MAL							29
		Buena Vista E.S.	2641 25th St., 94110	14B	14				49292-38	5	2nd	SDF	Rm 20	10/4/97	ATC	MAL							29
		Buena Vista E.S.	2641 25th St., 94110	14C	14			yes	49292-39	26	3rd	SDF	Rm 20	10/4/97	ATC	MAL							29
		Buena Vista E.S.	2641 25th St., 94110	15	15			yes	47484-15	42	1st	DF	Hall 2nd Flr East	8/17/97	ATC	MAL							19
		Buena Vista E.S.	2641 25th St., 94110	15A	15				49292-40	9	1st	DF	Hall 2nd Flr East	10/4/97	ATC	MAL							19
		Buena Vista E.S.	2641 25th St., 94110	15B	15				49292-41	<5	2nd	DF	Hall 2nd Flr East	10/4/97	ATC	MAL							19
		Buena Vista E.S.	2641 25th St., 94110	15C	15			yes	49292-42	11	3rd	DF	Hall 2nd Flr East	10/4/97	ATC	MAL							19
		Buena Vista E.S.	2641 25th St., 94110	16	16				47484-16	22	1st	SDF	Rm 22	8/17/97	ATC	MAL							30
		Buena Vista E.S.	2641 25th St., 94110	16A	16				49292-43	8	1st	SDF	Rm 22	10/4/97	ATC	MAL							30



### Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 NSCA Project B2243																	
Final Interim Report																	
Sample ID	Source ID	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surgeon	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inches)	Fill Time (seconds)	Follow-Up
18C	18	yes	49292-51	26	3rd	SDF	Rm 19	10/4/97	ATC	MAL					1.5	20	
19	19		47484-19	10	1st	SDF	Rm 15	8/17/97	ATC	MAL							
20	20		47484-20	15	1st	SDF	Rm 17	8/17/97	ATC	MAL							
21	21	yes	47484-21	71	1st	SDF	Rm 13	8/17/97	ATC	MAL							
21A	21		49292-52	9	1st	SDF	Rm 13	10/4/97	ATC	MAL							
21B	21		49292-53	5	2nd	SDF	Rm 13	10/4/97	ATC	MAL					3.5	23	
21C	21		49292-54	22	3rd	SDF	Rm 13	10/4/97	ATC	MAL					3.5	23	
22	22	yes	47484-22	30	1st	SDF	Rm 11	8/17/97	ATC	MAL					1.5	23	
22A	22		49292-55	<5	1st	SDF	Rm 11	10/4/97	ATC	MAL						23	
22B	22		49292-56	<5	2nd	SDF	Rm 11	10/4/97	ATC	MAL					2	23	
22C	22		49292-57	8	3rd	SDF	Rm 11	10/4/97	ATC	MAL					2	23	
23	na		47484-23	14	Spike	Blank		8/17/97	ATC	MAL	97-W00752-4	10					
24	na		47484-24	<5	Blank	Blank		8/17/97	ATC	MAL							
24A	na		49292-58	<5	Blank	Blank		10/4/97	ATC	MAL							



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report				Sample				Surveyor				Inter-lab				Comments &				Follow-Up						
Site		Address		Sample ID	Source ID	12 to 15 pph	>15 pph	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)															
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	1		1			yes	9708B57-01	55	1st	SDF	Rm 202	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	1		1			yes	9708B57-02	57	Duplicate	SDF	Rm 202	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	1A		1A				48807-04	7	1st	SDF	Rm 222	8/29/97	SES	MAL																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	1B		1B				48807-05	8	2nd	SDF	Rm 222	8/29/97	SES	MAL																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	1C		1C			yes	48807-06	20	3rd	SDF	Rm 222	8/29/97	SES	MAL																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	2		2		yes		9708B57-03	15	1st	SDF	Rm 219	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	2		2		yes		9708B57-04	15	Duplicate	SDF	Rm 219	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	2A		2A				48807-07	<5	1st	SDF	Rm 219	8/29/97	SES	MAL																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	2B		2B				48807-08	<5	2nd	SDF	Rm 219	8/29/97	SES	MAL																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	2C		2C				48807-09	8	3rd	SDF	Rm 219	8/29/97	SES	MAL																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	3		3				9708B57-05	9	1st	SDF	Rm 217	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	4		4				9708B57-06	7	1st	SDF	Rm 215	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	5		5		yes		9708B57-07	12	1st	SDF	Rm 119	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	6		6		yes		9708B57-08	13	1st	SDF	Rm 117	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	7		7			yes	9708B57-09	33	1st	SDF	Rm 118	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	7A		7A				48807-01	7	1st	SDF	Rm 118	8/29/97	SES	MAL																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	7B		7B				48807-02	7	2nd	SDF	Rm 118	8/29/97	SES	MAL																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	7C		7C			yes	48807-03	31	3rd	SDF	Rm 118	8/29/97	SES	MAL																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	8		8				9708B57-10	5	1st	DF	C93, 1st Flr	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	9		9				9708B57-11	<5	1st	DF	C93, 1st Flr	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	10		10				9708B57-12	<5	1st	SDF	Rm 020, 1st Flr	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	11		11				9708B57-13	<5	1st	SDF	Rm 030, 1st Flr	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	12		12				9708B57-14	<5	1st	SDF	Rm 010, 1st Flr	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	13		13				9708B57-15	<5	1st	DF	C93A, 1st Flr	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	14		14			yes	9708B57-16	22	1st	DF	C90, 2nd Flr, by Rm 211	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	15		15				9708B57-17	8	1st	DF	C90, 1st Flr, by Rm 111	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	16		16				9708B57-18	7	1st	SF	Employees' Kitchen	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	17		17				9708B57-19	10	1st	DF	Rm H01, Basement	8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	18		na				9708B57-20	<5	Blank			8/17/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	BL		na				48807-10	5	Blank			8/29/97	SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	NA1		na						NA		Rooms 106-116, T65, T66		SES	SEQ																					
Burnett C.C./E.S.	1520 Oakdale Ave., 94124	NO1		na						NO		Basement		SES	SEQ																					





### Table 2 - Final Interim Results

[illegible]



SFUSD Lead in Drinking Water Survey - Results Summary  
 Summer / Fall 1997  
 SCA Project B2243

Page 13 of 128. Printed 10/29/97





NSFUSD Lead in Drinking Water Survey - Results Summary  
Summer / Fall 1997  
SCA Project B2243

Page 14 of 128. Printed 10/29/97



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary														
SFUSD Lead in Drinking Water Survey - Summer / Fall 1997 SCA Project B2243		Results Summary												
Site	Address	Sample ID	Source ID	Final Interim Report	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Survevor	Lab
Carver E.S.	1360 Oakdale St., 94124	30	30			yes	47728-24	166	1st	SDF	Lower Level SE Wing	8/1997	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	30A	30			yes	49292-39	5	1st	SDF	Lower Level SE Wing	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	30B	30				49292-40	<5	2nd	SDF	Lower Level SE Wing	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	30C	30				49292-41	12	3rd	SDF	Lower Level SE Wing	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	31	31				47728-25	10	1st	SDF	Lower Level SE Wing	8/1997	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	32	32				47728-26	5	1st	SDF	Lower Level SE Wing	8/1997	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	33	33				47728-27	12	1st	SDF	Lower Level SE Wing	8/1997	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	34	34		yes		47728-28	10	1st	SDF	Lower Level SE Wing	8/1997	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	35	35			yes	47728-29	30	1st	DF	Lower Level Multi-purpose	8/1997	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	35A	35			yes	49292-45	20	1st	DF	Lower Level Multi-purpose	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	35B	35				49292-46	9	2nd	DF	Lower Level Multi-purpose	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	35C	35		yes		49292-47	13	3rd	DF	Lower Level Multi-purpose	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	36	36		yes		47728-30	13	1st	SDF	Lower Level Multi-purpose	8/1997	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	36A	36				49292-48	<5	1st	SDF	Lower Level Multi-purpose	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	36B	36				49292-49	<5	2nd	SDF	Lower Level Multi-purpose	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	36C	36				49292-50	<5	3rd	SDF	Lower Level Multi-purpose	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	37	37		yes		47728-31	14	1st	SF	Lower Level Faculty Dining	8/1997	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	37A	37				49292-51	7	1st	SF	Lower Level Faculty Dining	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	37B	37			yes	49292-52	19	2nd	SF	Lower Level Faculty Dining	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	37C	37			yes	49292-53	50	3rd	SF	Lower Level Faculty Dining	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	38	38			yes	47728-32	27	1st	SF	Lower Level Kitchen	8/1997	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	38A	38				49292-04	<5	1st	SF	Lower Level Kitchen	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	38B	38				49292-05	<5	2nd	SF	Lower Level Kitchen	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	38C	38			yes	49292-06	22	3rd	SF	Lower Level Kitchen	10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	39	na				47728-34	64	Spike			8/1997	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	BL	na				49292-08	<5	Blank			10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	BL	na				47728-33	<5	Blank			8/1997	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	NO1	na						NO	DF		10/597	RGA	MAL
Carver E.S.	1360 Oakdale St., 94124	S	S				49292-07	11	Spike			10/597	RGA	MAL



SFUSD Lead in Drinking Water Survey - Results Summary  
Summer / Fall 1997  
SCA Project B2243

Page 16 of 128, Printed 10/29/97







Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary														
Summer / Fall 1997 SCA Project B2243														
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Chavez E.S.	825 Shawell St., 94110	1	1			48025-01	<5	1st	SF	Kitchen off Rm 2	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	2	2			48025-02	<5	1st	MDF	1st Flr Hall North	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	3	3			48025-03	<5	1st	SDF	Rm 30B	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	4	4			48025-04	6	1st	SF	Rm 151A Kitchen	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	5	5			48025-05	<5	1st	MDF (2)	Corr E of Rm 4	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	6	6			48025-06	<5	1st	MDF (3)	Corr E of Rm 4	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	7	7			48025-07	<5	1st	WCDF	Corr W of Rm 4	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	8	8			48025-08	<5	1st	MDF (3)	Corr W of Rm 4	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	9	9			48025-09	<5	1st	MDF (2)	Corr W of Rm 4	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	10	10			48025-10	<5	1st	MDF (2)	1st Flr Hall South	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	12	12			48025-12	5	1st	MDF (2)	2nd Flr Hall South	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	13	13			48025-13	<5	1st	MDF (2)	2nd Flr Hall North	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	14	14			48025-14	<5	1st	SF	35A Kitchen	8/26/97	ATC	MAL	
Chavez E.S.	825 Shawell St., 94110	11	na			48025-11	21	Spike			8/26/97	ATC	MAL	97-W00753-14
Chavez E.S.	825 Shawell St., 94110	15	na			48025-15	<5	Blank			8/26/97	ATC	MAL	20



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Chin E.S.	350 Broadway St., 94133	1	1		47787-01	7	1st	SF	C91	8/2/97	SCA	MAL	
Chin E.S.	350 Broadway St., 94133	2	2		47787-02	<5	1st	SF	Rm 101	8/2/97	SCA	MAL	
Chin E.S.	350 Broadway St., 94133	3	3		47787-03	20	1st	DF	C90	8/2/97	SCA	MAL	
Chin E.S.	350 Broadway St., 94133	3A	3	yes	9710483-01	10	1st	DF	C90	10/1/97	SCA	SEQ	
Chin E.S.	350 Broadway St., 94133	3B	3		9710483-02	6	2nd	DF	C90	10/1/97	SCA	SEQ	
Chin E.S.	350 Broadway St., 94133	3C	3	yes	9710483-03	15	3rd	DF	C90	10/1/97	SCA	SEQ	
Chin E.S.	350 Broadway St., 94133	4	4		47787-04	10	1st	DF	C90	8/2/97	SCA	MAL	
Chin E.S.	350 Broadway St., 94133	5	5	yes	47787-05	18	1st	MDF	Ext 1	8/2/97	SCA	MAL	
Chin E.S.	350 Broadway St., 94133	5A	5		9710483-04	<5	1st	MDF	Ext 1	10/1/97	SCA	SEQ	
Chin E.S.	350 Broadway St., 94133	5B	5		9710483-05	6	2nd	MDF	Ext 1	10/1/97	SCA	SEQ	
Chin E.S.	350 Broadway St., 94133	5C	5		9710483-06	<5	3rd	MDF	Ext 1	10/1/97	SCA	SEQ	
Chin E.S.	350 Broadway St., 94133	6	na		47787-06	<5	Blank	MDF	Ext 1	8/2/97	SCA	MAL	
Chin E.S.	350 Broadway St., 94133	BL	na		9710483-08	<5	Blank			10/1/97	SCA	SEQ	
Follow-Up	Fill Time (second)	Arch Height (inch)	Comments & Field IDs	Inter-lab Results (ppb)	Spike Level (ppb)	Spike ID #	Lab	Surveyor	Sample Date	Room	Source Type	Sample Type	Results (ppb)
	60	0.5											
	60	0.5											
	60	0.5											
	25	2											
	25	2											
	25	2											
	25	2											



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary																						
Site		Address	Sample ID	Final Interim Report		Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source	Room	Sample Date	Surveyor	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
1	Chinatown Youth Center	1693 Polk St, 94109	1			1			49354-01	6	1st	SF	Room 112	10/9/97	AAE	MAL						
2	Chinatown Youth Center	1693 Polk St, 94109	2			2			49354-02	<5	1st	SF	Room 111	10/9/97	AAE	MAL						
3	Chinatown Youth Center	1693 Polk St, 94109	3			3			49354-03	<5	1st	SF	Room 109	10/9/97	AAE	MAL						
4	Chinatown Youth Center	1693 Polk St, 94109	4			4			49354-04	<5	1st	SF	Room 207	10/9/97	AAE	MAL						





Table 2 - Final Interim Results

[illegible]



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report		Results (ppb)		Sample Type		Source Type		Room		Sample Date		Surveyor		Lab		Spike ID #		Spike Level (ppb)		Inter-lab Results (ppb)		Comments & Field ID's		Arch Height (inch)		Fill Time (second)		Follow-Up	
Site		Address		Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up																	
Clarendon E.S.	500 Clarendon Ave., 94131	1						47608-01	<5	1st	SF	Kitchen, Rm 124	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	2						47608-02	<5	1st	SF	Kitchen, Rm 124	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	3				yes		47608-03	12	1st	DF	C92	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	4						47608-04	<5	1st	SF	Rm 106, Nurse	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	5						47608-05	<5	1st	DF	C91	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	6						47608-06	<5	1st	DF	Rm 103	8/17/97	SES	MAL			<5																					
Clarendon E.S.	500 Clarendon Ave., 94131	7						47608-07	<5	1st	DF	Rm 102	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	8						47608-08	<5	1st	DF	Rm 105	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	9						47608-09	5	1st	DF	Rm 107	8/17/97	SES	MAL			<5																					
Clarendon E.S.	500 Clarendon Ave., 94131	10						47608-10	<5	1st	DF	Rm 109	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	11						47608-11	<5	1st	DF	Rm 110	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	12						47608-12	<5	1st	DF	Rm 116	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	13						47608-13	<5	1st	DF	Rm 1	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	14						47608-14	<5	1st	DF	Rm 3	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	15						47608-15	<5	1st	DF	Rm 5	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	16						47608-16	<5	1st	DF	Rm 5	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	17						47608-17	<5	1st	MDF	Basement by Rm 203	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	18						47608-18	<5	1st	DF	Rm 203	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	19						47608-19	<5	1st	DF	Rm 205	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	20						47608-20	<5	1st	DF	Rm 207	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	21						47608-21	<5	1st	DF	Rm 209	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	22						47608-22	<5	1st	DF	Rm 214	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	23						47608-23	<5	1st	DF	Rm 206	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	24						47608-24	<5	1st	DF	Rm 204	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	25						47608-25	<5	1st	DF	C80	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	26						47608-26	<5	1st	MDF	1st Flr, Outside Bldg & T52	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	27						47608-27	<5	1st	SDF	Bungalow Classrm	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	28						47608-28	10	1st	SDF	Bungalow Classrm	8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	29	na					47608-29	<5	Blank			8/17/97	SES	MAL																								
Clarendon E.S.	500 Clarendon Ave., 94131	30	na					47608-30	21	Spike			8/17/97	SES	MAL	97-W00761-16	30																						
Clarendon E.S.	500 Clarendon Ave., 94131	NO1	na							NO	DF	1st Fl, West		SES	MAL				non-operational																				



SFUSD Lead in Drinking Water Survey - Results Summary  
 Summer / Fall 1997  
 SCA Project B2243

Site	Address	Sample ID	Source ID	Final Interim Report	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveys	Lab	Spike ID #	Spike Level (ppb)	Inter-Lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
Cleveland E.S.	455 Athens St., 94112	1	1		<5	1st	SF	Basement Girls Rm	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	2	2		<5	1st	WF	Basement WF, Left	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	3	3		<5	1st	WF	Basement WF, Right	8/22/97	AEE	MAL			<5				
Cleveland E.S.	455 Athens St., 94112	4	4		<5	1st	SF	Basement Boys' Rm	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	5	5		<5	1st	WF	Rm 105A	8/22/97	AEE	MAL			<5				
Cleveland E.S.	455 Athens St., 94112	6	6		<5	1st	WF	Rm 108A	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	7	7		<5	1st	DF	1st Fl. C90, Hall	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	8	8		<5	1st	WF	Office RR	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	9	9		<5	1st	WF	Principal RR	8/22/97	AEE	MAL			<5				
Cleveland E.S.	455 Athens St., 94112	11	11		<5	1st	SF	1st Flr. Hall RR	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	12	12		<5	1st	WF	Rm 210A	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	13	13		<5	1st	WF	Faculty Lunch Rm	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	14	14		<5	1st	SF	Rm 211A	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	15	15		<5	1st	SF	Rm 212A	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	16	16		<5	1st	SF	Rm 214A	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	17	17		<5	1st	SF	Rm 215A	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	18	18		<5	1st	DF	2nd Flr C90, Hall	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	19	19		<5	1st	WF	Rm B03A	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	22	22		<5	1st	DF	Rm B01A	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	23	23		<5	1st	SF	Rm B01A	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	24	24		<5	1st	MDF	Yard, Left Side	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	25	25		6	1st	MDF	Yard, Right Side	8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	10	na		<5	Blank			8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	20	na		<5	Blank			8/22/97	AEE	MAL							
Cleveland E.S.	455 Athens St., 94112	97-W00753-5	na		18	Spike			8/22/97	AEE	MAL		20					





SFUSD Lead in Drinking Water Survey - Results Summary  
Summer / Fall 1997  
SCA Project B2243

Page 23 of 128. Printed 10/29/97



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243																		
Site	Address	Sample ID	Final Interim Report		Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow Up
			Source ID	12 to 15 ppb														
Cooper C.C.	940 Filbert St., 94109	1	1		47743-01	<5	1st	SF	1st Flr. West Classroom	8/21/97	RGA	MAL						
Cooper C.C.	940 Filbert St., 94109	2	2		47743-02	<5	1st	SF	1st Flr. East Classroom	8/21/97	RGA	MAL						
Cooper C.C.	940 Filbert St., 94109	3	3		47743-03	5	1st	SF	2nd Flr. East Classroom	8/21/97	RGA	MAL						
Cooper C.C.	940 Filbert St., 94109	4	4		47743-04	10	1st	SF	2nd Flr. West Side Classroom	8/21/97	RGA	MAL						
Cooper C.C.	940 Filbert St., 94109	5	5		47743-05	<5	1st	SF	2nd Flr. West Side Kitchen	8/21/97	RGA	MAL						
Cooper C.C.	940 Filbert St., 94109	6	6		47743-06	<5	1st	SF	2nd Flr. Middle Classroom	8/21/97	RGA	MAL						
Cooper C.C.	940 Filbert St., 94109	7	na		47743-07	<5		Blank		8/21/97	RGA	MAL						
Cooper C.C.	940 Filbert St., 94109	8	na		47743-08	47		Spike		8/21/97	RGA	MAL	97-W00765-3	50	49			



**SFUSD Lead in Drinking Water Survey - Results Summary**  
**Summer / Fall 1997**  
**SCA Project B2243**

Page 25 of 128. Printed 10/29/97





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary													
Summer / Fall 1997													
SCA Project B.2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)
Davis M.S. (Hudson)	1150 Hudson St.	1	1		<5	1st	SF	Rm 002R, Kitchen/Sink, Basement	8/17/97	SES	SEQ		
Davis M.S. (Hudson)	1150 Hudson St.	1	1		<5	Duplicate	SF	Rm 002R, Kitchen/Sink, Basement	8/17/97	SES	SEQ		
Davis M.S. (Hudson)	1150 Hudson St.	2	2		<5	1st	SF	Rm 002R, Kitchen/Sink, Basement	8/17/97	SES	SEQ		
Davis M.S. (Hudson)	1150 Hudson St.	3	3		<5	1st	DF	Gym Bldg	8/17/97	SES	SEQ		
Davis M.S. (Hudson)	1150 Hudson St.	4	4		<5	1st	MDF	Outside Gym	8/17/97	SES	SEQ		
Davis M.S. (Hudson)	1150 Hudson St.	5	5		<5	1st	DF	C90, by Rm 105	8/17/97	SES	SEQ		
Davis M.S. (Hudson)	1150 Hudson St.	6	6		<5	1st	DF	C91, by Rm 119 Entry	8/17/97	SES	SEQ		
Davis M.S. (Hudson)	1150 Hudson St.	7	7		<5	1st	DF	C91, Across Rm 116 Doorway	8/17/97	SES	SEQ		
Davis M.S. (Hudson)	1150 Hudson St.	7A	7	yes	<5	1st	DF	C91, Across Rm 116 Doorway	8/29/97	SES	MAL		
Davis M.S. (Hudson)	1150 Hudson St.	7B	7		<5	2nd	DF	C91, Across Rm 116 Doorway	8/29/97	SES	MAL		
Davis M.S. (Hudson)	1150 Hudson St.	7C	7	yes	15	3rd	DF	C91, Across Rm 116 Doorway	8/29/97	SES	MAL		
Davis M.S. (Hudson)	1150 Hudson St.	8	8		<5	1st	DF	Across from 116 Doorway C9	8/17/97	SES	SEQ		
Davis M.S. (Hudson)	1150 Hudson St.	10	10		<5	1st	SF	Calateria	8/17/97	SES	SEQ		
Davis M.S. (Hudson)	1150 Hudson St.	9	na		<5	Blank			8/17/97	SES	SEQ		
Davis M.S. (Hudson)	1150 Hudson St.	11	na		18	Spike			8/17/97	SES	SEQ	97-W00757-15	7777
Davis M.S. (Hudson)	1150 Hudson St.	BL	na		<5	Blank			8/29/97	SES	MAL		



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243					Final Interim Report		Sample ID		Source ID		12 to 15 pph		>15 pph		Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Arch Height (inch)	Fill Time (second)	Follow-Up
De Avila E.S.	2				2										47421-02	6	1st	DF	Library, 1st Flr	8/15/97	QST	MAL						
De Avila E.S.	3				3										47421-03	5	1st	DF	By Rm 209	8/15/97	QST	MAL						
De Avila E.S.	4				4										47421-04	<5	1st	DF	Playgrd East, Waller St	8/15/97	QST	MAL						
De Avila E.S.	5				5										47421-05	<5	1st	DF	Playground	8/15/97	QST	MAL			<5			
De Avila E.S.	6				6										47421-06	<5	1st	MDF	Playground West, 1st Flr Level	8/15/97	QST	MAL						
De Avila E.S.	7				7										47421-07	<5	1st	MDF	Playground West, 1st Flr Level	8/15/97	QST	MAL						
De Avila E.S.	8				8										47421-08	<5	1st	MDF	North Side, Basement Level	8/15/97	QST	MAL						
De Avila E.S.	9				9							yes			47421-09	13	1st	MDF	East Side, Basement Level	8/15/97	QST	MAL						
De Avila E.S.	9A				9A										49189-01	<5	1st	MDF	Basement, East	10/2/97	QST	MAL						
De Avila E.S.	9B				9B										49189-02	<5	2nd	MDF	Basement, East	10/2/97	QST	MAL						
De Avila E.S.	9C				9C										49189-03	<5	3rd	MDF	Basement, East	10/2/97	QST	MAL						
De Avila E.S.	10				10										47421-10	<5	1st	DF	1st Flr Level by Women's Rm	8/15/97	QST	MAL						
De Avila E.S.	11				11										47421-11	5	1st	SF	Library Office, 1st Flr	8/15/97	QST	MAL						
De Avila E.S.	12				12										47421-12	10	1st	DF	Bitwm Rms 309 & 310	8/15/97	QST	MAL						
De Avila E.S.	13				13										47421-13	<5	1st	MDF	Playgrd East, 1st Flr Level	8/15/97	QST	MAL						
De Avila E.S.	1				1	na									47421-01	<5	Blank			8/15/97	QST	MAL	97-W00752-9	10				
De Avila E.S.	14				14	na									47421-14	11	Spike			8/15/97	QST	MAL						
De Avila E.S.	BL				BL	na									49189-04	<5	Blank			10/2/97	QST	MAL						



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Final Interim Report		Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)
			Source ID	12 to 15 ppb									
Dennan M.S.	241 Onieda Ave., 94112	1	1		<5	1st	DF	S84, 1st Flr	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	2	2		<5	1st	DF	Basement flr, Rm 050	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	3	3		<5	1st	DF	C99, Basement	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	4	4		5	1st	DF	C99, 1st Flr	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	5	5		<5	1st	DF	C95, 1st Flr, by Rm 105	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	6	6		<5	1st	DF	C95, 1st Flr, by Rm 114E	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	7	7		<5	1st	DF	C91, 1st Flr, Auditorium Wing	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	8	8		<5	1st	DF	C95, 2nd Flr, by Rm 204	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	9	9		<5	1st	DF	C95, 2nd Flr, by Rm 214	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	10	10		<5	1st	DF	C95, 3rd Flr, by Rm 314	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	11	11		<5	1st	DF	C95, 3rd Flr, by Rm 304	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	12	12		<5	1st	DF	Ext Courtyard by Rm 005	9/17/97	SES	MAL	97-W00760-14	20
Dennan M.S.	241 Onieda Ave., 94112	13	na		21	Spike	Blank		9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	14	na		<5	Blank		Basement Kitchen Room 055	9/17/97	SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	NA1	na			NA				SES	MAL		
Dennan M.S.	241 Onieda Ave., 94112	NO1	na			NO				SES	MAL		
													non-accessible non-operational





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243												
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab
Downtown H.S.	110 Barlett St, 94110	1	1		48116-01	8	1st	DF	C91, 1st Flr	8/30/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	1A	1		49320-01	15	1st	DF	1st Fl, C-90	10/4/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	1B	1	yes	49320-02	5	2nd	DF	1st Fl, C-90	10/4/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	1C	1	yes	49320-03	12	3rd	DF	1st Fl, C-90	10/4/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	2	2		48116-02	<5	1st	DF	C91, 2nd Flr	8/30/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	3	3		48116-03	9	1st	DF	C91, 3rd Flr	8/30/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	4	4		48116-04	<5	1st	SE	Rm310, Sm Kitchen	8/30/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	5	5		48116-05	12	1st	DF	C91, 4th Flr	8/30/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	6	6	yes	48116-06	27	1st	DF	C90, 1st Flr	8/30/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	7	7	yes	48116-07	28	1st	DF	C90, 2nd Flr	8/30/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	8	na		48116-08	<5	Blank			8/30/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	31	na		49320-04	<5	Blank			10/4/97	SFUSD	MAL
Downtown H.S.	110 Barlett St, 94110	NO1	na				NO	DF	outside Room 404			non-operational



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report											
Site	Address	Sample ID	Source ID	12 to 15 ppb	15 to 15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inches)	Fill Time (second)	Follow-Up		
Drew E.S.	50 Penoma St., 94124	3	3			9708757-24	<5	Duplicate SDF	Rm CC03	Rm CC03	8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	12	12			9708757-25	<5	Duplicate SDF	Cafeteria		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	18	18			9708757-26	5	Duplicate SDF	Rm 203/205		5/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	1	1			9708757-01	<5	SF	Kitchen		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	10	10			9708757-10	<5	SDF		Rm 108	8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	11	11			9708757-11	<5	SF	Corr by Janitor's Office		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	12	12			9708757-12	<5	MDF		Rm CC02	8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	13	13			9708757-13	7	SF	Kitchen, Upstairs		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	14	14			9708757-14	<5	SF	Corr. Main Office		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	15	15			9708757-15	<5	SF	Copy Rm		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	16	16			9708757-16	6	SF	Stationary Rm		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	17	17			9708757-17	<5	SF	Rm 108, Counselor's Office		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	18	18			9708757-18	5	SDF	Rm 203/205		8/14/97	ESI	SEQ		21						
Drew E.S.	50 Penoma St., 94124	19	19	yes		9708757-19	14	SF	Rm 205 Office		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	2	2			9708757-02	<5	SF	Break Rm		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	20	20			9708757-20	8	SF	Rm 208/201 Office		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	23	23	yes		9708757-23	13	SF	Playground		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	3	3			9708757-03	<5	SDF	Rm CC03		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	4	4			9708757-04	<5	SDF	Rm CC02		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	5	5			9708757-05	<5	SDF	1		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	6	6			9708757-06	9	SDF	6		8/14/97	ESI	SEQ		31						
Drew E.S.	50 Penoma St., 94124	7	7			9708757-07	7	SDF	5		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	8	8			9708757-08	<5	SDF	4		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	9	9			9708757-09	<5	SF	Playground		8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	22	na			9708757-22	<5	Blank			8/14/97	ESI	SEQ								
Drew E.S.	50 Penoma St., 94124	21	na			9708757-21	5	Spike			8/14/97	ESI	SEQ	not recorded							
Drew E.S.	50 Penoma St., 94124	NO1	na					NO	DF	Room 102	8/14/97	ESI	SEQ						non-operational		
Drew E.S.	50 Penoma St., 94124	NO10	na					NO	DF	Room 203		ESI	SEQ						non-operational		
Drew E.S.	50 Penoma St., 94124	NO11	na					NO	DF	Room 206		ESI	SEQ						non-operational		
Drew E.S.	50 Penoma St., 94124	NO12	na					NO	DF	Room 207		ESI	SEQ						non-operational		
Drew E.S.	50 Penoma St., 94124	NO2	na					NO	DF	Room 103		ESI	SEQ						non-operational		
Drew E.S.	50 Penoma St., 94124	NO3	na					NO	DF	Room 106		ESI	SEQ						non-operational		
Drew E.S.	50 Penoma St., 94124	NO4	na					NO	DF	Room 107		ESI	SEQ						non-operational		
Drew E.S.	50 Penoma St., 94124	NO5	na					NO	DF	Room 117		ESI	SEQ						non-operational		
Drew E.S.	50 Penoma St., 94124	NO6	na					NO	DF	Room 118		ESI	SEQ						non-operational		
Drew E.S.	50 Penoma St., 94124	NO7	na					NO	DF	Room 121		ESI	SEQ						non-operational		
Drew E.S.	50 Penoma St., 94124	NO8	na					NO	DF	Room 122		ESI	SEQ						non-operational		
Drew E.S.	50 Penoma St., 94124	NO9	na					NO	DF	Room 202		ESI	SEQ						non-operational		



Page 31 of 128. Printed 10/29/97





SFUSD Lead in Drinking Water Survey - Results Summary										Final Interim Report		Sample ID		Source ID		12 to 15 ppb		>15 ppb		Lab ID		Results		Sample Type		Source		Room		Sample Date		Surveyor		Spike ID #		Spike Level (ppb)		Inter-lab Results (ppb)		Comments & Field ID's		Arch Height (inch)		Fill Time (second)		Follow-Up																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
Summer / Fall 1997 SCA Project B243	El Dorado E.S.	70 Delta St., 94134	1A																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																															</



### Table 2 - Final Intern Results

Page 33 of 128. Printed 10/29/97



Page 34 of 128. Printed 10/29/97





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report		Sample										Room										Surveys										Spike ID #										Inter-Jab Results (ppb)										Comments & Field ID's										Arch Height (inches)										Fill Time (seconds)										Follow-Up																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
Site										Address										Sample ID		Source ID		12 to 15 ppb		>15 ppb		Lab ID		Results (ppb)		Sample Type		Source Type		Room		Sample Date		Surveys		Lab		Spike ID #		Spike Level (ppb)		Inter-Jab Results (ppb)		Comments & Field ID's		Arch Height (inches)		Fill Time (seconds)		Follow-Up																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
Fairmont E.S.										65 Cheney St. 94131										1	1					47846-01	<5	1st	SF	Upper Level Bldg C by Stove	8/26/97	AAE	MAL																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary																			
Summer / Fall 1997 SCA Project B2243																			
Site	Address	Sample ID	Final Interim Report		Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
			Source ID	12 to 15 ppb															
Filipino Education Ctr	824 Harrison St, 94107	1		yes	47739-01	14	1st	DF	1	8/16/97	RGA	MAL							
Filipino Education Ctr	824 Harrison St, 94107	1A	1		49297-01	<5	1st	SDF	Room 1	10/1/97	RGA	MAL						62	
Filipino Education Ctr	824 Harrison St, 94107	1B	1		49297-02	5	2nd	SDF	Room 1	10/1/97	RGA	MAL						62	
Filipino Education Ctr	824 Harrison St, 94107	1C	1		49297-03	<5	3rd	SDF	Room 1	10/1/97	RGA	MAL						62	
Filipino Education Ctr	824 Harrison St, 94107	2			47739-02	6	1st	DF	2	8/16/97	RGA	MAL			7				
Filipino Education Ctr	824 Harrison St, 94107	3			47739-03	<5	1st	DF	3	8/16/97	RGA	MAL							
Filipino Education Ctr	824 Harrison St, 94107	4			47739-04	7	1st	DF	4	8/16/97	RGA	MAL							
Filipino Education Ctr	824 Harrison St, 94107	5			47739-05	5	1st	DF	5	8/16/97	RGA	MAL							
Filipino Education Ctr	824 Harrison St, 94107	6			47739-06	5	1st	DF	6	8/16/97	RGA	MAL							
Filipino Education Ctr	824 Harrison St, 94107	7			47739-07	<5	1st	DF	7	8/16/97	RGA	MAL							
Filipino Education Ctr	824 Harrison St, 94107	8			47739-08	6	1st	SF	Kitchen	8/16/97	RGA	MAL							
Filipino Education Ctr	824 Harrison St, 94107	9			47739-09	<5	1st	DF		8/16/97	RGA	MAL							
Filipino Education Ctr	824 Harrison St, 94107	10			47739-10	8	1st	SF	Staff Kitchen	8/16/97	RGA	MAL							
Filipino Education Ctr	824 Harrison St, 94107	11			47739-12	<5	1st	DF	Outside	8/16/97	RGA	MAL							
Filipino Education Ctr	824 Harrison St, 94107	12	na		47739-13	57	Spike			8/16/97	RGA	MAL	97-W00765-16	50					
Filipino Education Ctr	824 Harrison St, 94107	BL	na		47739-11	<5	Blank			8/16/97	RGA	MAL							
Filipino Education Ctr	824 Harrison St, 94107	BL	na		49297-04	<5	Blank			10/1/97	RGA	MAL							



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Fluor E.S.	3125 Cesar Chavez St., 94110	1	1		47524-01	<5	1st	MDF	190 (Hall)	8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	2	2		47524-02	<5	1st	WCDF	190 (Hall)	8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	3	3		47524-03	<5	1st	SDF	108 B	8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	4	4		47524-04	10	1st	SF	108 B	8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	5	5		47524-05	<5	1st	SF	202	8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	6	6	yes	47524-06	30	1st	SF	211	8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	6A	6		9710493-04	<5	1st	SF	211	9/26/97	SCA	SEQ	
Fluor E.S.	3125 Cesar Chavez St., 94110	6B	6		9710493-05	<5	2nd	SF	211	9/26/97	SCA	SEQ	10
Fluor E.S.	3125 Cesar Chavez St., 94110	6C	6		9710493-06	11	3rd	SF	211	9/26/97	SCA	SEQ	10
Fluor E.S.	3125 Cesar Chavez St., 94110	6C	6		9710493-07	10	Duplicate	SF	211	9/26/97	SCA	SEQ	10
Fluor E.S.	3125 Cesar Chavez St., 94110	7	7		47524-07	<5	1st	MDF	230 (Hall)	8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	8	8		47524-08	<5	1st	WCDF	230 (Hall)	8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	9	9		47524-09	<5	1st	WCDF	350 (Hall)	8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	10	10	yes	47524-10	14	1st	MDF	350 (Hall)	8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	10A	10		9710493-01	<5	1st	MDF	350 (Hall)	9/26/97	SCA	SEQ	
Fluor E.S.	3125 Cesar Chavez St., 94110	10B	10		9710493-02	<5	2nd	MDF	350 (Hall)	9/26/97	SCA	SEQ	45
Fluor E.S.	3125 Cesar Chavez St., 94110	10C	10		9710493-03	<5	3rd	MDF	350 (Hall)	9/26/97	SCA	SEQ	45
Fluor E.S.	3125 Cesar Chavez St., 94110	11	na		47524-11	22	Spike			8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	12	na		47524-12	<5	Blank			8/17/97	SCA	MAL	
Fluor E.S.	3125 Cesar Chavez St., 94110	1B1	na		9710493-08	<5	Blank			9/26/97	SCA	SEQ	
Fluor E.S.	3125 Cesar Chavez St., 94110	1A1	na				NA		2nd FI Rooms (except 202, 211)		SCA	SEQ	
Fluor E.S.	3125 Cesar Chavez St., 94110	1A2	na				NA		all 3rd FI Rooms		SCA	SEQ	





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report		Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab
Francisco M.S.	2190 Powell St., 94133	1	1			47414-01	<5	1st	DF	2nd Flr Main Bldg	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	3	3			47414-03	9	1st	DF	1st Flr Main Bldg	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	4	4			47414-04	10	1st	SF	Rm 115	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	5	5			47414-05	9	1st	DF	1st Flr Main Bldg	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	6	6			47414-06	7	1st	DF	Shop Wing, 2nd Flr	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	7	7			47414-07	<5	1st	DF	Shop Wing, 2nd Flr	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	9	9			47414-09	<5	1st	DF	East Wing, 3rd Flr	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	10	10			47414-10	<5	1st	MDF	Lower Yard	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	11	11			47414-11	<5	1st	MDF	Upper Yard	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	12	12			47414-12	<5	1st	DF	Basement Gym Annex	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	13	13			47414-13	9	1st	DF	Rm 400, Basement Gym Annex	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	14	14			47414-14	34	Blank	DF	Gym Annex 1st Fl	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	15	na		yes	47414-15	<5	Blank	DF	Room 403	8/12/97	SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	NO1	na					NO	DF	Room 404		SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	NO2	na					NO	DF	outside Room 215		SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	NO3	na					NO	DF	outside Room 301		SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	NO4	na					NO	DF	outside Room 414		SFUSD	MAL
Francisco M.S.	2190 Powell St., 94133	NO5	na					NO	DF			SFUSD	MAL



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary		Final Interim Report		Sample ID	Source ID	Source 12 to 15		Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveys	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
Summer / Fall 1997		SCA Project B.2243				Source 12 to 15	ppb														
Franklin M.S.	1430 Scott St, 94115	2	2	2	2	47692-02	<5	1st	DF	Rm 8, Front	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	3	3	3	3	47692-03	<5	1st	DF	Rm 14, Front	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	4	4	4	4	47692-04	<5	1st	DF	Rm 102, Front	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	5	5	5	5	47692-05	<5	1st	DF	Rm 30, Girls Gym	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	6	6	6	6	47692-06	<5	1st	MDF	Rm 40, Caleteria	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	7	7	7	7	47692-07	<5	1st	SDF	Rm 41, Kitchen, Basem	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	8	8	8	8	47692-08	<5	1st	SDF	Rm 41, Kitchen, Basem	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	9	9	9	9	47692-09	<5	1st	SDF	Rm 41, Kitchen, Basem	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	10	10	10	10	47692-10	8	1st	SDF	Rm 41, Kitchen, Basem	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	11	11	11	11	47692-11	<5	1st	DF	Rm 113, Front	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	12	12	12	12	47692-12	<5	1st	SDF	Rm 119A Teachers' Lounge	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	13	13	13	13	47692-13	<5	1st	DF	Rm 206, Front	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	14	14	14	14	47692-14	7	1st	DF	Rm 214A, Front	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	15	15	15	15	47692-15	6	1st	DF	Rm 240, Hall Outside	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	16	16	16	16	47692-16	<5	1st	DF	Rm 2, Boys' Gym, Annex	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	17	17	17	17	47692-17	13	1st	MDF	Rm 16, Playground Outside	8/22/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	17A	17	17	17	49187-01	<5	1st	MDF	Outside Room 16 PG	10/29/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	17B	17	17	17	49187-02	<5	2nd	MDF	Outside Room 16 PG	10/29/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	17C	17	17	17	49187-03	<5	3rd	MDF	Outside Room 16 PG	10/29/97	QST	MAL								
Franklin M.S.	1430 Scott St, 94115	18	na	na	na	49187-04	<5	Blank	Blank												
Franklin M.S.	1430 Scott St, 94115	BL	na	na	na	49187-04	<5	Blank	Blank												



Page 40 of 128 Printed 10/29/97





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Final Interim Report		Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
			Source ID	12 to 15 ppb									
Garfield E.S.	420 Filbert St., 94133	2	2	yes	47730-01	29	1st	DF	Rm 403	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	3	3	yes	47730-02	20	1st	DF	Rm 405	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	4	4	yes	47730-03	22	1st	DF	Rm 408	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	5	5	yes	47730-04	45	1st	DF	Rm 409	8/17/97	RGA	MAL	28
Garfield E.S.	420 Filbert St., 94133	6	6	yes	47730-05	104	1st	DF	Rm 411	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	7	7	yes	47730-08	60	1st	DF	Rm 315	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	8	8	yes	47730-09	1203	1st	DF	Rm 314	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	9	9	yes	47730-10	25	1st	DF	Rm 316	8/17/97	RGA	MAL	28
Garfield E.S.	420 Filbert St., 94133	10	10	yes	47730-11	26	1st	DF	Rm 313	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	11	11	yes	47730-12	83	1st	DF	Rm 305	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	12	12	yes	47730-13	20	1st	DF	Rm 302	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	13	13	yes	47730-14	75	1st	DF	Rm 303	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	15	15	yes	47730-15	25	1st	DF	Rm 220	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	16	16	yes	47730-16	85	1st	DF	Rm 104	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	17	17	yes	47730-17	108	1st	DF	Rm 105	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	18	18	yes	47730-18	10	1st	SF	Rm 103 Kitchen	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	19	19	yes	47730-19	68	1st	DF	Rm 201	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	20	20	yes	47730-20	34	1st	DF	Rm 202	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	21	21	yes	47730-21	66	1st	DF	Rm 206	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	22	22	yes	47730-22	57	1st	DF	Rm 205	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	23	23	yes	47730-23	41	1st	DF	Rm 203	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	24	24	yes	47730-24	78	1st	DF	Rm 222	8/17/97	RGA	MAL	
Garfield E.S.	420 Filbert St., 94133	25	na	na	47730-07	57	Spike			8/17/97	RGA	MAL	50
Garfield E.S.	420 Filbert St., 94133	BL	na	na	47730-06	<5	Blank			8/17/97	RGA	MAL	97-W00765-13



NSF/USD Lead in Drinking Water Survey - Results Summary			Final Interim Report																					
Summer / Fall 1997		SCA Project B243		Sample ID	Source ID	12 to 15 ppb	>15 ppb	1 Lab ID	Results	Sample Type	Source Type	Room	Sample Date	Surveyor	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up			
Summer	SCA Project B243	Giannini J.H.	3151 Ortega St., 94122	2	2			47642-02	<5	1st	DF	Rm 116 Outside	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	3	3			47642-03		1st	DF	COOKING AREA ROOM 104	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	4	4			47642-04	<5	1st	DF	OUTSIDE ROOM 101	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	5	5			47642-05	<5	1st	DF	ROOM 040	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	7	7			47642-07	7	1st	DF	ROOM 041	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	9	9			47642-08	<5	1st	DF	GYM ROOM 141	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	10	10			47642-09	<5	1st	DF	OUTSIDE ROOM 201	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	11	11			47642-10	<5	1st	DF	OUTSIDE ROOM 220	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	12	12			47642-11	<5	1st	DF	OUTSIDE ROOM 216	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	13	13			47642-12	<5	1st	DF	CAFETERIA WALL ROOM	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	14	14			47642-13	<5	1st	DF	CAFETERIA WALL ROOM	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	15	15			47642-14	<5	1st	DF	CAFETERIA KITCHEN BAC	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	16	16			47642-15	14	1st	SF	CAFETERIA KITCHEN BAC	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	17	17			47642-16	<5	1st	SF	CAFETERIA KITCHEN BAC	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	18	18			47642-17	<5	1st	SF	CAFETERIA KITCHEN BAC	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	19	19			47642-18	<5	1st	DF	HALLWAY OUTSIDE AUD	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	20	20			47642-19	<5	1st	DF	HALLWAY OUTSIDE AUD	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	21	21			47642-20	<5	1st	SF	ROOM 230 - COOKING ARE	8/21/97	QST	MAL			5						
		Giannini J.H.	3151 Ortega St., 94122	22	22			47642-21	<5	1st	SF	ROOM 230 - COOKING ARE	8/21/97	QST	MAL			7						
		Giannini J.H.	3151 Ortega St., 94122	23	23			47642-22	<5	1st	SF	ROOM 230 - COOKING ARE	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	24	24			47642-23	<5	1st	SF	ROOM 230 - COOKING ARE	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	25	25			47642-24	<5	1st	SF	ROOM 230 - COOKING ARE	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	26	26			47642-25	8	1st	SF	230 (Cooking Area)	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	28	28			47642-27	<5	1st	DF	THIRD FLOOR PLAY - HAL	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	29	29			47642-28	<5	1st	MDF	THIRD FLOOR PLAYGROU	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	30	30			47642-29	<5	1st	SF	ROOM 119 - WORK ROOM	8/21/97	QST	MAL									
		Giannini J.H.	3151 Ortega St., 94122	31	31			48317-01	<5	1st	SF	COOKING AREA ROOM 236	9/9/97	QST	MAL									
Giannini J.H.	3151 Ortega St., 94122	32	32			48317-02	<5	1st	SF	COOKING AREA ROOM 236	9/9/97	QST	MAL											
Giannini J.H.	3151 Ortega St., 94122	33	33			48317-03	<5	1st	SF	COOKING AREA ROOM 236	9/9/97	QST	MAL											
Giannini J.H.	3151 Ortega St., 94122	1	na			47642-01	36	Blank Spike				8/21/97	QST	MAL										
Giannini J.H.	3151 Ortega St., 94122	6	na			47642-06	36					8/21/97	QST	MAL	97-W00671-19	30								
Giannini J.H.	3151 Ortega St., 94122	27	na			47642-26	28	Spike				8/21/97	QST	MAL	97-W00671-14	30								
Giannini J.H.	3151 Ortega St., 94122	NO1	na					NO	MDF		Yard outside Room 101	8/21/97	QST	MAL										
Giannini J.H.	3151 Ortega St., 94122	NO2	na					NO	DF		Room 231	8/21/97	QST	MAL			non-operational							
Giannini J.H.	3151 Ortega St., 94122	NO3	na					NO	DF		4th Floor	8/21/97	QST	MAL			non-operational							



SFUSD Lead in Drinking Water Survey - Results Summary  
Summer / Fall 1997  
SCA Project B2243

NSF/USD Lead in Drinking Water Survey - Results Summary																						
Summer / Fall 1997																						
NSA Project B2243																						
Site	Address	Sample ID	Final Interim Report		Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results	Sample Type	Source	Room	Sample Date	Surveyor	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up	
																						1st
1	151 Leppard St., 94131	1			1	yes		47413-01	12	1st	DF	OUTSIDE YARD EAST SIDE	8/12/97	SFUSD								
2	151 Leppard St., 94131	2			2			47413-02	6	1st	DF	OUTSIDE YARD WEST SIDE	8/12/97	SFUSD								
3	151 Leppard St., 94131	3			3			47413-03	<5	1st	DF	CORRIDOR C-90 FIRST FLD	8/12/97	SFUSD								
4	151 Leppard St., 94131	4			4			47413-04	8	1st	DF	CORRIDOR C-90 SECOND FLD	8/12/97	SFUSD								
5	151 Leppard St., 94131	5			5			47413-05	8	1st	SF	STAFF LUNCH ROOM - KIT	8/12/97	SFUSD								
6	151 Leppard St., 94131	6	na		na			47413-06	<3	Blank			8/12/97	SFUSD								





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Golden Gate Annex	1601 Turk St., 94115	2	2		970B64-02	<3	1st	SF	Rm 14A, Cooking Area, 2nd Flr	8/19/97	QST	SEQ	
Golden Gate Annex	1601 Turk St., 94115	2	2		970B64-03	<3	Duplicate	SF	Rm 14A, Cooking Area, 2nd Flr	8/19/97	QST	SEQ	
Golden Gate Annex	1601 Turk St., 94115	3	3		970B64-04	<3	1st	SF	Rm 9A, Cooking Area, 2nd Flr	8/19/97	QST	SEQ	
Golden Gate Annex	1601 Turk St., 94115	4	4		970B64-05	<3	1st	SF	Rm 7A, Cooking Area, 2nd Flr	8/19/97	QST	SEQ	
Golden Gate Annex	1601 Turk St., 94115	5	5		970B64-06	<3	1st	SF	Rm 5A, Cooking Area, 1st Flr	8/19/97	QST	SEQ	
Golden Gate Annex	1601 Turk St., 94115	6	6		970B64-07	<3	1st	SF	Rm 23, Cooking Area, 1st Flr	8/19/97	QST	SEQ	
Golden Gate Annex	1601 Turk St., 94115	7	7		970B64-08	<3	1st	SF	Kitchen, Basement	8/19/97	QST	SEQ	
Golden Gate Annex	1601 Turk St., 94115	8	8		970B64-09	<3	1st	DF	Rm 20, Basement	8/19/97	QST	SEQ	
Golden Gate Annex	1601 Turk St., 94115	1	na		970B64-01	<3	Blank			8/19/97	QST	SEQ	
Golden Gate Annex	1601 Turk St., 94115	9	na		970B64-10	28	Spike			8/19/97	QST	SEQ	97-W00761-3
													30



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report											
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up	
Golden Gate E.S.	1601 Turk St., 94115	2	2			9708B62-02	<5	1st	DF	Rm 2, Basement	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	2	2			9708B62-03	<5	Duplicate	DF	Rm 2, Basement	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	4	4			9708B62-04	<5	1st	DF	Rm 1, Basement	8/18/97	QST	SEQ			6					
Golden Gate E.S.	1601 Turk St., 94115	4	4			9708B62-05	<5	Duplicate	DF	Rm 1, Basement	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	5	5			9708B62-06	<5	1st	DF	Rm 202	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	5	5			9708B62-07	<5	Duplicate	DF	Rm 202	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	6	6			9708B62-08	<5	1st	DF	Rm 201	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	7	7			9708B62-09	<5	1st	DF	Rm 203	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	8	8			9708B62-10	<5	1st	DF	Rm 205	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	9	9			9708B62-11	<5	1st	DF	2nd Fir Hall	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	10	10			9708B62-12	<5	1st	DF	Rm 207	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	11	11			9708B62-13	<5	1st	DF	Rm 209	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	12	12			9708B62-14	<5	1st	DF	Rm 211	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	13	13			9708B62-15	5	1st	DF	Rm 208	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	14	14			9708B62-16	<5	1st	DF	Rm 102	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	15	15			9708B62-17	<5	1st	DF	Rm 103	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	16	16			9708B62-18	<5	1st	DF	Rm 105	8/18/97	QST	SEQ			8					
Golden Gate E.S.	1601 Turk St., 94115	17	17			9708B62-19	6	1st	DF	Rm 104	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	18	18			9708B62-20	<5	1st	DF	Rm 107	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	19	19			9708B62-21	<5	1st	DF	Rm 108	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	21	21			9708B62-23	6	1st	DF	Rm 109	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	22	22			9708B62-24	<5	1st	DF	Rm 111	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	23	23			9708B62-25	<5	1st	DF	Rm 110	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	24	24			9708B62-26	<5	1st	DF	1st Fir Hall by Rm 104	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	25	25			9708B62-27	<5	1st	DF	Rm 206	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	26	26			9708B62-28	<5	1st	DF	Playground South 1st Fir Leve	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	27	27		yes	9708B62-29	20	1st	MDF	Playground East, Basement Leve	8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	30	30			48029-02	<5	1st	MDF	MAIN LEVEL (1ST FLOOR)	8/30/97	QST	MAL								
Golden Gate E.S.	1601 Turk St., 94115	31	31			48029-03	<5	2nd	MDF	MAIN LEVEL (1ST FLOOR)	8/30/97	QST	MAL								
Golden Gate E.S.	1601 Turk St., 94115	32	32			48029-04	<5	3rd	MDF	MAIN LEVEL (1ST FLOOR)	8/30/97	QST	MAL								
Golden Gate E.S.	1601 Turk St., 94115	1	na			9708B62-01	<5	Blank			8/18/97	QST	SEQ								
Golden Gate E.S.	1601 Turk St., 94115	20	na			9708B62-22	17	Spike			8/18/97	QST	SEQ	97-W00760-12	20						
Golden Gate E.S.	1601 Turk St., 94115	28	na			9708B62-30	17	Spike			8/18/97	QST	SEQ	97-W00760-3	20						
Golden Gate E.S.	1601 Turk St., 94115	29	na			48029-01	<5	Blank			8/30/97	QST	MAL								
Golden Gate E.S.	1601 Turk St., 94115	NO1	na					NO	DF	Room 204	8/30/97	QST	MAL				non-operational				



100

SFUSD Lead in Drinking Water Survey - Results Summary															Final Interim Report		Sample ID		Source ID		12 to 15 ppb		>15 ppb		Lab ID		Results (ppb)		Sample Type		Source Type		Room		Sample Date		Surveyor		Lab		Spike ID #		Spike Level (ppb)		Inter-lab Results (ppb)		Comments & Field IDs		Arch Height (inch)		Fill Time (second)		Follow-Up																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																			
Summer / Fall 1997 SCUA Project B2243																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								





SFUSD Lead in Drinking Water Survey - Results Summary									
Summer / Fall 1997									
SCA Project B2243									
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room
Grattan E.S.	165 Grattan St., 94117	58			48008-01	9	1st	SF	ROOM 05A
Grattan E.S.	165 Grattan St., 94117	59	59		48008-02	6	2nd	SF	ROOM 05A
Grattan E.S.	165 Grattan St., 94117	60	60		48008-03	9	3rd	SF	ROOM 05A
Grattan E.S.	165 Grattan St., 94117	61	61		48008-04	<5	1st	SF	ROOM 06
Grattan E.S.	165 Grattan St., 94117	62	62		48008-05	<5	2nd	SF	ROOM 06
Grattan E.S.	165 Grattan St., 94117	63	63		48008-06	5	3rd	SF	ROOM 06
Grattan E.S.	165 Grattan St., 94117	64	64		48008-07	<5	1st	SDF	RM 107
Grattan E.S.	165 Grattan St., 94117	65	65		48008-08	<5	2nd	SDF	ROOM 107
Grattan E.S.	165 Grattan St., 94117	66	66		48008-09	5	3rd	SDF	ROOM 107
Grattan E.S.	165 Grattan St., 94117	67	67		48008-10	<5	1st	SF	ROOM 112 (KITCHEN)
Grattan E.S.	165 Grattan St., 94117	68	68		48008-11	<5	2nd	SF	ROOM 112 (KITCHEN)
Grattan E.S.	165 Grattan St., 94117	69	69		48008-12	5	3rd	SF	ROOM 112 (KITCHEN)
Grattan E.S.	165 Grattan St., 94117	70	70		48008-13	<5	1st	SF	ROOM 113 (CAFETERIA)
Grattan E.S.	165 Grattan St., 94117	71	71		48008-14	<5	2nd	SF	ROOM 113 (CAFETERIA)
Grattan E.S.	165 Grattan St., 94117	72	72		48008-15	<5	3rd	SF	ROOM 113 (CAFETERIA)
Grattan E.S.	165 Grattan St., 94117	73	73		48008-16	<5	1st	SF	ROOM 103
Grattan E.S.	165 Grattan St., 94117	74	74		48008-17	<5	2nd	SF	ROOM 113
Grattan E.S.	165 Grattan St., 94117	75	75		48008-18	<5	3rd	SF	ROOM 113
Grattan E.S.	165 Grattan St., 94117	76	76		48008-19	<5	1st	SF	ROOM 103
Grattan E.S.	165 Grattan St., 94117	77	77		48008-20	<5	2nd	SF	ROOM 103
Grattan E.S.	165 Grattan St., 94117	78	78	yes	48008-21	14	3rd	SF	ROOM 103
Grattan E.S.	165 Grattan St., 94117	79	79		48008-22	<5	1st	SF	ROOM 102
Grattan E.S.	165 Grattan St., 94117	80	80		48008-23	<5	2nd	SF	ROOM 102
Grattan E.S.	165 Grattan St., 94117	81	81		48008-24	<5	3rd	SF	ROOM 102
Grattan E.S.	165 Grattan St., 94117	82	82		48008-25	<5	1st	SF	ROOM 101
Grattan E.S.	165 Grattan St., 94117	83	83		48008-26	<5	2nd	SF	ROOM 101
Grattan E.S.	165 Grattan St., 94117	84	84		48008-27	<5	3rd	SF	ROOM 101
Grattan E.S.	165 Grattan St., 94117	85	85		48008-28	<5	1st	SF	ROOM 209
Grattan E.S.	165 Grattan St., 94117	86	86		48008-29	<5	2nd	SF	ROOM 209
Grattan E.S.	165 Grattan St., 94117	87	87		48008-30	<5	3rd	SF	ROOM 209
Grattan E.S.	165 Grattan St., 94117	88	88		48008-31	<5	1st	SDF	ROOM 209
Grattan E.S.	165 Grattan St., 94117	89	89		48008-32	<5	2nd	SDF	ROOM 209
Grattan E.S.	165 Grattan St., 94117	90	90		48008-33	7	3rd	SDF	ROOM 209
Grattan E.S.	165 Grattan St., 94117	91	91		48008-34	<5	1st	SDF	ROOM 207
Grattan E.S.	165 Grattan St., 94117	92	92		48008-35	<5	2nd	SDF	ROOM 207
Grattan E.S.	165 Grattan St., 94117	93	93		48008-36	<5	3rd	SDF	ROOM 207
Grattan E.S.	165 Grattan St., 94117	94	94		48008-37	7	1st	SDF	ROOM 205
Grattan E.S.	165 Grattan St., 94117	95	95		48008-38	9	2nd	SDF	ROOM 205
Grattan E.S.	165 Grattan St., 94117	96	96	yes	48008-39	15	3rd	SDF	ROOM 205
Grattan E.S.	165 Grattan St., 94117	97	97		48008-40	<5	1st	SF	ROOM 203
Grattan E.S.	165 Grattan St., 94117	98	98		48008-41	<5	2nd	SF	ROOM 203
Grattan E.S.	165 Grattan St., 94117	99	99		48008-42	<5	3rd	SF	ROOM 203
Grattan E.S.	165 Grattan St., 94117	100	100		48008-43	<5	1st	SF	ROOM 212
Grattan E.S.	165 Grattan St., 94117	101	101	yes	48008-44	26	2nd	SF	ROOM 212
Grattan E.S.	165 Grattan St., 94117	102	102		48008-45	<5	3rd	SF	ROOM 212
Grattan E.S.	165 Grattan St., 94117	103	na		48008-46	<5	Blank	NA	Room 206
Grattan E.S.	165 Grattan St., 94117	NA1	na						



Table 2 - Final Interim Results

[illegible]





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report				Sample				Surveyor				Spike ID #				Inter-lab Results (ppb)				Comments & Field ID's				Arch Height (Inch)				Fill Time (second)				Follow-Up			
Site		Address		Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (Inch)	Fill Time (second)	Follow-Up																							
Harc E.S.	1035 Gilman St., 94124	1	1					48092-01	<5	1st	SF	ROOM 015	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	2	2					48092-02	19	1st	SF	ROOM 017A	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	2A	2			yes		9710472-01	<5	1st	SF	ROOM 017A	10/4/97	SCA	SEQ						15																								
Harc E.S.	1035 Gilman St., 94124	2B	2					9710472-02	<5	2nd	SF	ROOM 017A	10/4/97	SCA	SEQ						15																								
Harc E.S.	1035 Gilman St., 94124	2C	2					9710472-03	<5	3rd	SF	ROOM 017A	10/4/97	SCA	SEQ						15																								
Harc E.S.	1035 Gilman St., 94124	3	3					48092-03	11	1st	SF	ROOM 107	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	4	4					48092-04	<5	1st	SF	ROOM 109	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	5	5					48092-05	8	1st	SF	ROOM 111	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	6	6					48092-06	<5	1st	SF	ROOM 113	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	7	7			yes		48092-07	43	1st	SF	ROOM 115	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	7A	7					9710472-04	<5	1st	SF	ROOM 115	10/4/97	SCA	SEQ						15																								
Harc E.S.	1035 Gilman St., 94124	7B	7					9710472-05	<5	2nd	SF	ROOM 115	10/4/97	SCA	SEQ						15																								
Harc E.S.	1035 Gilman St., 94124	7C	7		yes			9710472-06	15	3rd	SF	ROOM 115	10/4/97	SCA	SEQ						15																								
Harc E.S.	1035 Gilman St., 94124	8	8					48092-08	10	1st	SF	ROOM 114	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	9	9					48092-09	<5	1st	SF	ROOM 112	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	10	10					48092-10	<5	1st	DF	HALL - C90	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	11	11					48092-11	5	1st	DF	HALL - C91	8/26/97	SCA	MAL			<5																											
Harc E.S.	1035 Gilman St., 94124	12	12					48092-12	<5	1st	SF	ROOM 101	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	13	13					48092-13	10	1st	DF	ROOM 204	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	14	14					48092-14	<5	1st	SF	ROOM 205	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	15	15					48092-15	10	1st	DF	ROOM 207	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	16	16					48092-16	<5	1st	SF	ROOM 206	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	17	17					48092-17	11	1st	DF	ROOM 209	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	18	18					48092-18	5	1st	SF	ROOM 208	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	19	19					48092-19	7	1st	SF	ROOM 210	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	20	20			yes		48092-20	6	1st	SF	ROOM 211	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	21	21			yes		48092-21	24	1st	MDF	ROOM 210 EXTERIOR	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	22	22					48092-22	<5	1st	SDF	ROOM 001A	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	23	23					48092-23	5	1st	SDF	ROOM 002A	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	24	24					48092-24	6	1st	SF	ROOM 004A	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	25	25			yes		48092-25	<5	1st	SDF	ROOM 003A	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	26	26					48092-26	13	1st	SF	Hall C94	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	26A	26					9710472-08	<5	1st	SF	Hall C94	10/4/97	SCA	SEQ						20																								
Harc E.S.	1035 Gilman St., 94124	26B	26					9710472-09	<5	2nd	SF	Hall C94	10/4/97	SCA	SEQ						20																								
Harc E.S.	1035 Gilman St., 94124	26C	26					9710472-10	<5	Duplicate	SF	Hall C94	10/4/97	SCA	SEQ						20																								
Harc E.S.	1035 Gilman St., 94124	26D	26			yes		9710472-11	5	3rd	SF	Hall C94	10/4/97	SCA	SEQ						20																								
Harc E.S.	1035 Gilman St., 94124	27	27					48092-27	16	1st	SF	Rm 5A	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	27A	27					9710472-12	<5	1st	SF	Rm 5A	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	27B	27					9710472-13	<5	2nd	SF	Rm 5A	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	27C	27					9710472-14	<5	3rd	SF	Rm 5A	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	28	28					48092-28	8	1st	SF	Rm 6A	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	29	29					48092-29	10	1st	SF	Rm 8A	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	30	30			yes		48092-30	10	1st	SF	Rm 8A	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	31	31			yes		48092-31	26	1st	MDF	Play Area C96	8/26/97	SCA	MAL																														
Harc E.S.	1035 Gilman St., 94124	31A	31					9710472-15	6	1st	MDF	Play Area C96	10/4/97	SCA	SEQ					2	33																								
Harc E.S.	1035 Gilman St., 94124	31B	31					9710472-16	<5	2nd	MDF	Play Area C96	10/4/97	SCA	SEQ					2	33																								
Harc E.S.	1035 Gilman St., 94124	31C	31			yes		9710472-17	31	3rd	MDF	Play Area C96	10/4/97	SCA	SEQ					2																									
Harc E.S.	1035 Gilman St., 94124	32	32			yes		48092-32	7	1st	SF	Rm 1B	8/26/97	SCA	MAL						10																								
Harc E.S.	1035 Gilman St., 94124	32A	32					9710472-18	7	1st	SF	Rm 1B	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	32B	32					9710472-19	5	2nd	SF	Rm 1B	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	32B	32			yes		9710472-20	5	Duplicate	SF	Rm 1B	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	32C	32					9710472-21	13	3rd	SF	Rm 1B	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	34	34			yes		48092-33	17	1st	SF	Rm 2B	8/26/97	SCA	MAL						10																								
Harc E.S.	1035 Gilman St., 94124	34A	34					9710472-22	<5	1st	SF	Rm 2B	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	34B	34					9710472-23	<5	2nd	SF	Rm 2B	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	34C	34			yes		9710472-24	<5	3rd	SF	Rm 2B	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	35	35					48092-35	35	1st	SF	Rm 3B	8/26/97	SCA	MAL						15																								
Harc E.S.	1035 Gilman St., 94124	35A	35					9710472-25	<5	1st	SF	Rm 3B	10/4/97	SCA	SEQ						15																								
Harc E.S.	1035 Gilman St., 94124	35B	35					9710472-26	<5	2nd	SF	Rm 3B	10/4/97	SCA	SEQ						15																								
Harc E.S.	1035 Gilman St., 94124	35C	35					9710472-27	<5	3rd	SF	Rm 3B	10/4/97	SCA	SEQ						15																								
Harc E.S.	1035 Gilman St., 94124	36	36			yes		48092-36	110	1st	SF	Rm 4B	8/26/97	SCA	MAL						10																								
Harc E.S.	1035 Gilman St., 94124	36A	36					9710472-28	<5	1st	SF	Rm 4B	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	36B	36					9710472-29	<5	2nd	SF	Rm 4B	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	36B	36					9710472-30	<5	Duplicate	SF	Rm 4B	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	36C	36					9710472-31	<5	3rd	SF	Rm 4B	10/4/97	SCA	SEQ						10																								
Harc E.S.	1035 Gilman St., 94124	33	na					48092-33	104	Spike			8/26/97	SCA	MAL	97-W00776-7	100																												
Harc E.S.	1035 Gilman St., 94124	7D	na					9710472-07	95	Spike			10/4/97	SCA	SEQ																														
Harc E.S.	1035 Gilman St., 94124	8L	na					48092-37	<5	Blank			8/26/97	SCA	MAL																														





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B 2243																			
Site	Address	Sample ID	Final Interim Report			Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
			Source ID	12 to 15 ppb	>15 ppb														
Harte E.S.	1035 Gilman St., 94124	BL	na			9710472-32	<3	Blank		10/10/97	SCA	SEQ							
Harte E.S.	1035 Gilman St., 94124	N01	na					NO	DF	Room 010	SCA	SEQ				non-operational			
Harte E.S.	1035 Gilman St., 94124	N02	na					NO	DF	Room 202	SCA	SEQ				non-operational			
Harte E.S.	1035 Gilman St., 94124	N03	na					NO	DF	outside Room T-66	SCA	SEQ				non-operational			
Harte E.S.	1035 Gilman St., 94124	N04	na					NO	DF	outside Room 002	SCA	SEQ				non-operational			
Harte E.S.	1035 Gilman St., 94124	N05	na					NO	DF	outside Room 004	SCA	SEQ				non-operational			



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243																		
Site	Address	Sample ID	Final Interim Report		Results	Sample Type	Source Type	Room	Sample Date	Surveynr	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
			Source ID	12 to 15 ppb														
Hillcrest E.S.	810 Silver Ave., 94134	1	1		11	1st	DF	HALLWAY C90	8/23/97	SCA	MAL							
Hillcrest E.S.	810 Silver Ave., 94134	2	2		<5	1st	DF	TEACHERS LOUNGE	8/23/97	SCA	MAL							
Hillcrest E.S.	810 Silver Ave., 94134	3	3		7	1st	DF	HALLWAY C94	8/23/97	SCA	MAL							
Hillcrest E.S.	810 Silver Ave., 94134	4	4		<5	1st	MDF	EXT. YARD	8/23/97	SCA	MAL							
Hillcrest E.S.	810 Silver Ave., 94134	5	5		9	1st	DF	HALLWAY C92	8/23/97	SCA	MAL							
Hillcrest E.S.	810 Silver Ave., 94134	6	6		58	1st	MDF	EXT. YARD	8/23/97	SCA	MAL							
Hillcrest E.S.	810 Silver Ave., 94134	6A	6	yes	9710494-01	<5	MDF	EXT. YARD	10/3/97	SCA	SEQ					2	60	
Hillcrest E.S.	810 Silver Ave., 94134	6B	6		9710494-02	<5	MDF	EXT. YARD	10/3/97	SCA	SEQ					2	60	
Hillcrest E.S.	810 Silver Ave., 94134	6C	6		9710494-03	<5	MDF	EXT. YARD	10/3/97	SCA	SEQ					2	60	
Hillcrest E.S.	810 Silver Ave., 94134	7	7		47783-07	19	1st	DF	2ND FL HALLWAY	8/23/97	SCA	MAL						
Hillcrest E.S.	810 Silver Ave., 94134	7A	7	yes	9710494-04	<5	1st	DF	2ND FL HALLWAY	10/3/97	SCA	SEQ				1.5	20	
Hillcrest E.S.	810 Silver Ave., 94134	7B	7		9710494-05	<5	2nd	DF	2ND FL HALLWAY	10/3/97	SCA	SEQ				1.5	20	
Hillcrest E.S.	810 Silver Ave., 94134	7C	7		9710494-06	6	3rd	DF	2ND FL HALLWAY	10/3/97	SCA	SEQ				1.5	20	
Hillcrest E.S.	810 Silver Ave., 94134	7C	7		9710494-07	6	Duplicate	DF	2ND FL HALLWAY	10/3/97	SCA	SEQ				1.5	20	
Hillcrest E.S.	810 Silver Ave., 94134	8	8		47783-08	9	1st	DF	2ND FL HALLWAY	8/23/97	SCA	MAL						
Hillcrest E.S.	810 Silver Ave., 94134	9	na		47783-09	33	Spike		8/23/97	SCA	MAL	97-W00761-11	30					
Hillcrest E.S.	810 Silver Ave., 94134	10	na		47783-10	<5	Blank		8/23/97	SCA	MAL							
Hillcrest E.S.	810 Silver Ave., 94134	BL	na		9710494-08	<5	Blank		10/3/97	SCA	SEQ							
Hillcrest E.S.	810 Silver Ave., 94134	NO1	na				NO	Room 119		SCA	SEQ				non-operational			
Hillcrest E.S.	810 Silver Ave., 94134	NO2	na				NO	Room K01		SCA	SEQ				non-operational			
Hillcrest E.S.	810 Silver Ave., 94134	NO3	na				NO	Room K02		SCA	SEQ				non-operational			
Hillcrest E.S.	810 Silver Ave., 94134	NO4	na				NO	outside Room 202		SCA	SEQ				non-operational			
Hillcrest E.S.	810 Silver Ave., 94134	NO5	na				NO	outside Room 211		SCA	SEQ				non-operational			



SFUSD Lead in Drinking Water Survey - Results Summary  
 Summer / Fall 1997  
 SCA Project B2243

SFUSD Lead in Drinking Water Survey - Results Summary																				
Summer / Fall 1997 SCA Project B2243																				
Sample ID	Address	Site	Final Interim Report	Source ID	12 to 15 ppb	>15 ppb	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
1	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		1			9708D10-01	<5	1st	SF	Rm 19, Kitchen	8/25/97	RGA	SEQ						
2	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		2			9708D10-02	<5	Duplicate	SF	Rm 19, Kitchen	8/25/97	RGA	SEQ						
3	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		1			9708D10-03	<5	1st	SF	Rm 23, Break Rm	8/25/97	RGA	SEQ		19				
4	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		4			9708D10-05	8	1st	SF	Kitchen, 1st Level	8/25/97	RGA	SEQ						
5	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		5			9708D10-06	<5	1st	SF	Break Rm, 1st Level	8/25/97	RGA	SEQ						
6	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		6			9708D10-07	<5	1st	WCDF	East Hall 1st Level	8/25/97	RGA	SEQ						
7	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		7			9708D10-08	<5	1st	WCDF	North Hall, 2nd Level	8/25/97	RGA	SEQ						
8	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		8			9708D10-09	<5	1st	DF	South Hall, 2nd Level	8/25/97	RGA	SEQ						
9	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		9			9708D10-10	<5	1st	SF	Kitchen, 2nd Level	8/25/97	RGA	SEQ						
10	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		10			9708D10-11	<5	1st	SF	Kitchen, 2nd Level	8/25/97	RGA	SEQ						
na	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		na			9708D10-04	Blank												
11	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		na			9708D10-12	44	Spike						50					
NA1	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		na				NO	NA	North Hallway	8/25/97	RGA	SEQ	97-W00765-12			non-accessible			
NO1	1325 Florida St., 94110	Hilltop Pregnancy Svcs. Ctr.		na				NO	DF	outside Room 201	8/25/97	RGA	SEQ				non-rational			





SPUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243																						
Site	Address	Final Interim Report		Sample ID	Source ID	12 to 15 ppb		Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inches)	Fill Time (second)	Follow-Up
		>15 ppb	>15 ppb																			
Hoover M.S.	2290 14th Ave., 94116	1	1			48051-01	<5	1st	DF	C9B		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	2	2			48051-02	7	1st	DF	C9B		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	3	3			48051-03	<5	1st	DF	C9C		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	4	4			48051-04	<5	1st	DF	C9C		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	5	5			48051-05	6	1st	DF	C9C		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	6	6			48051-06	<5	1st	DF	C9B		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	7	7			48051-07	<5	1st	DF	C9B		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	8	8			48051-08	<5	1st	DF	C9C		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	9	9			48051-09	<5	1st	DF	C93		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	10	10			48051-10	<5	1st	DF	C93		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	11	11			48051-11	<5	1st	DF	C9B		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	12	12			48051-12	<5	1st	DF	C9B		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	13	13			48051-13	<5	1st	DF	B1R		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	14	14			48051-14	<5	1st	SF	B1R		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	15	15			48051-15	7	1st	SF	B1R		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	16	16			48051-16	<5	1st	SF	B1R		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	17	17			48051-17	<5	1st	SF	B1R		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	19	19			48051-19	<5	1st	WF	30B		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	20	20			48051-20	<5	1st	SF	B1R		8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	18	na			48051-18	11	Spike				8/27/97	SCA	MAL	97-W00771-4	10						
Hoover M.S.	2290 14th Ave., 94116	21	na			48051-21	<5	Blank				8/27/97	SCA	MAL								
Hoover M.S.	2290 14th Ave., 94116	N01	na				NO	NO	DF	outside Room A13		8/27/97	SCA	MAL					non-operational			
Hoover M.S.	2290 14th Ave., 94116	N02	na				NO	NO	DF	outside Room A21			SCA	MAL					non-operational			
Hoover M.S.	2290 14th Ave., 94116	N03	na				NO	NO	DF	outside Room A32			SCA	MAL					non-operational			
Hoover M.S.	2290 14th Ave., 94116	N04	na				NO	NO	DF	outside Room B21			SCA	MAL					non-operational			
Hoover M.S.	2290 14th Ave., 94116	N05	na				NO	NO	DF	outside Room C30			SCA	MAL					non-operational			
Hoover M.S.	2290 14th Ave., 94116	N06	na				NO	NO	DF	outside Room S11			SCA	MAL					non-operational			
Hoover M.S.	2290 14th Ave., 94116	N07	na				NO	NO	DF	outside Room S84			SCA	MAL					non-operational			



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project 82243												
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab
Intnl. Studies Academy	693 Vermont St., 94107	1	1		4/7/12-01	6	1st	DF	CORRIDOR C-90 FIRST FLD	8/13/97	SFUSD	MAL
Intnl. Studies Academy	693 Vermont St., 94107	2	2		4/7/12-02	<5	1st	DF	CORRIDOR C-90 SECOND F	8/13/97	SFUSD	MAL
Intnl. Studies Academy	693 Vermont St., 94107	3	3		4/7/12-03	<5	1st	DF	KITCHEN AREA 035, BASE	8/13/97	SFUSD	MAL
Intnl. Studies Academy	693 Vermont St., 94107	4	4		4/7/12-04	<5	1st	DF	BY ENTRANCE TO THE GY	8/13/97	SFUSD	MAL
Intnl. Studies Academy	693 Vermont St., 94107	5	na		4/7/12-05	10	Spike			8/13/97	SFUSD	MAL
Intnl. Studies Academy	693 Vermont St., 94107	6	na		4/7/12-06	<5	Blank			8/13/97	SFUSD	MAL
Intnl. Studies Academy	693 Vermont St., 94107	NO1	na				NO	DF	Yard outside Room 2		SFUSD	MAL
Intnl. Studies Academy	693 Vermont St., 94107	NO2	na				NO	DF	outside Room 035		SFUSD	MAL
												non-operational
												non-operational



SFUSD Lead in Drinking Water Survey - Results Summary																			
Summer / Fall 1997																			
SCA Project B2243																			
Sample ID	Address	Final Interim Report			Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow Up
		Source ID	12 to 15 pph	>15 pph															
1	1350 25th Ave., 94122				47786-01	<5	1st	SF	BATHROOM 1	8/2/97	SCA	MAL							
2	1350 25th Ave., 94122	2			47786-02	<5	1st	SF	BATHROOM 1	8/2/97	SCA	MAL			5				
3	1350 25th Ave., 94122	3			47786-03	<5	1st	SF	BATHROOM 1	8/2/97	SCA	MAL							
4	1350 25th Ave., 94122	4		yes	47786-04	33	1st	SF	Kitchen	8/2/97	SCA	MAL							
5	1350 25th Ave., 94122	5			9710481-01	<5	1st	SF	Kitchen	10/1/97	SCA	SEQ							
6	1350 25th Ave., 94122	6			9710481-02	<5	2nd	SF	Kitchen	10/1/97	SCA	SEQ							
7	1350 25th Ave., 94122	7			9710481-03	<5	3rd	SF	Kitchen	10/1/97	SCA	SEQ							
8	1350 25th Ave., 94122	8			9710481-04	5	Duplicate	SF	Kitchen	10/1/97	SCA	SEQ							
9	1350 25th Ave., 94122	9			47786-05	<5	1st	SF	BATHROOM 2	8/2/97	SCA	MAL							
10	1350 25th Ave., 94122	10			47786-06	<5	1st	SF	BATHROOM 3	8/2/97	SCA	MAL							
11	1350 25th Ave., 94122	11			47786-07	<5	1st	WF	OUTSIDE FOUNT 1	8/2/97	SCA	MAL							
12	1350 25th Ave., 94122	12			47786-08	<5	1st	SF	Bungalow	8/2/97	SCA	MAL							
13	1350 25th Ave., 94122	13	na		47786-09	<5	1st	SF		8/2/97	SCA	MAL		30					
14	1350 25th Ave., 94122	14	na		9710481-01	<5	Spike	Blank		10/1/97	SCA	SEQ				97-W00761-9			
15	1350 25th Ave., 94122	15			9710481-05	<5	Blank	Blank		10/1/97	SCA	SEQ							





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary										Final Interim Report		Source ID		Sample ID		Address		Lab ID		Results (ppb)		Sample Type		Source Type		Room		Sample Date		Surveyor		Spike ID #		Spike Level (ppb)		Inter-lab Results (ppb)		Comments & Field ID's		Arch Height (Inch)		Fill Time (second)		Follow-Up			
Summer / Fall 1997										12 to 15 ppb		>15 ppb																																			
SCA Project B2243																																															
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (Inch)	Fill Time (second)	Follow-Up																												
Jefferson E.S.	1752 Irving St., 94122	1	1			47525-16	<5	1st	SDF	Room 212	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	1	1			47525-01	<5	1st	SDF	Room 108	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	2	2			47525-02	<5	1st	SDF	Room 106	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	3	3			47525-03	<5	1st	DF	HALL - 1ST FLOOR	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	4	4			47525-04	<5	1st	SDF	Room 104	8/18/97	SCA	MAL		7																																
Jefferson E.S.	1752 Irving St., 94122	5	5			47525-05	<5	1st	SDF	Room 102	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	6	6			47525-06	<5	1st	SF	TEACHERS LOUNGE	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	7	7			47525-07	<5	1st	DF	CAPETERIA	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	8	8			47525-08	<5	SF	ROOM 8	8/18/97	SCA	MAL																																			
Jefferson E.S.	1752 Irving St., 94122	9	9			47525-09	7	1st	SDF	Room 101	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	10	10			47525-10	<5	1st	SDF	Room 103	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	11	11			47525-11	10	1st	SDF	Room 105	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	12	12			47525-12	<5	1st	SDF	Room 209	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	13	13			47525-13	<5	1st	DF	HALL - 2ND FLOOR	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	15	15			47525-17	<5	1st	SDF	Room 213	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	16	16			47525-18	<5	1st	SDF	Room 211	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	17	17			47525-19	16	1st	SDF	Room 210	8/18/97	SCA	MAL				2	25																													
Jefferson E.S.	1752 Irving St., 94122	17A	17		yes	9710478-01	<5	1st	SDF	Room 210	10/3/97	SCA	SEQ				2	25																													
Jefferson E.S.	1752 Irving St., 94122	17B	17			9710478-02	<5	2nd	SDF	Room 210	10/3/97	SCA	SEQ				2	25																													
Jefferson E.S.	1752 Irving St., 94122	17C	17			9710478-03	<5	3rd	SDF	Room 210	10/3/97	SCA	SEQ				2	25																													
Jefferson E.S.	1752 Irving St., 94122	18	18			47525-20	7	1st	SDF	Room 208	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	19	19			47525-21	<5	1st	SDF	Room 206	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	20	20			47525-22	<5	1st	SDF	Room 204	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	21	21		yes	47525-23	41	1st	SDF	Room 202	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	21A	21			9710478-04	6	1st	SDF	Room 202	10/3/97	SCA	SEQ				0.5	45																													
Jefferson E.S.	1752 Irving St., 94122	21B	21			9710478-05	<5	2nd	SDF	Room 202	10/3/97	SCA	SEQ				0.5	45																													
Jefferson E.S.	1752 Irving St., 94122	21C	21		yes	9710478-06	26	3rd	SDF	Room 202	10/3/97	SCA	SEQ				0.5	45																													
Jefferson E.S.	1752 Irving St., 94122	22	22			47525-24	8	1st	SDF	Room 201	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	23	23			47525-25	10	1st	SDF	Room 203	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	24	24			47525-26	5	1st	SDF	Room 205	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	25	25	yes		47525-27	15	1st	SDF	Room 207	8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	25A	25			9710478-07	<5	1st	SDF	Room 207	10/3/97	SCA	SEQ				1	35																													
Jefferson E.S.	1752 Irving St., 94122	25B	25			9710478-08	<5	2nd	SDF	Room 207	10/3/97	SCA	SEQ				1	35																													
Jefferson E.S.	1752 Irving St., 94122	25C	25			9710478-09	8	3rd	SDF	Room 207	10/3/97	SCA	SEQ				1	35																													
Jefferson E.S.	1752 Irving St., 94122	25C	25			9710478-10	7	Duplicate	SDF	Room 207	10/3/97	SCA	SEQ				1	35																													
Jefferson E.S.	1752 Irving St., 94122	26	na			47525-28	<5	1st	MDF	PLAYGROUND	8/18/97	SCA	MAL	97-W00753-7	20																																
Jefferson E.S.	1752 Irving St., 94122	27	na			47525-29	21	Spike			8/18/97	SCA	MAL	97-W00753-11	20																																
Jefferson E.S.	1752 Irving St., 94122	28	na			47525-14	21	Spike			8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	BL	na			47525-30	<5	Blank			8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	BL	na			47525-15	<5	Blank			8/18/97	SCA	MAL																																		
Jefferson E.S.	1752 Irving St., 94122	BL	na			9710478-11	<5	Blank			10/3/97	SCA	SEQ																																		



**SFUSB Lead in Drinking Water Survey • Results Summary**  
**Summer / Fall 1997**  
**SCA Project B243**

Page 57 of 120, Printed 10/20/97



SP-USD Lead in Drinking Water Survey - Results Summary										Final Interim Report		Follow-Up								
Summer / Fall 1997 SUA Project B-2243	Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spill ID #	Spill Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	
SUA Project B-2243	Key E.S. & Annex	1530 43rd Ave. 94122	1	1			47742-01	1st	DF	FIRST FLOOR KITCHEN BY	8/19/97	RGA	MAL							
			2	2			47742-02	<5	1st	SF	FIRST FLOOR KITCHEN	8/19/97	RGA	MAL						
			3	3	yes		47742-03	14	1st	SF	FIRST FLOOR HALL, SOUTH	8/19/97	RGA	MAL					56	
			3A	3			49296-01	<5	1st	DF	1st Fl, Hall South	10/25/97	RGA	MAL					56	
			3B	3			49296-02	<5	2nd	DF	1st Fl, Hall South	10/25/97	RGA	MAL					56	
			3C	3			49296-03	<5	3rd	DF	1st Fl, Hall South	10/25/97	RGA	MAL						
			4	4			47742-04	<5	1st	SF	2ND FLOOR HALL, SOUTH	8/19/97	RGA	MAL						
			5	5			47742-05	<5	1st	SF	1ST FLOOR ADMIN. LOUN	8/19/97	RGA	MAL						
			6	6			47742-06	<5	1st	MDF	OUTSIDE BASKETBALL CO	8/19/97	RGA	MAL						
			7	na			47742-07	<5	Blank				8/19/97	RGA	MAL	97-W00765-6	50			
			8	na			47742-08	57	Spill				8/19/97	RGA	MAL					
			BL	na			49296-04	<5	Blank				10/25/97	RGA	MAL					
			N01	na					NO	DF		outside Room 001		RGA	MAL				non-operational	
			N02	na					NO	DF		outside Room 011		RGA	MAL				non-operational	
			N03	na					NO	SF		Room 020		RGA	MAL				non-operational	
			N04	na					NO	SF		Room 021		RGA	MAL				non-operational	
N05	na					NO	SF		Room 022		RGA	MAL				non-operational				
N06	na					NO	SF		Room 022		RGA	MAL				non-operational				





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary																					
Summer / Fall 1997																					
SCA Project B2243																					
Site	Address	Sample ID	Source ID	Final Interim Report	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
King E.S.	1215 Carolina St., 94107	1	1				47523-01	10	1st	SF	KITCHEN ROOM 017	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	2	2				47523-02	<5	1st	MDF	EXTERIOR NEAR T-600	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	3	3				47523-03	<5	1st	SF	ROOM 009	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	4	4				47523-04	<5	1st	SF	ROOM 005	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	5	5				47523-05	<5	1st	DF	ROOM 003	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	6	6			yes	47523-06	59	1st	DF	ROOM 001	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	6A	6				9710480-01	<5	1st	DF	ROOM 001	10/3/97	SCA	SEQ					3	45	
King E.S.	1215 Carolina St., 94107	6B	6				9710480-02	<5	2nd	DF	ROOM 001	10/3/97	SCA	SEQ					3	45	
King E.S.	1215 Carolina St., 94107	6C	6				9710480-03	5	3rd	DF	ROOM 001	10/4/97	SCA	SEQ					3	45	
King E.S.	1215 Carolina St., 94107	7	7			yes	47523-07	16	1st	DF	ROOM 113	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	7A	7				9710480-04	9	1st	DF	ROOM 113	10/3/97	SCA	SEQ					1.5	32	
King E.S.	1215 Carolina St., 94107	7B	7				9710480-05	10	2nd	DF	ROOM 113	10/3/97	SCA	SEQ					1.5	32	
King E.S.	1215 Carolina St., 94107	7C	7				9710480-06	11	3rd	DF	ROOM 113	10/4/97	SCA	SEQ					1.5	32	
King E.S.	1215 Carolina St., 94107	8	8				47523-08	11	1st	DF	ROOM 114	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	9	9				47523-09	9	1st	DF	HALL - SOUTH	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	10	10				47523-10	<5	1st	DF	HALL NEAR ROOM 201	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	11	11			yes	47523-11	31	1st	DF	HALL NEAR LOUNGE	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	11A	11				9710480-07	<5	1st	DF	HALL NEAR LOUNGE	10/3/97	SCA	SEQ					3	47	
King E.S.	1215 Carolina St., 94107	11B	11				9710480-08	<5	2nd	DF	HALL NEAR LOUNGE	10/3/97	SCA	SEQ					3	47	
King E.S.	1215 Carolina St., 94107	11C	11				9710480-09	11	3rd	DF	HALL NEAR LOUNGE	10/4/97	SCA	SEQ					3	47	
King E.S.	1215 Carolina St., 94107	11C	11				9710480-10	10	Duplicate	DF	HALL NEAR LOUNGE	10/4/97	SCA	SEQ					3	47	
King E.S.	1215 Carolina St., 94107	12	12				47523-12	10	1st	DF	HALL NEAR BOYS' RESTROOM	8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	13	na				47523-13	21	Spike	DF		8/16/97	SCA	MAL	97-W00753-6	20					
King E.S.	1215 Carolina St., 94107	BL	na				47523-14	<5	Blank	DF		8/16/97	SCA	MAL							
King E.S.	1215 Carolina St., 94107	BL	na				9710480-11	<5	Blank	DF		10/3/97	SCA	SEQ							
King E.S.	1215 Carolina St., 94107	NO1	na						NO	DF	Room 015		SCA	MAL							
King E.S.	1215 Carolina St., 94107	NO2	na						NO	DF	Room 015 outside Room 100		SCA	MAL							
King E.S.	1215 Carolina St., 94107																	non-operational			



SFUSD Lead in Drinking Water Survey - Results Summary													
Summer / Fall 1997													
SCA Project B2243													
Site	Address	Sample ID	Source ID	Source	Sample Type	Results (ppb)	Lab ID	Final Interim Report	Source Type	Room	Sample Date	Surveyor	Lab
King M.S.	1215 Carolina St., 94107	3	3	SF	1st	<5	47641-02		DF	UNDER STAIRWAY NEXT	8/2/97	QST	MAL
King M.S.	1215 Carolina St., 94107	4	4	DF	1st	<5	47641-03		DF	UNDER STAIRWAY NEXT	8/2/97	QST	MAL
King M.S.	1215 Carolina St., 94107	7	7	SF	1st	<5	47641-04		DF	INSIDE CAFETERIA KITCH	8/2/97	QST	MAL
King M.S.	1215 Carolina St., 94107	8	8	DF	1st	5	47641-05		DF	LOWER LEVEL GIRLS' GYM	8/2/97	QST	MAL
King M.S.	1215 Carolina St., 94107	9	9	DF	1st	8	47641-06		DF	UPPER LEVEL GYM - BASH	8/2/97	QST	MAL
King M.S.	1215 Carolina St., 94107	10	10	DF	1st	<5	47641-07		DF	LOWER LEVEL GIRLS' BATH	8/2/97	QST	MAL
King M.S.	1215 Carolina St., 94107	11	11	DF	1st	<5	47641-08		DF	LOWER LEVEL BOYS' ROO	8/2/97	QST	MAL
King M.S.	1215 Carolina St., 94107	12	12	DF	1st	<5	47641-09		DF	LOWER LEVEL BOYS' ROO	8/2/97	QST	MAL
King M.S.	1215 Carolina St., 94107	14	14	DF	1st	<5	47641-10		DF	UPPER LEVEL BASKETBALL	8/2/97	QST	MAL
King M.S.	1215 Carolina St., 94107	1	na	Blank	Blank	<5	47641-01		DF	outside Room 101	8/2/97	QST	MAL
King M.S.	1215 Carolina St., 94107	NO1	na	NO	NO				DF	outside Room 206		QST	MAL
King M.S.	1215 Carolina St., 94107	NO2	na	NO	NO				DF	outside Room 211		QST	MAL
King M.S.	1215 Carolina St., 94107	NO3	na	NO	NO				DF	Boy's bathroom in gym		QST	MAL
King M.S.	1215 Carolina St., 94107	NO4	na	NO	NO				DF			QST	MAL



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B1243													
Site	Address	Sample ID	Final Interim Report		Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surrogate	Lab	Spike ID #	Spike Level (ppb)
			Source ID	12 to 15 ppb									
Lafayette E.S.	4545 Anza St, 94121	1	1		<5	1st	DF	1ST FLOOR CORRIDOR (19)	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	1A	1		6	1st	DF	1st Fl, Cor (190)	10/5/97	SFUSD	MAL		18
Lafayette E.S.	4545 Anza St, 94121	1B	1		<5	2nd	DF	1st Fl, Cor (190)	10/5/97	SFUSD	MAL		18
Lafayette E.S.	4545 Anza St, 94121	1C	1		<5	3rd	DF	1st Fl, Cor (190)	10/5/97	SFUSD	MAL		18
Lafayette E.S.	4545 Anza St, 94121	2	2		<5	1st	DF	1ST FLOOR CORRIDOR (19)	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	2A	2		<5	1st	DF	1st Fl, Room 026B	10/5/97	SFUSD	MAL		35
Lafayette E.S.	4545 Anza St, 94121	2B	2		<5	2nd	DF	1st Fl, Room 026B	10/5/97	SFUSD	MAL		35
Lafayette E.S.	4545 Anza St, 94121	2C	2		<5	3rd	DF	1ST FLOOR CORRIDOR (19)	8/21/97	SFUSD	MAL		35
Lafayette E.S.	4545 Anza St, 94121	3	3	yes	16	1st	DF	2ND FLOOR CORRIDOR (25)	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	4	4		7	1st	DF	2ND FLOOR CORRIDOR (25)	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	5	5		9	1st	DF	2ND FLOOR CORRIDOR (25)	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	6	6		<5	1st	DF	2ND FLOOR CORRIDOR (25)	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	7	7	yes	17	1st	DF	1ST FLOOR CORRIDOR (19)	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	8	8		5	1st	DF	1ST FLOOR CORRIDOR (19)	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	9	9		<5	1st	MDF	YARD	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	10	10		<5	1st	MDF	YARD	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	11	11		<5	1st	SF	FACULTY LOUNGE RM (03)	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	12	12		<5	1st	SF	KITCHEN RM (037)	8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	13	na		<5	Blank			8/21/97	SFUSD	MAL		
Lafayette E.S.	4545 Anza St, 94121	NO1	na		NO	NO	SF	Yard outside Room 012	8/21/97	SFUSD	MAL		non-operational





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Final Interim Report		Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)
			Source ID	>15 ppb									
Lakeshore E.S.	220 Middlefield Dr., 94132	2	2		9708B83-02	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	3	3		9708B83-04	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	4	4		9708B83-05	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	5	5		9708B83-06	<5	1st	MDF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	6	6		9708B83-07	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	7	7		9708B83-08	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	8	8		9708B83-09	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	9	9		9708B83-10	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	12	12		9708B83-12	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	13	13		9708B83-13	<5	Duplicate	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	14	14		9708B83-14	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	15	15		9708B83-15	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	16	16		9708B83-16	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	17	17		9708B83-17	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	18	18		9708B83-18	<5	1st	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	1	na		9708B83-01	<5	Blank	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	2	na		9708B83-03	<5	Duplicate	DF	8/1/97	QST	SEQ		
Lakeshore E.S.	220 Middlefield Dr., 94132	11	na		9708B83-11	<5	Spike	DF	8/1/97	QST	SEQ	97-W00760-7	20



### Table 2 - Final Interim Results

SPUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243																			Final Interim Report		Follow-Up	
Sample ID	Address	Source ID	12 to 15 pph	>15 pph	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inches)	Fill Time (second)				
1	1044 Larkin St, 94109	1			49456-01	<5	1st	SF	Kitchen	10/9/97	AAE	MAL										
2	Larkin Street Youth Center	2			49456-02	<5	1st	SF	Restroom	10/9/97	AAE	MAL										
3	Larkin Street Youth Center	3			49456-03	<5	1st	SF	Art Room	10/9/97	AAE	MAL										
4	Larkin Street Youth Center	4			49456-04	<5	1st	SF	Staff Restroom	10/9/97	AAE	MAL										
5	Larkin Street Youth Center	5			49456-05	<5	1st	SF	Medical Clinic RR	10/9/97	AAE	MAL										
6	Larkin Street Youth Center	6			49456-06	<5	1st	SF	Alter Care Restroom	10/9/97	AAE	MAL										
7	Larkin Street Youth Center	7			49456-07	<5	1st	SF	Alter Care Kitchen	10/9/97	AAE	MAL										
8	Larkin St, 94109	na			49456-08	<5	Blank			10/9/97	AAE	MAL										
9	Larkin Street Youth Center	na			49456-09	97	Spike			10/9/97	AAE	MAL	97-W00776-12	100								



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243														
Site	Address	Sample ID	Source ID	Final Interim Report		Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
				Source	12 to 15 ppb									
Las Americas C.C.	3200 20th Ave., 94110	4	4			9709175-05	11	Duplicate	SDF	Room 204	9/5/97	QST	SEQ	
Las Americas C.C.	3200 20th Ave., 94110	1	1			9709175-01	5	1st	SDF	Room 207	9/5/97	QST	SEQ	
Las Americas C.C.	3200 20th Ave., 94110	2	2			9709175-02	<5	1st	SDF	Room 206	9/5/97	QST	SEQ	
Las Americas C.C.	3200 20th Ave., 94110	3	3			9709175-03	<5	1st	SDF	Room 205	9/5/97	QST	SEQ	
Las Americas C.C.	3200 20th Ave., 94110	4	4			9709175-04	11	1st	SDF	Room 204	9/5/97	QST	SEQ	
Las Americas C.C.	3200 20th Ave., 94110	5	na			9709175-06	<5	Blank			9/5/97	QST	SEQ	






Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project 82243													
Site	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveys	Lab	Spike ID #	Spike Level (ppb)
Lick M.S.	1	1		47942-01	12	1st	MDF	OUTSIDE YARD NORTH SIDE	8/23/97	SFUSD	MAL		
Lick M.S.	1A	1		49319-01	<3	1st	MDF	Yard outside	10/4/97	SFUSD	MAL		
Lick M.S.	1B	1		49319-02	<3	2nd	MDF	Yard outside	10/4/97	SFUSD	MAL		
Lick M.S.	1C	1		49319-07	<3	3rd	MDF	Yard outside	10/4/97	SFUSD	MAL		
Lick M.S.	2	2		47942-02	<3	1st	MDF	OUTSIDE YARD NORTH SIDE	8/23/97	SFUSD	MAL		
Lick M.S.	3	3		47942-03	<3	1st	MDF	OUTSIDE YARD WEST SIDE	8/23/97	SFUSD	MAL		
Lick M.S.	4	4		47942-04	<3	1st	DF	ROOM 001 BASEMENT	8/23/97	SFUSD	MAL		
Lick M.S.	5	5		47942-05	<3	1st	DF	CORRIDOR C90 - BASEMENT	8/23/97	SFUSD	MAL		
Lick M.S.	6	6		47942-06	<3	1st	DF	CORRIDOR C90 - FIRST FL	8/23/97	SFUSD	MAL		
Lick M.S.	7	7		47942-07	<3	1st	DF	CORRIDOR C90 - FIRST FL	8/23/97	SFUSD	MAL		
Lick M.S.	8	8		47942-08	<3	1st	DF	CORRIDOR C91, FIRST FL	8/23/97	SFUSD	MAL		
Lick M.S.	9	9		47942-09	<3	1st	DF	CAFETERIA 130, 1ST FLOOR	8/23/97	SFUSD	MAL		
Lick M.S.	10	10	yes	47942-10	17	1st	DF	BOY'S LOCKER ROOM 143	8/23/97	SFUSD	MAL		
Lick M.S.	10A	10		49319-03	<3	1st	DF	Room 130	10/4/97	SFUSD	MAL		
Lick M.S.	10B	10		49319-04	<3	2nd	DF	Room 130	10/4/97	SFUSD	MAL		
Lick M.S.	10C	10		49319-08	<3	3rd	DF	Room 130	10/4/97	SFUSD	MAL		
Lick M.S.	11	11		47942-11	<3	1st	DF	CORRIDOR C90 2ND FLOOR	8/23/97	SFUSD	MAL		
Lick M.S.	12	12		47942-12	<3	1st	DF	CORRIDOR C90 EAST SIDE	8/23/97	SFUSD	MAL		
Lick M.S.	13	13	yes	47942-13	12	1st	SF	TEACHERS LUNCH ROOM	8/23/97	SFUSD	MAL		
Lick M.S.	13A	13		49319-05	<3	1st	SF	Room 223	10/4/97	SFUSD	MAL		
Lick M.S.	13B	13		49319-06	<3	2nd	SF	Room 223	10/4/97	SFUSD	MAL		
Lick M.S.	14	14		47942-14	<3	1st	DF	CORRIDOR C90, THIRD FL	8/23/97	SFUSD	MAL		
Lick M.S.	15	15		47942-15	<3	1st	DF	CORRIDOR C90, 3RD FLOOR	8/23/97	SFUSD	MAL		
Lick M.S.	16	na		47942-16	11	Spike			8/23/97	SFUSD	MAL	97-W0071-6	10
Lick M.S.	17	na		47942-17	<3	Blank			8/23/97	SFUSD	MAL		
Lick M.S.	30	na		49319-09	<3	Blank			10/4/97	SFUSD	MAL		
Lick M.S.	NA1	na				NA		1st Fl, Kitchen		SFUSD	MAL		
Lick M.S.													non-accessible



**SFUSD Lead in Drinking Water Survey - Results Summary**Page 66 of 128. Printed 10/29/97



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report		Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
				Source 12 to 15	>15 ppb								
Longfellow E.S.	3630 Divisadero St., 94132	1	1			47741-01	1st	SF	1st Level Kitchen	8/22/97	RGA	MAL	
Longfellow E.S.	3630 Divisadero St., 94132	2	2			47741-02	1st	DF	1ST LEVEL HALL	8/22/97	RGA	MAL	
Longfellow E.S.	3630 Divisadero St., 94132	3	3			47741-03	1st	DF	1ST LEVEL HALL	8/22/97	RGA	MAL	
Longfellow E.S.	3630 Divisadero St., 94132	4	4			47741-04	1st	DF	2ND LEVEL HALL	8/22/97	RGA	MAL	
Longfellow E.S.	3630 Divisadero St., 94132	5	5			47741-05	1st	DF	2ND LEVEL HALL	8/22/97	RGA	MAL	
Longfellow E.S.	3630 Divisadero St., 94132	6	6			47741-06	1st	DF	BASEMENT LEVEL HALL	8/22/97	RGA	MAL	
Longfellow E.S.	3630 Divisadero St., 94132	7	7			47741-07	1st	MDF	PLAY YARD	8/22/97	RGA	MAL	
Longfellow E.S.	3630 Divisadero St., 94132	8	8			47741-08	1st	MDF	PLAY YARD	8/22/97	RGA	MAL	
Longfellow E.S.	3630 Divisadero St., 94132	9	9			47741-09	1st	DF	1ST LEVEL CLASSROOM #	8/22/97	RGA	MAL	
Longfellow E.S.	3630 Divisadero St., 94132	10	10			47741-10	1st	DF	1ST LEVEL CLASSROOM #	8/22/97	RGA	MAL	
Longfellow E.S.	3630 Divisadero St., 94132	11	na			47741-12	Spike			8/22/97	RGA	MAL	50
Longfellow E.S.	3630 Divisadero St., 94132	BL	na			47741-11	Blank			8/22/97	RGA	MAL	
Longfellow E.S.	3630 Divisadero St., 94132	NOI	na				NO	DF	outside Room 112	8/22/97	RGA	MAL	non-operational





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243																				
Site	Address	Sample ID	Final Interim Report			Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
			Source ID	12 to 15 ppb	>15 ppb															
Lowell H.S.	1101 Encalypus Dr, 94132	1	1			48769-01	5	1st	DF	Adj to Room 129	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	2	2			48769-02	<5	1st	DF	Adj to Room 112A	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	3	3		yes	48769-03	13	1st	DF	Adj to Room 142	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	4	4			48769-04	<5	1st	DF	Adj to Room 251	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	5	5			48769-05	<5	1st	DF	Adj to Room T71	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	6	6			48769-06	<5	1st	DF	Adj to Room T69	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	7	7			48769-07	<5	1st	DF	Adj to Room J213	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	8	8			48769-08	<5	1st	DF	Adj to Room T72	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	9	9			48769-09	<5	1st	DF	Adj to Room 339	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	10	10			48769-10	<5	1st	DF	Adj to Room T63	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	11	11			48769-11	<5	1st	DF	Adj to Room 046	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	12	12			48769-12	<5	1st	DF	Adj to Room 045	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	13	13			48769-13	<5	1st	DF	Adj to Room 041	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	14	14			48769-14	<5	1st	DF	Room 033	9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	15	na			48769-15	20	Spike			9/22/97	SES	MAL							
Lowell H.S.	1101 Encalypus Dr, 94132	16	na			48769-16	<5	Blank			9/22/97	SES	MAL							



**SFUSD Lead in Drinking Water Survey - Results Summary**

SFUSD Lead in Drinking Water Survey - Results Summary																			
Summer / Fall 1997																			
SCA Project B.2243																			
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
Mahter C.C.	990 Church St., 94114	1	1		9708CC09-01	<5	1st	SF	Kitchen	8/25/97	RGA	SEQ							
Mahter C.C.	990 Church St., 94114	1	1		9708CC09-02	<5	Duplicate	SF	Kitchen	8/25/97	RGA	SEQ							
Mahter C.C.	990 Church St., 94114	2	2		9708CC09-03	<5	1st	DF	Courtyard	8/25/97	RGA	SEQ							
Mahter C.C.	990 Church St., 94114	3	3		9708CC09-04	<5	1st	SF	Staff Break Rm	8/25/97	RGA	SEQ							
Mahter C.C.	990 Church St., 94114	BL	na		9708CC09-05	<5	Blank			8/25/97	RGA	SEQ							



SFUSD Lead in Drinking Water Survey - Results Summary		Final Interim Report		Sample ID		Source ID		12 to 15 ppb		>15 ppb		Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spile ID #	Spile Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
					1	1						47607-01	<3	1st	DF	C-90 - BASEMENT OUTSIDE	8/16/97	SES	MAL							
					2	2						47607-02	7	1st	SF	ROOM 004 - KITCHEN SINK	8/16/97	SES	MAL							
					3	3				yes		47607-03	14	1st	SF	ROOM 004 - KITCHEN SINK	8/16/97	SES	MAL							
					4	4						47607-04	<3	1st	DF	C-90 - BASEMENT OUTSIDE	8/16/97	SES	MAL							
					5	5						47607-05	<3	1st	DF	C-90 - FIRST FLOOR OUTSIDE	8/16/97	SES	MAL							
					6	6						47607-06	<3	1st	DF	C-90 - FIRST FLOOR OUTSIDE	8/16/97	SES	MAL							
					7	7						47607-07	<3	1st	MDF	PLAYGROUND/ ONE FOUN	8/16/97	SES	MAL							
					8	8						47607-08	8	1st	MDF	C-92 - OUTSIDE 204 (3 TAP	8/16/97	SES	MAL							
					9	na						47607-09	<3	Blank			8/16/97	SES	MAL							





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Supervisor	Lab	Spike ID #
Mann MS	3351 23rd St., 94110	1	1	>15 pph	48520-01	<5	1st	DF	Main Entrance	9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	2	2		48520-02	<5	1st	DF	C90, by Rm 102	9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	3	3		48520-03	<5	1st	DF	C90, by Rm 102	9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	4	4		48520-04	<5	1st	DF	C92	9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	5	5		48520-05	<5	1st	DF	C95, by Rm 152	9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	6	6		48520-06	<5	1st	DF	C92, by Rm 152	9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	7	7		48520-07	<5	1st	DF	C95, by Rm 251	9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	8	8		48520-08	<5	1st	DF	C95, by Rm 251	9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	9	9		48520-09	<5	1st	DF	C90, by Rm 202	9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	10	10		48520-10	<5	1st	DF	C90, by Rm 202	9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	11	11		48520-11	<5	1st	DF	C90, by Rm 302	9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	12	na		48520-12	21	Spike			9/15/97	SES	MAL	20
Mann MS	3351 23rd St., 94110	13	na		48520-13	<5	Blank			9/15/97	SES	MAL	
Mann MS	3351 23rd St., 94110	NO1	na				NO	DF	outside Room 114		SES	MAL	
Mann MS	3351 23rd St., 94110	NO2	na				NO	DF	outside Room 302		SES	MAL	
												non-operational	
												non-operational	



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report											
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up	
Marina J.H.	3500 Fillmore St, 94123	2	2			47744-02	<5	1st	DF	OUTSIDE ROOM 104	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	3	3			47744-03	<5	1st	SF	COOKING ROOM RM - 104	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	4	4			47744-04	<5	1st	SF	ROOM - 104 COOKING RM	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	5	5			47744-05	<5	1st	SF	ROOM - 104 COOKING RM	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	6	6			47744-06	<5	1st	SF	ROOM - 104 COOKING RM	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	7	7			47744-07	<5	1st	SF	ROOM - 104 COOKING RM	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	8	8			47744-08	<5	1st	SF	ROOM - 104 COOKING RM	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	9	9			47744-09	6	1st	DF	OUTSIDE ROOM 150	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	10	10			47744-10	<5	1st	DF	OUTSIDE OF BLDG OUTSIDE	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	11	11			47744-11	<5	1st	DF	THIRD FLOOR OUTSIDE RM	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	13	13			47744-12	<5	1st	DF	SECOND FLOOR OUTSIDE	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	14	14			47744-13	<5	1st	DF	OUTSIDE ROOM 208	8/23/97	QST	MAL			<5					
Marina J.H.	3500 Fillmore St, 94123	15	15			47744-14	10	1st	DF	INSIDE ROOM 217	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	16	16			47744-15	9	1st	DF	INSIDE ROOM 03B	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	17	17		yes	47744-16	13	1st	DF	ROOM 036	8/23/97	QST	MAL			13					
Marina J.H.	3500 Fillmore St, 94123	17A	17			49188-01	<5	1st	DF	Room 036	10/2/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	17B	17			49188-01	<5	2nd	DF	Room 036	10/2/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	17C	17			49188-01	<5	3rd	DF	Room 036	10/2/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	18	18			47744-17	<5	1st	MDF	OUTSIDE OF BLDG. ROOM	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	19	19			47744-18	<5	1st	DF	OUTSIDE ROOM 117	8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	20	20			47744-19	<5	1st	DF	INSIDE ROOM 01B	8/23/97	QST	MAL			<5					
Marina J.H.	3500 Fillmore St, 94123	1	na			47744-01	<5	Blank			8/23/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	21	na			47744-20	16	Blank			8/23/97	QST	MAL	97-W00761-17	30						
Marina J.H.	3500 Fillmore St, 94123	BL	na			49188-01	<5	Blank			10/2/97	QST	MAL								
Marina J.H.	3500 Fillmore St, 94123	NO1	na					NO	DF	Room T-63A		QST	MAL				non-operational				
Marina J.H.	3500 Fillmore St, 94123	NO2	na					NO	DF	outside Room 316		QST	MAL				non-operational				




Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report		Sample ID		Lab ID		Results (ppb)		Sample Type		Source		Room		Sample Date		Surveys		Lab		Spike ID #		Spike Level (ppb)		Inter-lab Results (ppb)		Comments & Field ID's		Arch Height (inch)		Fill Time (second)		Follow-Up																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
Site		Address		Sample ID		Source ID		12 to 15		15 to 17		17 to 19		19 to 21		21 to 23		23 to 25		25 to 27		27 to 29		29 to 31		31 to 33		33 to 35		35 to 37		37 to 39		39 to 41		41 to 43		43 to 45		45 to 47		47 to 49		49 to 51																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
Marshall E.S.	1575 5th St., 94103	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project 82243										Final Interim Report		Sample		Surveyor		Spike Level		Inter-lab Results (ppb)		Comments & Field ID's		Arch Height (inch)		Fill Time (second)		Follow-Up	
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	ppb	Results (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up						
Marshall H.S.	45 Conkling St., 94124	1	1			48050-01	<5	1st	DF	C90	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	2A	2	yes		9710514-01	13	1st	DF	C90	8/26/97	SCA	SEQ				16		2	45							
Marshall H.S.	45 Conkling St., 94124	2B	2			9710514-02	14	2nd	DF	C90	10/7/97	SCA	SEQ						2	45							
Marshall H.S.	45 Conkling St., 94124	2C	2	yes		9710514-03	<5	3rd	DF	C90	10/7/97	SCA	SEQ						2	45							
Marshall H.S.	45 Conkling St., 94124	3	3			48050-03	11	1st	DF	C90	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	4	4			48050-04	11	1st	DF	VM 128 (CAF)	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	5	5	yes		48050-05	44	1st	DF	VM 128 (CAF)	8/26/97	SCA	MAL						1.5	50							
Marshall H.S.	45 Conkling St., 94124	5A	5			9710514-04	<5	1st	DF	VM 128 (CAF)	10/7/97	SCA	SEQ						1.5	50							
Marshall H.S.	45 Conkling St., 94124	5B	5			9710514-05	10	2nd	DF	VM 128 (CAF)	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	5C	5			9710514-06	5	3rd	DF	VM 128 (CAF)	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	6	6			48050-06	5	1st	DF	C90	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	7	7			48050-07	<5	1st	DF	C90	8/26/97	SCA	MAL				6										
Marshall H.S.	45 Conkling St., 94124	8	8			48050-08	<5	1st	DF	C90	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	9	9	yes		48050-09	18	1st	DF	C90	8/26/97	SCA	MAL				18										
Marshall H.S.	45 Conkling St., 94124	9A	9			9710514-07	8	1st	DF	C90	10/7/97	SCA	SEQ						2	40							
Marshall H.S.	45 Conkling St., 94124	9B	9	yes		9710514-08	25	2nd	DF	C90	10/7/97	SCA	SEQ						2	40							
Marshall H.S.	45 Conkling St., 94124	9C	9			9710514-09	<5	3rd	DF	C90	10/7/97	SCA	SEQ						2	40							
Marshall H.S.	45 Conkling St., 94124	9C	9			9710514-10	<5	Duplicate	DF	C90	10/7/97	SCA	SEQ						2	40							
Marshall H.S.	45 Conkling St., 94124	10	10			48050-10	<5	1st	DF	C90	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	11	11			48050-11	7	1st	DF	BG1	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	12	12			48050-12	10	1st	DF	GG1	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	13	13	yes		48050-13	13	1st	DF	BG2	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	13A	13			9710514-11	<5	1st	DF	BG2	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	13B	13			9710514-12	<5	2nd	DF	BG2	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	13C	13			9710514-13	<5	3rd	DF	BG2	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	14	14	yes		48050-14	21	1st	DF	GG2	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	14A	14			9710514-14	<5	1st	DF	GG2	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	14B	14			9710514-15	<5	2nd	DF	GG2	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	14C	14			9710514-16	<5	3rd	DF	GG2	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	15	15	yes		48050-15	42	1st	DF	C83	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	15A	15			9710514-17	<5	1st	DF	C83	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	15B	15			9710514-18	<5	2nd	DF	C83	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	15C	15			9710514-19	<5	3rd	DF	C83	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	16	16			9710514-20	6	Duplicate	DF	C83	10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	17	17	yes		48050-16	<5	1st	SF	124E	8/26/97	SCA	MAL														
Marshall H.S.	45 Conkling St., 94124	17A	17			9710514-21	32	1st	DF	C86	10/7/97	SCA	SEQ						3	20							
Marshall H.S.	45 Conkling St., 94124	17B	17			9710514-22	8	2nd	DF	C86	10/7/97	SCA	SEQ						3	20							
Marshall H.S.	45 Conkling St., 94124	17C	17			9710514-23	<5	3rd	DF	C86	10/7/97	SCA	SEQ						3	20							
Marshall H.S.	45 Conkling St., 94124	18A	18			9710514-24	<5	1st	DF	C86	10/7/97	SCA	SEQ						2	30							
Marshall H.S.	45 Conkling St., 94124	18B	18			9710514-25	<5	2nd	DF	C86	10/7/97	SCA	SEQ						2	30							
Marshall H.S.	45 Conkling St., 94124	18C	18			9710514-26	<5	3rd	DF	C86	10/7/97	SCA	SEQ						2	30							
Marshall H.S.	45 Conkling St., 94124	18D	18			9710514-28	11	Duplicate	DF	C86	10/7/97	SCA	SEQ						2	30							
Marshall H.S.	45 Conkling St., 94124	18D	18			9710514-27	10	Duplicate	DF	C86	10/7/97	SCA	SEQ						2	30							
Marshall H.S.	45 Conkling St., 94124	18	na			48050-18	21	Spike	DF		8/26/97	SCA	MAL	97-W00774-1	20												
Marshall H.S.	45 Conkling St., 94124	19	na			48050-19	<5	Blank	DF		8/26/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	BL	na			9710514-29	<5	Blank	DF		10/7/97	SCA	SEQ														
Marshall H.S.	45 Conkling St., 94124	NA1	na					NA	DF	Room 119		SCA	MAL					non-accessible non-operational									
Marshall H.S.	45 Conkling St., 94124	NO1	na					NO	DF	Room 102		SCA	MAL					non-operational non-operational									
Marshall H.S.	45 Conkling St., 94124	NO10	na					NO	DF	Room 105		SCA	MAL					non-operational non-operational									
Marshall H.S.	45 Conkling St., 94124	NO2	na					NO	DF	Room 107		SCA	MAL					non-operational non-operational									
Marshall H.S.	45 Conkling St., 94124	NO3	na					NO	DF	Room 206		SCA	MAL					non-operational non-operational									
Marshall H.S.	45 Conkling St., 94124	NO4	na					NO	DF	Room 206		SCA	MAL					non-operational non-operational									
Marshall H.S.	45 Conkling St., 94124	NO5	na					NO	DF	Room 206		SCA	MAL					non-operational non-operational									
Marshall H.S.	45 Conkling St., 94124	NO6	na					NO	DF	Room 119		SCA	MAL					non-operational non-operational									
Marshall H.S.	45 Conkling St., 94124	NO7	na					NO	DF	Room 200		SCA	MAL					non-operational non-operational									
Marshall H.S.	45 Conkling St., 94124	NO8	na					NO	DF	Room 200		SCA	MAL					non-operational non-operational									
Marshall H.S.	45 Conkling St., 94124	NO9	na					NO	DF	Room 312		SCA	MAL					non-operational non-operational									



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary																					
Summer / Fall 1997																					
SCA Project B243																					
Sample ID	Site	Address	Final Interim Report	Source ID	I2 to I5	I5 to I8	Lab ID	Results (ppb)	Sample Type	Source	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inches)	Fill Time (second)	Follow-Up
1	Martin C.C.	1155 Page St., 94117		1			9708B59-01	<5	1st	SF	Kitchen 1st Flr	8/18/97	QST	SEQ							
1	Martin C.C.	1155 Page St., 94117		1			9708B59-02	<5	Duplicate	SF	Kitchen 1st Flr	8/18/97	QST	SEQ							
2	Martin C.C.	1155 Page St., 94117		2			9708B59-03	<5	1st	SF	Kitchen 1st Flr	8/18/97	QST	SEQ							
3	Martin C.C.	1155 Page St., 94117		3			9708B59-04	<5	Blank	SF	Kitchen 1st Flr	8/18/97	QST	SEQ							
4	Martin C.C.	1155 Page St., 94117		na			9708B59-05	<5	Spike	SF		8/18/97	QST	SEQ	97-W007040-10	20					



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243														
Site		Sample ID	Source ID	Final Interim Report		Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Address				12 to 15 ppb	>15 ppb									
555 Potrero Dr., 94131		1	1		yes	48240-01	47	1st	DF	AUDITORIUM LOBBY	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		2	2			48240-02	<5	1st	SF	CAFETERIA KIT. WEST	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		3	3			48240-03	<5	1st	SF	CAFETERIA KIT. CENTER	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		4	4	yes		48240-04	14	1st	SF	CAFETERIA KIT. EAST	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		5	5		yes	48240-05	18	1st	DF	BOYS' LOCKER ROOM NO.	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		6	6			48240-06	10	1st	DF	BOYS' LOCKER ROOM NO.	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		7	7			48240-07	<5	1st	DF	BOYS' LOCKER ROOM NO.	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		8	8			48240-08	<5	1st	DF	GYM LOBBY EAST	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		9	9			48240-09	<5	1st	DF	GYM LOBBY WEST	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		11	11			48240-11	<5	1st	DF	ACADEMIC - L4 N HALL	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		12	12			48240-12	11	1st	DF	ACADEMIC - L4 S HALL	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		14	14		yes	48240-13	16	1st	DF	ACADEMIC - L3 S HALL	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		15	15			48240-14	6	1st	DF	ACADEMIC - L3 S HALL	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		17	17			48240-16	<5	1st	DF	ACADEMIC - L2 N HALL	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		18	18			48240-17	5	1st	DF	ACADEMIC - L2 N HALL	9/6/97	ATC	MAL	
555 Potrero Dr., 94131		10	na			48240-10	<5	Blank			9/6/97	ATC	MAL	
555 Potrero Dr., 94131		16	na			48240-15	21	Shake			9/6/97	ATC	MAL	





Page 77 of 128. Printed 10/20/97



SFUSD Lead in Drinking Water Survey - Results Summary										Final Interim Report												
Summer / Fall 1997 SCA Project B2243		Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
		McKinley E.S.	1025 14th St. 94114	2	2		yes	9708B70-02	12	1st	DF	Rm 17	8/1997	QST	SEQ			14				
		McKinley E.S.	1025 14th St. 94114	2	2		yes	9708B70-03	11	Duplicate	DF	Rm 17	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	2A	2			49166-01	<5	1st	DF	Room 17	10/29/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	2B	2			49166-02	<5	2nd	DF	Room 17	10/29/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	2C	2			49166-03	8	3rd	DF	Room 17	10/29/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	3	3			9708B70-04	11	1st	DF	Rm 18	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	4	4			9708B70-05	5	1st	DF	Hall 1st Flr by Rm 10	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	5	5			9708B70-06	<5	1st	DF	Rm 11	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	6	6		yes	9708B70-07	20	1st	DF	Rm 12	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	7	7		yes	9708B70-08	12	1st	DF	Rm 13	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	7A	7			49166-04	<5	1st	DF	Room 13	10/29/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	7B	7			49166-05	<5	2nd	DF	Room 13	10/29/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	7C	7			49166-06	<5	3rd	DF	Room 13	10/29/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	8	8			9708B70-09	8	1st	DF	Rm 14	8/1997	QST	SEQ			9				
		McKinley E.S.	1025 14th St. 94114	9	9			9708B70-10	6	1st	DF	Rm 15	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	10	10		yes	9708B70-11	13	1st	DF	Rm 16	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	10A	10			49166-07	<5	1st	DF	Room 16	10/29/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	10B	10			49166-08	<5	2nd	DF	Room 16	10/29/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	10C	10			49166-09	<5	3rd	DF	Room 16	10/29/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	12	12			9708B70-13	<5	1st	DF	Kitchen/Office 1st Flr	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	13	13			9708B70-14	<5	1st	SF	1st by Girls RR	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	14	14			9708B70-15	7	1st	DF	Staff Lunch Rm Kitchen, 2nd	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	15	15			9708B70-16	9	1st	SF	Rm 28	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	16	16		yes	9708B70-17	19	1st	DF	Rm 27	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	17	17			9708B70-18	8	1st	DF	Rm 26	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	18	18			9708B70-19	<5	1st	DF	Rm 25	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	18	18			9708B70-20	<5	Duplicate	DF	Rm 25	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	19	19			9708B70-21	9	1st	DF	Rm 24	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	20	20			9708B70-22	8	1st	DF	Rm 23	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	21	21			9708B70-23	10	1st	DF	Rm 22	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	22	22			9708B70-24	<5	1st	DF	Rm 21	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	23	23			9708B70-25	<5	1st	DF	Hall by Rm 24	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	24	24			9708B70-26	<5	1st	DF	Playground NE of Office	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	25	25			9708B70-27	<5	1st	MDF	Playground SW of Bldg	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	25	25			9708B70-28	<5	1st	MDF	Playground SW of Bldg	8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	26	26			48383-01	5	1st	DF	ROOM 12	9/10/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	27	27			48383-02	<5	1st	DF	ROOM 12	9/10/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	29	29			48383-04	<5	1st	DF	ROOM 27	9/10/97	QST	MAL							
		McKinley E.S.	1025 14th St. 94114	1	na			9708B70-01	<5	Blank	DF		8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	11	na			9708B70-12	<5	Spike	DF		8/1997	QST	SEQ							
		McKinley E.S.	1025 14th St. 94114	8L	na			49166-10	27	Blank	DF		10/29/97	QST	MAL			30				
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			
		McKinley E.S.	1025 14th St. 94114																			



**San Francisco Public Utility District**  
**Summer / Fall 1997**  
**SCA Project B2243**

Page 79 of 128, Printed 10/29/97





THE UNIVERSITY OF CHICAGO PRESS

Page 80 of 120, Printed 10/29/97



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243												
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab
Miraloma E.S.	175 Omar Way, 94112	1	1		47609-01	8	1st	DF	1ST FLOOR - C90 OUTSIDE	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	2	2		47609-02	15	1st	DF	1ST FLOOR - RM 107	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	3	3	yes	47609-03	10	1st	DF	1ST FLOOR - RM 105	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	4	4		47609-04	53	1st	DF	1ST FLOOR - RM 103	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	5	5		47609-05	18	1st	DF	1ST FLOOR - RM 101	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	6	6	yes	47609-06	13	1st	DF	1ST FLOOR - RM 100	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	7	7		47609-07	10	1st	DF	1ST FLOOR - RM 102	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	8	8	yes	47609-08	12	1st	DF	1ST FLOOR - RM 106	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	9	9		47609-09	<5	1st	SF	1ST FLOOR - RM 110 - FAC	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	10	10	yes	47609-10	14	1st	DF	RM 001	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	11	11		47609-11	20	1st	DF	RM 010	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	12	12		47609-12	9	1st	DF	RM 012	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	13	13		47609-13	<5	1st	DF	RM 014	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	14	14	yes	47609-14	21	1st	DF	RM 016	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	15	15	yes	47609-15	21	1st	DF	RM 018	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	16	16		47609-16	9	1st	SF	BASEMENT FLOOR - RM 02	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	17	17	yes	47609-17	17	1st	SF	KITCHEN RM 023	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	18	18	yes	47609-18	40	1st	SF	KITCHEN RM 023	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	21	21		47609-21	25	1st	DF	ROOM 123	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	19	na	yes	47609-19	12	Spike			8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	20	na		47609-20	<5	Blank			8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	NO1	na				NO	DF	Room 008	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	NO2	na				NO	DF	Room 020C	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	NO3	na				NO	DF	Room 108	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	NO4	na				NO	DF	Room 109	8/17/97	SES	MAL
Miraloma E.S.	175 Omar Way, 94112	NO5	na				NO	DF	outside Room 120	8/17/97	SES	MAL



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Mission Annex	421 Bartlett St, 94127	2	2		48242-01	38	1st	SDF	Portable #4	9/5/97	ATC	MAL	
Mission Annex	421 Bartlett St, 94127	3	3		48242-02	12	1st	SDF	Portable #5	9/5/97	ATC	MAL	
Mission Annex	421 Bartlett St, 94127	4	4	yes	48242-03	22	1st	SDF	Portable #6	9/5/97	ATC	MAL	
Mission Annex	421 Bartlett St, 94127	6	na		48242-04	<5	Blank			9/5/97	ATC	MAL	
Mission Annex	421 Bartlett St, 94127	7	na		48242-05	22	Spike			9/5/97	ATC	MAL 97-W00753-9	20
Mission Annex C.C.	421 Bartlett St, 94127	1	1		48241-01	5	1st	SF	Kitchen 421 Bartlett	9/5/97	ATC	MAL	
Mission Annex C.C.	421 Bartlett St, 94127	2	2		48021-01	<5	1st	SF	STAFF LOUNGE	8/23/97	ATC	MAL	
Mission Annex C.C.	421 Bartlett St, 94127	2A	2		49207-07	8	1st	SDF	Portable #4	10/3/97	ATC	MAL	0.5
Mission Annex C.C.	421 Bartlett St, 94127	2B	2		49207-08	5	2nd	SDF	Portable #4	10/3/97	ATC	MAL	0.5
Mission Annex C.C.	421 Bartlett St, 94127	2C	2	yes	49207-09	13	3rd	SDF	Portable #4	10/3/97	ATC	MAL	0.5
Mission Annex C.C.	421 Bartlett St, 94127	3A	3		49207-04	<5	1st	SDF	Portable #5	10/3/97	ATC	MAL	4
Mission Annex C.C.	421 Bartlett St, 94127	3B	3		49207-05	<5	2nd	SDF	Portable #5	10/3/97	ATC	MAL	4
Mission Annex C.C.	421 Bartlett St, 94127	3C	3		49207-06	11	3rd	SDF	Portable #5	10/3/97	ATC	MAL	4
Mission Annex C.C.	421 Bartlett St, 94127	4	4		48241-02	7	1st	SF	Kitchen 2950 Mission	9/5/97	ATC	MAL	3.5
Mission Annex C.C.	421 Bartlett St, 94127	4A	4		49207-01	9	1st	SDF	Portable #6	10/3/97	ATC	MAL	3.5
Mission Annex C.C.	421 Bartlett St, 94127	4B	4		49207-02	8	2nd	SDF	Portable #6	10/3/97	ATC	MAL	3.5
Mission Annex C.C.	421 Bartlett St, 94127	4C	4		49207-03	10	3rd	SDF	Portable #6	10/3/97	ATC	MAL	3.5
Mission Annex C.C.	421 Bartlett St, 94127	5	na		48021-02	<5	Blank			8/23/97	ATC	MAL	





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary																			
Summer / Fall 1997																			
SCA Project B2243																			
Site	Address	Sample ID	Final Interim Report		Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
			Source ID	>15 ppb															
Mission H.S.	3750 18th St., 94114	1	1	yes	47836-01	19	1st	DF	GIRL'S LOCKERROOM ROOM	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	2	2		47836-02	<5	1st	SF	BASEMENT LEVEL	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	3	3		47836-03	5	1st	DF	1ST FLOOR - C97 OUTSIDE	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	4	4		47836-04	8	1st	SF	1ST FLOOR - RM 116	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	5	5		47836-05	8	1st	SF	1ST FLOOR - ROOM 122 CA	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	6	6		47836-06	<5	1st	SF	1ST FLOOR - RM 122 CAFE	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	7	7		47836-07	5	1st	SF	1ST FLOOR - RM 122 CAFE	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	8	8		47836-08	5	1st	SF	1ST FLOOR - RM 122 CAFE	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	9	9		47836-09	7	1st	SF	1ST FLOOR - RM 122 CAFE	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	10	10		47836-10	<5	1st	SF	1ST FLOOR - RM 117 CAFE	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	11	11		47836-11	<5	1st	DF	2ND FLOOR - C97 OUTSIDE	8/26/97	SES	MAL			<5				
Mission H.S.	3750 18th St., 94114	12	12		47836-12	<5	1st	SF	2ND FLOOR - RM 237 COOK	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	13	13		47836-13	5	1st	SF	2ND FLOOR - RM 237 COOK	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	14	14		47836-14	10	1st	SF	2ND FLOOR - RM 237 COOK	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	15	15		47836-15	<5	1st	DF	2ND FLOOR - C91 OUTSIDE	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	16	16		47836-16	<5	1st	DF	4TH FLOOR - C91 OUTSIDE	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	17	17		47836-17	5	1st	DF	4TH FLOOR - C91 OUTSIDE	8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	18	na		47836-18	<5		Blank		8/26/97	SES	MAL							
Mission H.S.	3750 18th St., 94114	NO1	na			NO	NO	DF	Room 237		SES	MAL				non-operational			
Mission H.S.	3750 18th St., 94114	NO2	na			NO	NO	DF	outside Room T-62		SES	MAL				non-operational			
Mission H.S.	3750 18th St., 94114	NO3	na			NO	NO	SF	Room 122		SES	MAL				non-operational			
Mission H.S.	3750 18th St., 94114	NO4	na			NO	NO	SF	Room 237		SES	MAL				non-operational			



SFUSD Lead in Drinking Water Survey - Results Summary  
 Summer / Fall 1997  
 SCA Project B243

SFUSD Lead in Drinking Water Survey - Results Summary																				
Summer / Fall 1997																				
SCA Project B2243																				
Site	Address	Sample ID	Final Interim Report			Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
			Source ID	12 to 15 ppb	>15 ppb															
Monroe E.S.	260 Madrid St., 94112	2	7			47845-02	<5	1st	SDF	101	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	3	3			47845-03	<5	1st	DF	102	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	4	4			47845-04	<5	1st	DF	102	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	5	5			47845-05	<5	1st	DF	103	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	6	6			47845-06	<5	1st	SDF	103	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	8	8			47845-08	6	1st	SDF	104	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	11	11			47845-11	<5	1st	SDF	105	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	12	12			47845-12	<5	1st	MDF	LIBRARY	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	13	13			47845-13	6	1st	SDF	106	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	14	14			47845-14	7	1st	DF	107	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	15	15			47845-15	<5	1st	SDF	107	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	16	16			47845-16	9	1st	SDF	108	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	17	17			47845-17	<5	1st	SDF	109	8/24/97	AAE	MAL			<5				
Monroe E.S.	260 Madrid St., 94112	18	18			47845-18	<5	1st	SDF	110	8/24/97	AAE	MAL			<5				
Monroe E.S.	260 Madrid St., 94112	19	19			47845-19	<5	1st	SF	KITCHEN	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	21	21			47845-21	<5	1st	SDF	201	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	22	22			47845-22	<5	1st	DF	201	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	23	23			47845-23	<5	1st	DF	202	8/24/97	AAE	MAL			<5				
Monroe E.S.	260 Madrid St., 94112	24	24			47845-24	<5	1st	SDF	202	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	25	25			47845-25	<5	1st	DF	203	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	26	26			47845-26	<5	1st	SDF	203	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	27	27			47845-27	<5	1st	SDF	204	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	28	28			47845-28	<5	1st	SDF	205	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	29	29			47845-29	<5	1st	SF	LOUNGE	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	31	31			47845-31	<5	1st	SF	WOMEN'S RM	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	32	32			47845-32	<5	1st	SF	MEN'S RM	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	33	33			47845-33	<5	1st	MDF	2ND FLOOR DF	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	34	34			47845-34	<5	1st	SF	BOY'S RM	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	35	35			47845-35	<5	1st	SF	GIRL'S RM	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	36	36			47845-36	<5	1st	MDF	OUTSIDE MDF	8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	10	na			47845-10	<5	Blank	Blank		8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	20	na			47845-20	<5	Blank	Blank		8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	30	na			47845-30	<5	Blank	Blank		8/24/97	AAE	MAL							
Monroe E.S.	260 Madrid St., 94112	97-W0075	na			47845-37	20	Spike	Spike		8/24/97	AAE	MAL	97-W007531-4	20					



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source	Room	Sample Date	Surveyor	Lab	Spike ID #
Miscellaneous E.S.	2355 Folcom St., 94110	9	9		9709158-10	<3	Duplicate	SDF	Room 201	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	16	16		9709158-18	<3	Duplicate	SDF	Faculty Room	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	10	10		9709158-11	<3	1st	SDF	Room 202	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	11	11		9709158-12	<3	1st	SDF	Room 203	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	12	12		9709158-13	<3	1st	SDF	Room 205	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	13	13		9709158-14	<3	1st	SDF	Room 206	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	14	14		9709158-15	<3	1st	SDF	Room 207	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	16	16		9709158-17	<3	1st	SDF	Faculty Room	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	2	2		9709158-02	<3	1st	SDF	Room 102	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	3	3		9709158-03	<3	1st	SDF	Room 103	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	4	4		9709158-04	<3	1st	SDF	Room 104	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	5	5		9709158-05	<3	1st	SDF	Room 105	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	6	6		9709158-06	<3	1st	SDF	Room 106	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	7	7		9709158-07	<3	1st	SDF	Room 107	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	8	8		9709158-08	<3	1st	SDF	Room 108	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	9	9		9709158-09	<3	1st	SDF	Room 201	9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	15	na		9709158-16	13	Spike			9/5/97	QST	SEQ	97-W00771-1
Miscellaneous E.S.	2355 Folcom St., 94110	1	na		9709158-01	<3	Blank			9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	1	1		9709198-01	<3	1st			9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	2	2		9709198-02	<3	1st			9/5/97	QST	SEQ	
Miscellaneous E.S.	2355 Folcom St., 94110	NO1	na				NO	MDF	1st Flr by Boys Room	9/5/97	QST	non-operational	





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Sample ID	Final Interim Report			Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)
		Source ID	12 to 15 ppb	>15 ppb									
Muir E.S.P.K.	2	2			9708850-02	<5	1st	DF	8/17/97	QST	SEQ		
Muir E.S.P.K.	3	3			9708850-03	<5	1st	DF	8/17/97	QST	SEQ		
Muir E.S.P.K.	4	4			9708850-04	<5	1st	DF	8/17/97	QST	SEQ		
Muir E.S.P.K.	5	5			9708850-05	<5	1st	SDF	8/17/97	QST	SEQ		
Muir E.S.P.K.	6	6			9708850-06	7	1st	DF	8/17/97	QST	SEQ		
Muir E.S.P.K.	7	7			9708850-07	<5	1st	DF	8/17/97	QST	SEQ		
Muir E.S.P.K.	8	8			9708850-08	<5	1st	DF	8/17/97	QST	SEQ		
Muir E.S.P.K.	9	9			9708850-09	<5	1st	DF	8/17/97	QST	SEQ		
Muir E.S.P.K.	10	10			9708850-10	<5	1st	DF	8/17/97	QST	SEQ		
Muir E.S.P.K.	10	10			9708850-11	<5	Duplicate	DF	8/17/97	QST	SEQ		
Muir E.S.P.K.	1	na			9708850-01	<5	Blank	DF	8/17/97	QST	SEQ		
Muir E.S.P.K.	NOI	na					NO	DF		QST	SEQ		
								outside Room 014					non-operational



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary													
Summer / Fall 1997													
SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor
New Traditions E.S.	2049 Grove St., 94117	2	2				47366-02	<5	1st	MDF	SOUTHWEST OF BASEMENT	8/14/97	QST
New Traditions E.S.	2049 Grove St., 94117	3	3				47366-03	25	1st	DF	FIRST FLOOR HALLWAY	8/14/97	QST
New Traditions E.S.	2049 Grove St., 94117	4	4			yes	47366-04	<5	1st	SF	KITCHEN SINK RM. 013A	8/14/97	QST
New Traditions E.S.	2049 Grove St., 94117	5	5				47366-05	10	1st	DF	HALLWAY - SOUTH OF RM	8/14/97	QST
New Traditions E.S.	2049 Grove St., 94117	6	6				47366-06	<5	1st	MDF	NORTHWEST OF BLDG (OI)	8/14/97	QST
New Traditions E.S.	2049 Grove St., 94117	7	7				47366-07	<5	1st	MDF	NORTHEAST OF BLDG (OI)	8/14/97	QST
New Traditions E.S.	2049 Grove St., 94117	8	8				47366-08	<5	1st	SF	SINK INSIDE OF RM B-14	8/14/97	QST
New Traditions E.S.	2049 Grove St., 94117	9	9				47366-09	<5	1st	SF	SINK INSIDE OF RM B-15	8/14/97	QST
New Traditions E.S.	2049 Grove St., 94117	11	11				48027-02	<5	1st	DF	HALLWAY, NORTH OF RO	8/30/97	QST
New Traditions E.S.	2049 Grove St., 94117	12	12				48027-03	<5	2nd	DF	HALLWAY, NORTH OF RO	8/30/97	QST
New Traditions E.S.	2049 Grove St., 94117	13	13				48027-04	<5	3rd	DF	HALLWAY, NORTH OF RO	8/30/97	QST
New Traditions E.S.	2049 Grove St., 94117	1	na				47366-01	<5	Blank	DF	HALLWAY, NORTH OF RO	8/14/97	QST
New Traditions E.S.	2049 Grove St., 94117	10	na				48027-01	<5	Blank			8/30/97	QST
New Traditions E.S.	2049 Grove St., 94117	10	na				48027-01	<5	Blank			8/30/97	QST



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project #3243													
Site	Address	Sample ID	Final Interim Report		Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)
			Source ID	12 to 15 ppb									
Newcomer H.S.	2340 Jackson St., 94115	4	4		7	1st	SF	SECOND FLOOR TEACHER	8/22/97	QST	MAL		
Newcomer H.S.	2340 Jackson St., 94115	5	5		9	1st	SF	SECOND FLOOR TEACHER	8/22/97	QST	MAL		
Newcomer H.S.	2340 Jackson St., 94115	6	6		<5	1st	DF	FRONT OF RM 104	8/22/97	QST	MAL		
Newcomer H.S.	2340 Jackson St., 94115	7	7		10	1st	SF	CAFETERIA KITCHEN	8/22/97	QST	MAL		
Newcomer H.S.	2340 Jackson St., 94115	8	8	yes	29	1st	SF	CAFETERIA FOOD AREA	8/22/97	QST	MAL		
Newcomer H.S.	2340 Jackson St., 94115	8A	8		<5	1st	SF	CAFETERIA FOOD AREA	9/10/97	QST	MAL		
Newcomer H.S.	2340 Jackson St., 94115	9	9		6	1st	DF	PLAYGROUND - NORTH	8/22/97	QST	MAL		
Newcomer H.S.	2340 Jackson St., 94115	10	10	yes	24	1st	MDF	PLAYGROUND - NORTH	8/22/97	QST	MAL		
Newcomer H.S.	2340 Jackson St., 94115	10A	10		<5	1st	MDF	PLAYGROUND - NORTH	9/10/97	QST	MAL		
Newcomer H.S.	2340 Jackson St., 94115	11	na		<5	Blank			8/22/97	QST	MAL		
Newcomer H.S.	2340 Jackson St., 94115	NO1	na		21	Spike		1st Fl. Parking Lot (SE)	8/22/97	QST	MAL	97-W00760-18	20
Newcomer H.S.	2340 Jackson St., 94115	NO2	na			NO	DF	outside Room 205		QST	MAL		
Newcomer H.S.	2340 Jackson St., 94115	NO3	na			NO	DF	outside Room 306		QST	MAL		
Newcomer H.S.												non-operational	
												non-operational	
												non-operational	





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243														
Site		Sample ID	Source ID	Final Interim Report	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab
Nortega C.C.	1775 44th Ave., 94122	1	1				47499-01	<5	1st	DF	ROOM 003 RIGHT HAND CORN	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	2	2				47499-02	<5	1st	DF	ROOM 003 LEFT HAND CORN	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	3	3				47499-03	<5	1st	SF	KITCHEN AREA 003C NOR	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	4	4				47499-04	<5	1st	SF	KITCHEN AREA 003C EAST	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	5	5				47499-05	<5	1st	DF	ROOM 001 BY NORTHSIDE	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	6	6				47499-06	<5	1st	DF	ROOM 002 JUST BY ENTRANCE	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	7	7				47499-07	<5	1st	WF	ROOM 004 NORTHSIDE CORN	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	8	8				47499-08	<5	1st	WF	ROOM 005 BY EAST CORN	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	9	9				47499-09	<5	1st	WF	ROOM 006 BY NORTH CORN	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	10	10				47499-10	<5	1st	WF	ROOM 007 BY EAST CORN	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	11	11				47499-11	<5	1st	DF	SOUTHSIDE OF THE YARD	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	12	12				47499-12	<5	1st	DF	OUTSIDE YARD BY CORN	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	13	13				47499-13	7	1st	DF	OUTSIDE YARD SOUTHSIDE	8/16/97	SFUSD	MAL
	1775 44th Ave., 94122	14	na				47499-14	<5	Blank					
	1775 44th Ave., 94122	15	na				47499-15	<5	Spike					



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243																					
Site	Address	Sample ID	Final Interim Report		Results (ppb)	Sample Type	Source	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up			
			Source ID	>15 ppb																	
O'Connell H. S.	1920 42nd Ave., 94116	1	1		<5	1st	DF	Corr. Basement	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	2	2		<5	1st	DF	Corr. Basement	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	3	3		<5	1st	SF	Classrm 7	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	4	4		<5	1st	DF	Corr. 1st Flr	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	5	5		<5	1st	SF	Classrm 108	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	6	6		<5	1st	SF	Classrm 106	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	7	7		<5	1st	SF	Classrm 104	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	8	8		<5	1st	SF	Classrm 102	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	9	9		<5	1st	DF	Corr. 1st Flr	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	10	10		<5	1st	DF	Classrm 103	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	11	11		6	1st	DF	Classrm 105	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	12	12		<5	1st	SF	Lunge 1st Flr	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	13	13		<5	1st	SF	Rm 115, RR	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	14	14		8	1st	SF	Rm 110	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	15	15		<5	1st	DF	Corr 1st Flr	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	16	16		<5	1st	SF	Kitchen	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	17	17		<5	1st	SF	Kitchen	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	18	18		7	1st	SF	Kitchen	8/15/97	ESI	MAL										
O'Connell H. S.	1920 42nd Ave., 94116	19	19		47475-19	21	Spike		8/15/97	ESI	MAL	97-W00760-8	20								
O'Connell H. S.	1920 42nd Ave., 94116	20	20		47475-20	<5	Blank		8/15/97	ESI	MAL										



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243												
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab
Ortega E.S.	400 Sargent St., 94132	1	1		47476-01	<5	1st	SDF	CLASS -100	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	2	2		47476-02	8	1st	SDF	CLASS -101	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	3	3		47476-03	<5	1st	SDF	CLASS -102	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	4	4		47476-04	11	1st	SDF	CLASS -103	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	5	5		47476-05	5	1st	DF	CORRIDOR - 1ST FLOOR	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	6	6		47476-06	<5	1st	DF	CLASS -002	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	7	7	yes	47476-07	16	1st	DF	CLASS -003	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	8	8		47476-08	<5	1st	DF	CLASS -004	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	9	9		47476-09	<5	1st	DF	CLASS -007	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	10	10		47476-10	<5	1st	DF	CLASS -011	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	11	11		47476-11	7	1st	DF	CLASS -012	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	12	12	yes	47476-12	14	1st	DF	CLASS -013	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	13	13		47476-13	<5	1st	DF	CLASS -014	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	14	14		47476-14	5	1st	DF	CORRIDOR - 2ND FLOOR	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	15	15		47476-15	<5	1st	SDF	ROOM 207A	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	16	16		47476-16	<5	1st	SDF	CLASS -200	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	17	17		47476-17	8	1st	SDF	CLASS -202	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	18	18	yes	47476-18	17	1st	SDF	CLASS -203	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	19	19		47476-19	9	1st	SDF	CLASS -204	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	20	20	yes	47476-20	15	1st	SDF	CLASS -206	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	21	21		47476-21	<5	1st	SDF	CORRIDOR 2ND FLOOR	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	22	22	yes	47476-22	15	1st	DF	LOUNGE 208A	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	23	23		47476-23	<5	1st	SF	CAFETERIA 209	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	24	24		47476-24	<5	1st	DF	KITCHEN	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	25	25	yes	47476-25	31	1st	SF	KITCHEN	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	26	26		47476-26	<5	1st	SF	KITCHEN	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	27	27		47476-27	7	1st	SF	PLAYGROUND	8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	28	28	yes	47476-28	19	1st	SF		8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	29	29		47476-29	7	1st	SF		8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	30	na		47476-30	23	Spike			8/15/97	ESI	MAL
Ortega E.S.	400 Sargent St., 94132	31	na		47476-31	<5	Blank			8/15/97	ESI	MAL





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 S.C.A. Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report 12 to 15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Parker E.S.	840 Broadway St., 94133	1	1		9708D15-01	<5	1st	SF	Kitchen	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	1	1		9708D15-02	<5	Duplicate	SF	Kitchen	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	2	2		9708D15-03	<5	1st	SF	Cafeteria Kitchen	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	2	2		9708D15-04	<5	Duplicate	SF	Cafeteria Kitchen	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	3	3		9708D15-05	<5	1st	DF	105	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	3	3		9708D15-06	<5	Duplicate	DF	105	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	4	4		9708D15-07	<5	1st	DF	104	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	5	5		9708D15-08	<5	1st	DF	103	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	6	6		9708D15-09	<5	1st	DF	103	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	7	7		9708D15-10	<5	1st	DF	102	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	8	8		9708D15-11	<5	1st	DF	101	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	9	9		9708D15-12	<5	1st	DF	101	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	10	10		9708D15-13	<5	1st	DF	Playgrd	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	11	11		9708D15-14	<5	1st	DF	Playgrd	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	12	12		9708D15-15	<5	1st	DF	Playgrd	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	13	13		9708D15-16	<5	1st	DF	Walkway 3rd	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	14	14		9708D15-17	<5	1st	DF	305	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	15	15		9708D15-18	<5	1st	DF	304	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	16	16		9708D15-19	<5	1st	DF	303	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	17	17		9708D15-20	<5	1st	DF	302	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	18	18		9708D15-21	<5	1st	DF	301	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	19	19		9708D15-22	<5	1st	DF	Walkway 2nd	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	20	20		9708D15-23	<5	1st	DF	206	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	21	21		9708D15-24	<5	1st	DF	205	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	22	22		9708D15-25	<5	1st	DF	204	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	23	23		9708D15-26	<5	1st	DF	203	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	24	24		9708D15-27	<5	1st	DF	202	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	25	25		9708D15-28	<5	1st	SF	201 Facility	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	26	26		9708D15-29	<5	1st	SF	200	8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	27	27		9708D15-30	<5	1st	DF		8/24/97	RGA	SEQ	
Parker E.S.	840 Broadway St., 94133	28	na		9708D15-32	51	Spike			8/24/97	RGA	SEQ	97-W00765-19
Parker E.S.	840 Broadway St., 94133	BL	na		9708D15-31	<5	Blank			8/24/97	RGA	SEQ	



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243												
Site	Address	Sample ID	Source ID	Final Interim Report	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Peabody E.S./C.C.	251 6th Ave. 94118	1	1		49315-01	<5	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	1A	1		49315-01	<5	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	1B	1		49315-02	<5	2nd	DF	10/4/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	1C	1		49315-03	<5	3rd	DF	10/4/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	2	2	yes	49315-02	15	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	2A	2		49315-04	6	1st	DF	10/4/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	2B	2		49315-05	5	2nd	DF	10/4/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	2C	2		49315-06	9	3rd	DF	10/4/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	3	3		49315-03	6	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	3A	3		49315-07	<5	1st	DF	10/4/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	3B	3		49315-08	<5	2nd	DF	10/4/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	3C	3		49315-09	<5	3rd	DF	10/4/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	4	4		49315-04	<5	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	4A	4		49315-10	6	1st	DF	10/4/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	4B	4		49315-11	5	2nd	DF	10/4/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	4C	4		49315-12	11	3rd	DF	10/4/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	5	5		49315-05	5	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	6	6		49315-06	8	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	7	7		49315-07	5	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	8	8		49315-08	7	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	9	9	yes	49315-09	20	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	10	10		49315-10	6	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	11	11		49315-11	9	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	12	12	yes	49315-12	14	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	13	13		49315-13	10	1st	SF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	14	14		49315-14	<5	1st	MDF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	15	15	yes	49315-15	48	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	16	16		49315-16	<5	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	17	17		49315-17	<5	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	18	18		49315-18	<5	1st	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	19	na		49315-19	<5	Blank	DF	8/23/97	SFUSD	MAL	
Peabody E.S./C.C.	251 6th Ave. 94118	20	na		49315-20	97	Spike		8/23/97	SFUSD	MAL	97-W00776-5





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report			Comments & Field ID's				Spike Level (ppb)		Inter-lab Results (ppb)		Fill Time (second)		Follow-Up	
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Surveyor	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up						
Potrero Hill J.H.	655 DeHaro St. 94107	2	2			4745-02	8	1st	DF	OUTSIDE ROOM 203	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	3	3			4745-03	<5	1st	DF	THIRD FLOOR ACROSS - R	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	4	4			4745-04	5	1st	DF	OUTSIDE ROOM 381	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	5	5			4745-05	8	1st	DF	FACULTY LOUNGE - ROOM	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	6	6			4745-06	5	1st	DF	CATERIA KITCHEN	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	7	7			4745-07	<5	1st	DF	CATERIA KITCHEN	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	8	8			4745-08	<5	1st	DF	CATERIA KITCHEN	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	9	9			4745-09	<5	1st	DF	CATERIA KITCHEN	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	10	10			4745-10	<5	1st	DF	CATERIA KITCHEN	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	11	11			4745-11	<5	1st	DF	CATERIA KITCHEN	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	12	12			4745-12	10	1st	DF	OUTSIDE ROOM 108	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	13	13		yes	4745-13	78	1st	MDF	Exterior by Rm 101	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	13A	13			48315-01	<5	1st	MDF	Exterior by Rm 101	99/97	QST	MAL											
Potrero Hill J.H.	655 DeHaro St. 94107	13B	13			48315-03	<5	2nd	MDF	Exterior by Rm 101	99/97	QST	MAL											
Potrero Hill J.H.	655 DeHaro St. 94107	14	14	yes		4745-14	14	1st	DF	GIRL'S GYM BATHROOM	QST	MAL		15										
Potrero Hill J.H.	655 DeHaro St. 94107	14A	14			49220-01	<5	1st	DF	Basement, Girl Bathrm	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	14B	14			49220-02	<5	2nd	DF	Basement, Girl Bathrm	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	14C	14			49220-03	<5	3rd	DF	Basement, Girl Bathrm	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	15	15	yes		4745-15	30	1st	MDF	Exterior by Gym Boys' Rm	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	15A	15			48315-04	<5	1st	MDF	Exterior by Gym Boys' Rm	99/97	QST	MAL											
Potrero Hill J.H.	655 DeHaro St. 94107	15B	15			48315-06	<5	1st	DF	GYMNASIUM NORTHWEST	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	16	16	yes		4745-16	15	1st	DF	FIRST FLOOR - GYMNASIUM	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	16A	16			48315-07	5	1st	DF	FIRST FLOOR - GYMNASIUM	99/97	QST	MAL											
Potrero Hill J.H.	655 DeHaro St. 94107	16B	16			48315-08	<5	1st	DF	FIRST FLOOR - GYMNASIUM	99/97	QST	MAL											
Potrero Hill J.H.	655 DeHaro St. 94107	16C	16			48315-09	<5	1st	DF	FIRST FLOOR - GYMNASIUM	99/97	QST	MAL											
Potrero Hill J.H.	655 DeHaro St. 94107	17	17	yes		4745-17	14	1st	DF	GYMNASIUM NORTHEAST	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	17A	17			49220-04	<5	1st	DF	1st Fl. NE Gym	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	17B	17			49220-05	<5	2nd	DF	1st Fl. NE Gym	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	17C	17			49220-06	<5	3rd	DF	1st Fl. NE Gym	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	18	18	yes		4745-18	12	1st	MDF	OUTSIDE GYMNASIUM RO	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	18A	18			49220-07	<5	1st	MDF	1st Fl. outside Rm 130	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	18B	18			49220-08	<5	2nd	MDF	1st Fl. outside Rm 130	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	18C	18			49220-09	<5	3rd	MDF	1st Fl. outside Rm 130	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	19	19			4745-19	<5	1st	DF	BASEMENT LEVEL - OUTS	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	20	20		yes	4745-20	25	1st	DF	103	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	20A	20			48315-10	10	1st	DF	FIRST FLOOR INSIDE ROO	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	20B	20			48315-11	<5	1st	DF	FIRST FLOOR INSIDE ROO	99/97	QST	MAL											
Potrero Hill J.H.	655 DeHaro St. 94107	20C	20			48315-12	<5	1st	DF	FIRST FLOOR INSIDE ROO	99/97	QST	MAL											
Potrero Hill J.H.	655 DeHaro St. 94107	21	21	yes		4745-21	15	1st	DF	104	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	22	22	yes		4745-22	14	1st	DF	105	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	23	23	yes		4745-23	33	1st	DF	106	QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	1	na			4745-01	<5	Blank			QST	MAL												
Potrero Hill J.H.	655 DeHaro St. 94107	24	na			4745-24	40	Spike			QST	MAL	97-W00761-7	30	29									
Potrero Hill J.H.	655 DeHaro St. 94107	BL	na			49220-10	<5	Blank			QST	MAL												



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243					Final Interim Report															
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
Presidio CC	Blgd 387, Presidio, 94129	1	1			47782-01	<5	1a	SF	ROOM #1 KITCHEN FAUCET	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	2	2			47782-02	5	1a	SF	ROOM #2 KITCHEN FAUCET	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	3	3			47782-03	<5	1a	DF	CORRIDOR ADJACENT TO ROOM #4 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	4	4			47782-04	<5	1a	SDF	ROOM #4 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	5	5			47782-05	<5	1a	SDF	ROOM #3 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	6	6			47782-06	7	1a	SF	SDF IN MAIN KITCHEN	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	7	7			47782-07	<5	1a	SF	SDF IN MAIN KITCHEN ADJ TO ROOM #5 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	8	8			47782-08	6	1a	SF	SDF IN EMPLOYEE BREAK ROOM	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	9	9			47782-09	<5	1a	SDF	ROOM #5 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	10	10			47782-10	<5	1a	SDF	ROOM #5 ADJ TO ACTIVITIES	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	11	11			47782-11	<5	1a	SDF	ROOM #12 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	12	12	yes		47782-12	15	1a	SF	ROOM #12 SDF CLOSER TO ROOM #10 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	13	13			47782-13	<5	1a	SDF	ROOM #10 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	14	14			47782-14	<5	1a	SDF	ROOM #7 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	15	15			47782-15	<5	1a	SDF	ROOM #9 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	16	16			47782-16	<5	1a	SDF	ROOM #8 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	17	17			47782-17	16	1a	DF	OUTSIDE DF ADJ TO ROOM #10 SDF	8/23/97	SES	MAL							
Presidio CC	Blgd 387, Presidio, 94129	18	18		yes	47782-18	5	1a	DF	OUTSIDE DF ADJ TO ROOM #10 SDF	8/23/97	SES	MAL			5				
Presidio CC	Blgd 387, Presidio, 94129	19	19		yes	47782-19	12	1a	DF	OUTSIDE DF ADJ TO ROOM #10 SDF	8/23/97	SES	MAL			13				
Presidio CC	Blgd 387, Presidio, 94129	20	na			47782-20	21	Spike Blank		8/23/97	SES	MAL	97-W00760-1	20						
Presidio CC	Blgd 387, Presidio, 94129	BL	na			47782-21	<5	Blank		8/23/97	SES	MAL					non-operational			
Presidio CC	Blgd 387, Presidio, 94129	NO1	na				NO	NO	DF	Room 90		SES	MAL				non-operational			
Presidio CC	Blgd 387, Presidio, 94129	NO2	na				NO	NO	SDF	Room 11		SES	MAL				non-operational			
Presidio CC	Blgd 387, Presidio, 94129	NO3	na				NO	NO	SDF	Room 12		SES	MAL				non-operational			





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243																				
Site	Address	Sample ID	Source ID	Final Interim Report		Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inches)	Fill Time (second)	Follow-Up
				Source	12 to 15															
Presidio M.S.	450 30th St, 94121	1	1			47904-01	6	1st	MDF	OUTSIDE LOWER YARD	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	1A	1			49321-01	<5	1st	DF	Room 147A	10/4/97	SFUSD	MAL					3	60	
Presidio M.S.	450 30th St, 94121	1B	1			49321-02	<5	2nd	DF	Room 147A	10/4/97	SFUSD	MAL					3	60	
Presidio M.S.	450 30th St, 94121	1C	1			49321-03	<5	3rd	DF	Room 147A	10/4/97	SFUSD	MAL					3	60	
Presidio M.S.	450 30th St, 94121	2	2			47904-02	<5	1st	MDF	OUTSIDE YARD BY STAIR	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	2A	2			49321-04	<5	1st	DF	1st Fl Corridor	10/4/97	SFUSD	MAL					3	50	
Presidio M.S.	450 30th St, 94121	2B	2			49321-05	<5	2nd	DF	1st Fl Corridor	10/4/97	SFUSD	MAL					3	50	
Presidio M.S.	450 30th St, 94121	2C	2			49321-06	<5	3rd	DF	1st Fl Corridor	10/4/97	SFUSD	MAL					3	50	
Presidio M.S.	450 30th St, 94121	3	3		yes	47904-03	33	1st	DF	CORRIDOR C90 SOUTHSIDE	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	3A	3			49321-07	<5	1st	DF	2nd Fl Corridor	10/4/97	SFUSD	MAL					2	50	
Presidio M.S.	450 30th St, 94121	3B	3			49321-08	<5	2nd	DF	2nd Fl Corridor	10/4/97	SFUSD	MAL					2	50	
Presidio M.S.	450 30th St, 94121	3C	3			49321-09	<5	3rd	DF	2nd Fl Corridor	10/4/97	SFUSD	MAL					2	50	
Presidio M.S.	450 30th St, 94121	4	4			47904-04	5	1st	DF	CORRIDOR C90 NORTHSIDE	10/4/97	SFUSD	MAL					1	60	
Presidio M.S.	450 30th St, 94121	4A	4		yes	49321-10	103	1st	DF	3rd Fl Corridor	10/4/97	SFUSD	MAL					1	60	
Presidio M.S.	450 30th St, 94121	4B	4			49321-11	<5	2nd	DF	3rd Fl Corridor	10/4/97	SFUSD	MAL					1	60	
Presidio M.S.	450 30th St, 94121	4C	4			49321-12	<5	3rd	DF	3rd Fl Corridor	10/4/97	SFUSD	MAL					1	60	
Presidio M.S.	450 30th St, 94121	5	5		yes	47904-05	47	1st	DF	CORRIDOR C90 SOUTHSIDE	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	6	6			47904-06	11	1st	DF	CORRIDOR C90 NORTHSIDE	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	7	7		yes	47904-07	49	1st	DF	CORRIDOR C90 SOUTHSIDE	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	8	8			47904-08	7	1st	DF	CORRIDOR C90 NORTHSIDE	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	9	9			47904-09	<5	1st	SF	KITCHEN ROOM 213, 2ND	8/26/97	SFUSD	MAL			<5				
Presidio M.S.	450 30th St, 94121	10	10			47904-10	<5	1st	SF	KITCHEN ROOM 213, 2ND	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	11	11			47904-11	<5	1st	SF	KITCHEN ROOM 213, 2ND	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	12	12			47904-12	9	1st	DF	ROOM 230 2ND FLOOR	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	13	13			47904-13	<5	1st	DF	CORRIDOR C-95 1ST FLOOR	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	14	14		yes	47904-14	37	1st	DF	AREA 147A	8/26/97	SFUSD	MAL							
Presidio M.S.	450 30th St, 94121	15	na			47904-15	<5	Blank			8/26/97	SFUSD	MAL		100					
Presidio M.S.	450 30th St, 94121	16	na			47904-16	181	Spike			8/26/97	SFUSD	MAL	97-W00776-2						



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Final Interim Report		Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)
			Source ID	12 to 15 ppb									
Redding E.S.P.K.C.C.	1421 Pine St, 94109	1	1		<5	1st	MDF	OUTSIDE PLAYGROUND	8/25/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	2	2		<5	1st	MDF	OUTSIDE PLAYGROUND	8/25/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	3	3		<5	1st	MDF	OUTSIDE PLAYGROUND	8/25/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	4	4		9	1st	MDF	OUTSIDE PLAYGROUND	8/25/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	5	5		<5	1st	SF	FACULTY ROOM	8/25/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	6	6		<5	1st	SF	KITCHEN	8/25/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	7	7		<5	1st	DF	2ND FLOOR HALLWAY	8/25/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	8	8	yes	18	1st	DF	2ND FLOOR HALLWAY	8/25/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	8A	8		<5	1st	DF	2nd Fl. Hallway	10/3/97	RGA	MAL		35
Redding E.S.P.K.C.C.	1421 Pine St, 94109	8B	8		<5	2nd	DF	2nd Fl. Hallway	10/3/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	8C	8		<5	3rd	DF	2nd Fl. Hallway	10/3/97	RGA	MAL		30
Redding E.S.P.K.C.C.	1421 Pine St, 94109	9	9		<5	1st	DF	3RD FLOOR HALLWAY	8/25/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	10	na		Blank				8/25/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	11	na		47	Spike			8/25/97	RGA	MAL	97-W00765-4	50
Redding E.S.P.K.C.C.	1421 Pine St, 94109	BL	na		<5	Blank			10/3/97	RGA	MAL		
Redding E.S.P.K.C.C.	1421 Pine St, 94109	NO1	na			NO	DF	outside Room 018		RGA	MAL	13B	non-operational



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project 82243										Final Interim Report		Sample ID		Address						
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow Up
Revere E.S. & Annex	555 Tompkins Ave., 94110	1	1			47847-01	<5	1st	SDF	ROOM 214	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	2	2			47847-02	<5	1st	SDF	ROOM 215	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	3	3			47847-03	<5	1st	SDF	ROOM 213	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	4	4			47847-04	<5	1st	SDF	ROOM 211	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	5	5			47847-05	<5	1st	SDF	ROOM 209	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	6	6			47847-06	<5	1st	DF	2ND FLOOR HALL	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	7	7			47847-07	<5	1st	SDF	ROOM 208	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	8	8			47847-08	<5	1st	SDF	ROOM 207	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	9	9			47847-09	<5	1st	SDF	ROOM 205	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	10	10			47847-10	<5	1st	SDF	ROOM 203	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	11	11			47847-11	<5	1st	SDF	ROOM 201	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	12	12			47847-12	<5	1st	SDF	ROOM 202	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	13	13			47847-13	<5	1st	SDF	ROOM 210	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	14	14			47847-14	<5	1st	DF	1ST FLOOR HALL	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	15	15			47847-15	<5	1st	MDF	PLAY YARD	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	17	17			47847-17	<5	1st	SDF	ANNEX 116	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	18	18			47847-18	<5	1st	SDF	ANNEX 105	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	19	19			47847-19	<5	1st	SDF	ANNEX 106	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	20	20			47847-20	10	1st	SDF	ANNEX 113	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	21	21			47847-21	<5	1st	SDF	ANNEX 121	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	22	22			47847-22	<5	1st	SDF	ANNEX 122	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	23	23			47847-23	<5	1st	SDF	ANNEX 114	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	24	24			47847-24	<5	1st	SDF	ANNEX 115	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	25	25			47847-25	<5	1st	SDF	ANNEX OFFICE	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	26	26			47847-26	<5	1st	SDF	ANNEX RM 211	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	27	27			47847-27	<5	1st	SDF	ANNEX RM 201	8/26/97	RGA	MAL			8				
Revere E.S. & Annex	555 Tompkins Ave., 94110	28	28			47847-28	<5	1st	SDF	ANNEX RM 212	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	29	29			47847-29	<5	1st	SDF	ANNEX RM 202	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	30	30			47847-30	<5	1st	SDF	ANNEX RM 209	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	31	31			47847-31	<5	1st	SDF	ANNEX RM 217	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	32	32			47847-32	<5	1st	SDF	FACULTY ROOM	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	33	33			47847-33	<5	1st	SDF	PLAYGROUND	8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	34	34			47847-34	5	1st	MDF	ANNEX HALLWAY	8/26/97	RGA	MAL			6				
Revere E.S. & Annex	555 Tompkins Ave., 94110	16	na			47847-16	<5	Blank			8/26/97	RGA	MAL							
Revere E.S. & Annex	555 Tompkins Ave., 94110	35	na			47847-35	50	Spike			8/26/97	RGA	MAL	97-W00765-11	50					non-accessible
Revere E.S. & Annex	555 Tompkins Ave., 94110	NA1	na				NA	NA		2nd Fl. South End	8/26/97	RGA	MAL							





**SFUSD Lead in Drinking Water Survey - Results Summary**  
Summer / Fall 1997  
SCA Project B2243

Page 92 of 128, Printed 10/29/97







Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report				Sample ID		Source ID		12 to 15 ppb		>15 ppb		Lab ID		Results (ppb)		Sample Type		Source Type		Room		Sample Date		Surveyor		Lab		Spike ID #		Spike Level (ppb)		Inter-lab Results (ppb)		Comments & Field ID's		Arch Height (inch)		Fill Time (second)		Follow-Up																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																											
Site		Address		Sample ID		Source ID		12 to 15 ppb		>15 ppb		Lab ID		Results (ppb)		Sample Type		Source Type		Room		Sample Date		Surveyor		Lab		Spike ID #		Spike Level (ppb)		Inter-lab Results (ppb)		Comments & Field ID's		Arch Height (inch)		Fill Time (second)		Follow-Up																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																					
Rosevelt MS		460 Aguello Blvd., 94118	1									48275-01	1	1st	MDF	EXT. YARD C-97, EAST	9/7/97	SFUSD	MAL																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																										</





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report										
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
San Francisco Charter Early Childhood	25th Ave. & Quintara St.	1	1			47833-01	<5	1st	DF	ROOM 3	8/26/97	MAL	MAL							
San Francisco Charter Early Childhood	25th Ave. & Quintara St.	2	2			47833-02	<5	1st	SF	ROOM 4	8/26/97	MAL	MAL							
San Francisco Charter Early Childhood	25th Ave. & Quintara St.	3	3			47833-03	<5	1st	DF	IN ROOM 6 NOT ENOUGH	8/26/97	MAL	MAL							
San Francisco Charter Early Childhood	25th Ave. & Quintara St.	4	4			47833-04	<5	1st	SDF	ROOM 1 - KINDERGARTEN	8/26/97	MAL	MAL							
San Francisco Charter Early Childhood	25th Ave. & Quintara St.	5	5			47833-05	<5	1st	SDF	ROOM 2	8/26/97	MAL	MAL							
San Francisco Charter Early Childhood	25th Ave. & Quintara St.	6	6			47833-06	<5	1st	SF	KITCHENETTE AREA ADJ	8/26/97	MAL	MAL							
San Francisco Charter Early Childhood	25th Ave. & Quintara St.	7	7			47833-07	6	1st	SF	ART ROOM	8/26/97	MAL	MAL							
San Francisco Charter Early Childhood	25th Ave. & Quintara St.	8	8			47833-08	<5	1st	SDF	IN THE BUNGALOW (2ND	8/26/97	MAL	MAL							
San Francisco Charter Early Childhood	25th Ave. & Quintara St.	BL	na			47833-09	<5	Blank			8/26/97	MAL	MAL							
San Francisco Charter Early Childhood	25th Ave. & Quintara St.	NO1	na				NO	NO	DF	Room 6	8/26/97	MAL	MAL				non-operational			



Table 2 - Final Interim Results

[illegible]



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report											
Sample ID	Address	Site	Source ID	12 to 15 ppo	>15 ppo	Lab ID	Results (ppb)	Sample Type	Source	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (Inch)	Fill Time (second)	Follow-Up	
1	300 Seneca Ave., 94112	San Miguel C.C.	1			9708D01-02	<3	1st	SF	Rm 24	8/25/97	RGA	SEQ								
2	300 Seneca Ave., 94112	San Miguel C.C.	1			9708D01-01	<3	Duplicate	SF	Rm 24	8/25/97	RGA	SEQ								
2	300 Seneca Ave., 94112	San Miguel C.C.	2			9708D01-03	<3	1st	SF	Rm 23	8/25/97	RGA	SEQ								
3	300 Seneca Ave., 94112	San Miguel C.C.	3			9708D01-04	<3	1st	SF	Rm 22	8/25/97	RGA	SEQ								
4	300 Seneca Ave., 94112	San Miguel C.C.	4			9708D01-05	<3	1st	WF	Rm 15	8/25/97	RGA	SEQ								
5	300 Seneca Ave., 94112	San Miguel C.C.	5			9708D01-06	<3	1st	SF	Rm 16	8/25/97	RGA	SEQ								
6	300 Seneca Ave., 94112	San Miguel C.C.	6			9708D01-07	<3	1st	SF	Rm 17	8/25/97	RGA	SEQ								
7	300 Seneca Ave., 94112	San Miguel C.C.	7			9708D01-08	<3	1st	SF	Rm 18	8/25/97	RGA	SEQ								
8	300 Seneca Ave., 94112	San Miguel C.C.	8			9708D01-09	<3	1st	SF	Rm 19	8/25/97	RGA	SEQ								
9	300 Seneca Ave., 94112	San Miguel C.C.	9			9708D01-10	<3	1st	SF	Kitchen	8/25/97	RGA	SEQ								
10	300 Seneca Ave., 94112	San Miguel C.C.	na			9708D01-11	<3	Blank			8/25/97	RGA	SEQ								
11	300 Seneca Ave., 94112	San Miguel C.C.	na			9708D01-12	<3	Splice			8/25/97	RGA	SEQ	97-W00765-18	50						





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Sanchez E.S.	325 Sanchez St., 94114	2	2		47365-02	<5	1st	DF	HALLWAY - NEXT TO RM.	8/14/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	3	3		47365-03	11	1st	DF	1st FLOOR HALLWAY - NE	8/14/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	4	4		47365-04	10	1st	DF	FIRST FLOOR HALLWAY -	8/14/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	5	5	yes	47365-05	23	1st	DF	FIRST FLOOR HALLWAY -	8/14/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	6	6		47365-06	<5	1st	MDF	BASEMENT LEVEL OUTSIDE	8/14/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	7	7		47365-07	10	1st	MDF	BASEMENT LEVEL OUTSIDE	8/14/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	8	8		47365-08	9	1st	MDF	BASEMENT LEVEL OUTSIDE	8/14/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	9	9		47365-09	5	1st	DF	HALLWAY OUTSIDE BASH	8/14/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	11	11		48026-02	5	1st	DF	2ND FLOOR - HALLWAY N	8/30/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	12	12		48026-03	<5	2nd	DF	2ND FLOOR - HALLWAY N	8/30/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	13	13		48026-04	<5	3rd	Blank	2ND FLOOR - HALLWAY N	8/30/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	1	na		47365-01	<5	Blank			8/14/97	QST	MAL	
Sanchez E.S.	325 Sanchez St., 94114	10	na		48026-01	<5	Blank			8/30/97	QST	MAL	



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)
School of the Arts	700 Font Blvd, 94132	1	1		34	1st	SDF	Room 003, West	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	2	2	yes	48768-02	1st	SDF	Room 003, East	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	3	3	yes	48768-03	1st	DF	Adj to Room 003	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	4	4	yes	48768-04	1st	DF	Adj to Room T60	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	5	5	yes	48768-05	1st	DF	Adj to Room T50	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	6	6		48768-06	1st	DF	Adj to Room J03	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	7	7		48768-07	1st	DF	Adj to Room 005	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	8	8		48768-08	1st	SDF	Room 005	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	9	9		48768-09	1st	SDF	Room 006	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	10	10		48768-10	1st	SDF	Room 026	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	11	11		48768-11	1st	SDF	Room 025	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	12	12		48768-12	1st	SDF	Room 012	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	13	13		48768-13	1st	SDF	Room 013	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	14	14		48768-14	1st	SDF	Room 014	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	15	15		48768-15	1st	SDF	Room 016	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	16	16		48768-16	1st	SDF	Room 018	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	17	17		48768-17	1st	SDF	Room 014	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	18	18		48768-18	1st	SDF	Room 020	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	19	19		48768-19	1st	SDF	Room 021	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	20	20		48768-20	1st	SDF	Room 022	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	21	21		48768-21	1st	SDF	Room 023	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	22	22	yes	48768-22	1st	DF	Corridor C-92 West	9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	23	na		48768-23	1st	Spike		9/17/97	SES	MAL		
School of the Arts	700 Font Blvd, 94132	24	na		48768-24	Blank			9/17/97	SES	MAL		



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project 02243													
Site	Address	Sample ID	Final Interim Report		Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)
			Source ID	12 to 15 ppb									
Serra Annex C.C.	155 Appleton Ave. 94110	1	1		6	1st	SDF	3025A	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	2	2		13	1st	DF	3025A	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	2A	2	yes	5	1st	DF	3025A	9/29/97	AEE	MAL		6
Serra Annex C.C.	155 Appleton Ave. 94110	2B	2		5	2nd	DF	3025A	9/29/97	AEE	MAL		6
Serra Annex C.C.	155 Appleton Ave. 94110	2C	2		11	3rd	DF	3025A	9/29/97	AEE	MAL		6
Serra Annex C.C.	155 Appleton Ave. 94110	3	3		6	1st	SDF	3025B	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	4	4		<5	1st	DF	3025B	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	5	5		<5	1st	DF	MAIN YARD	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	6	6		<5	1st	WF	3024	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	7	7		<5	1st	WF	3023	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	8	8		<5	1st	SF	3023	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	9	9		<5	1st	WF	3021	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	11	11		<5	1st	WF	3021	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	12	12		<5	1st	WF	3021	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	13	13		<5	1st	MDF	BACK YARD AREA	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	14	14		9	1st	DF	3020	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	15	15		<5	1st	SDF	3020	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	16	16		<5	1st	WF	3023	8/19/97	AEE	MAL		
Serra Annex C.C.	155 Appleton Ave. 94110	10	na		<5	Blank			8/19/97	AEE	MAL		





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary													
Summer / Fall 1997													
SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)
Serra E.S.	625 Holly Park Circle, 94110	1	1		<5	1st	WF	ADULT RESTROOM	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	2	2		<5	1st	SDF	ROOM 206	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	3	3		<5	1st	SF	ROOM 206	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	4	4		<5	1st	SDF	ROOM 207	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	5	5		<5	1st	SDF	ROOM 207	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	6	6		<5	1st	SDF	ROOM 208	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	7	7		<5	1st	SF	ROOM 208	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	8	8		<5	1st	SDF	ROOM 209	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	9	9		<5	1st	SDF	ROOM 209	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	10	10		<5	1st	SF	SINK NEAR STOVE	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	11	11		<5	1st	SF	TEACHER RESTROOM	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	12	12		<5	1st	SF	2ND ADULT RESTROOM	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	13	13		<5	1st	SF	TEACHER LUNCH ROOM	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	14	14		<5	1st	SF	BOY'S ROOM	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	15	15		<5	1st	SF	GIRL'S ROOM	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	16	16		<5	1st	SDF	HALL DF	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	17	17		<5	1st	DF	ROOM 205	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	18	18		<5	1st	SDF	ROOM 205	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	19	19		<5	1st	SDF	PLAY YARD AREA	8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	20	20		<5	Blank	MDF		8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	21	na		<5	Blank			8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	22	na		<5	Blank			8/21/97	AAE	MAL		
Serra E.S.	625 Holly Park Circle, 94110	97-W00753-2	97-W00753-2		21	spike			8/21/97	AAE	MAL		



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary										Final Interim Report								
Summer / Fall 1997										12 to 15 ppb				>15 ppb				
SCA Project B2243										Source ID				Results				
Site	Address	Sample ID	Source ID	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (Inch)	Fill Time (second)	Follow-Up
Serra S.A.	625 Holly Park Circle, 94110	1	1	47765-01	<5	1st	SDF	CAFE	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	2	2	47765-02	<5	1st	SF	OFFICE	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	3	3	47765-03	<5	1st	SDF	GIRL'S ROOM	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	4	4	47765-04	<5	1st	WF	GIRL'S ROOM	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	5	5	47765-05	<5	1st	SDF	BOY'S ROOM	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	6	6	47765-06	<5	1st	WF	BOY'S ROOM	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	7	7	47765-07	<5	1st	DF	HALL OUTSIDE OF RESTROOM	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	8	8	47765-08	<5	1st	WF	ADULT RESTROOM	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	9	9	47765-09	<5	1st	DF	CLASS ROOM #5	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	11	11	47765-11	<5	1st	SDF	GLASS ROOM #5	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	12	12	47765-12	<5	1st	DF	CLASSROOM #4	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	13	13	47765-13	<5	1st	SDF	CLASSROOM #4	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	14	14	47765-14	<5	1st	DF	CLASSROOM #3	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	15	15	47765-15	<5	1st	SDF	CLASSROOM #3	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	16	16	47765-16	<5	1st	DF	CLASSROOM #2	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	17	17	47765-17	<5	1st	SDF	CLASSROOM #2	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	18	18	47765-18	<5	1st	DF	CLASSROOM #1	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	19	19	47765-19	<5	1st	SDF	CLASSROOM #1	8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	na	na	47765-20	<5	Blank			8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	na	na	47765-21	<5	Blank			8/20/97	AAE	MAL							
Serra S.A.	625 Holly Park Circle, 94110	97-W007	na		21	Spike			8/20/97	AAE	MAL	97-W00751-1	20					



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)
Sheridan E.S.	431 Capitol Ave., 94112	1	1		<5	1st	SF	100F. Lounge	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	2	2		7	1st	SF	102B. Kitchen	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	3	3		<5	1st	SDF	Classrm 103	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	4	4		<5	1st	SDF	Classrm 104	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	5	5		<5	1st	DF	Corr C101	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	6	6		9	1st	DF	Corr C 201	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	7	7		<5	1st	SDF	Classrm 205	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	8	8		<5	1st	SDF	Classrm 204	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	9	9		<5	1st	SDF	Lab 206A	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	10	10		<5	1st	SDF	Classrm 201	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	11	11		<5	1st	SDF	Lab 106A	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	12	12	yes	31	1st	SDF	Classrm 12	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	13	13	yes	45	1st	SDF	Classrm 11	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	14	14	yes	19	1st	SDF	Classrm 10	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	15	15	yes	13	1st	SDF	Classrm 9	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	16	16	yes	29	1st	SDF	Classrm 8	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	17	17		11	1st	SDF	Classrm 7	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	18	18	yes	17	1st	SDF	Classrm 6	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	19	19	yes	34	1st	SDF	Classrm 5	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	20	20	yes	9	1st	SDF	Classrm 4	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	21	21	yes	66	1st	SDF	Classrm 3	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	22	22	yes	16	1st	SDF	Classrm 2	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	23	23		11	1st	SDF	Classrm 1	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	24	24		<5	1st	MDF	Playground	8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	26	26		<5	Blank			8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	25	na		21	Spike			8/15/97	ESI	MAL		
Sheridan E.S.	431 Capitol Ave., 94112	1	1		6	1st	SF	1ST FLOOR TEACHER LOU	8/20/97	RGA	MAL	97-W00760-9	20





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report 12 to 15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Sherman E.S.	1651 Union St, 94123	2	2		47727-02	<5	1st	SF	1ST FLOOR KITCHEN SINK	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	3	3		47727-03	<5	1st	DF	1ST FLOOR AUDITORIUM	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	4	4		47727-04	<5	1st	SDF	1ST FLOOR LIBRARY	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	5	5		47727-05	11	1st	SF	1ST FLOOR LIBRARY STOR	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	6	6		47727-06	<5	1st	MDF	OUTSIDE PLAYGROUND B	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	7	7		47727-07	<5	1st	MDF	OUTSIDE UPPER PLAYGRO	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	8	8		47727-08	<5	1st	MDF	OUTSIDE PLAYGROUND, S	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	9	9		47727-09	8	1st	DF	2ND FLOOR CORRIDOR, N	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	21	21		47727-10	10	1st	DF	3RD FLOOR CORRIDOR, N	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	23	23		47727-11	<5	1st	DF	3RD FLOOR CORRIDOR, S	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	24	24	yes	47727-12	23	1st	MDF	OUTSIDE S. W. PLAYGROU	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	24A	24		49294-01	<5	1st	MDF	Outside SW Playground	9/30/97	RGA	MAL	36
Sherman E.S.	1651 Union St, 94123	24B	24		49294-02	<5	2nd	MDF	Outside SW Playground	9/30/97	RGA	MAL	36
Sherman E.S.	1651 Union St, 94123	24C	24		49294-03	<5	3rd	MDF	Outside SW Playground	9/30/97	RGA	MAL	36
Sherman E.S.	1651 Union St, 94123	25	25		47727-13	8	1st	DF	OUTSIDE S. W. PLAYGROU	8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	26	na		47727-14	<5	Blank			8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	27	na		47727-15	55	Spike			8/20/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	BL	na		49294-04	<5	Blank			9/30/97	RGA	MAL	
Sherman E.S.	1651 Union St, 94123	NO1	na			NO	NO	DF	outside Room 207		RGA	MAL	non-operational
Sherman E.S.	1651 Union St, 94123	NO2	na			NO	NO	SF	Room 203A		RGA	MAL	non-operational
Sherman E.S.	1651 Union St, 94123	NO3	na			NO	NO	SF	Room 303		RGA	MAL	non-operational
Sherman E.S.	1651 Union St, 94123	NO4	na			NO	NO	MDF	outside Room 150		RGA	MAL	non-operational
Sherman E.S.	1651 Union St, 94123	SP	na		49294-05	95	Spike			9/30/97	RGA	MAL	



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report				Sample ID		Address		Follow-Up									
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inches)	Fill Time (second)	Follow-Up								
Stout E.S.	50 Darien Way, 94127	1	1		yes	9708755-01	370	1st	SF	Kitchen	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	1A	1			9708755-01	<5	1st	SF	Kitchen	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	1B	1			9708755-02	<5	2nd	SF	Kitchen	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	1C	1			9708755-03	<5	3rd	SF	Kitchen	9/16/97	ESI				3-1											
Stout E.S.	50 Darien Way, 94127	3C	3			9708755-04	<5	3rd	SF	Lounge	9/16/97	ESI				3-4											
Stout E.S.	50 Darien Way, 94127	7A	7			9708755-05	<5	1st	SDF	Class A-2	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	7B	7			9708755-06	<5	2nd	SDF	Class A-2	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	7C	7			9708755-07	<5	3rd	SDF	Class A-2	9/16/97	ESI															
Stout E.S.	50 Darien Way, 94127	9	9			9708755-08	<5	Duplicate	SDF	Class A-4	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	11	11		yes	9708755-09	32	1st	SDF	Class B-1	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	11A	11			9708755-10	9	1st	SDF	Class B-1	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	11B	11			9708755-11	<5	2nd	SDF	Class B-1	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	11C	11			9708755-12	8	3rd	SDF	Class B-1	9/16/97	ESI															
Stout E.S.	50 Darien Way, 94127	15	15		yes	9708755-13	19	Duplicate	SDF	Pod C Lounge	8/14/97	ESI				3-3											
Stout E.S.	50 Darien Way, 94127	15A	15			9708755-14	<5	1st	SDF	Pod C Lounge	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	15B	15			9708755-15	<5	2nd	SDF	Pod C Lounge	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	18A	18			9708755-16	<5	1st	SDF	Class C-3	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	18B	18			9708755-17	<5	2nd	SDF	Class C-3	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	18C	18			9708755-18	<5	3rd	SDF	Class C-3	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	20A	20			9708755-19	7	3rd	SDF	Class C-3	9/16/97	ESI															
Stout E.S.	50 Darien Way, 94127	20B	20			9708755-20	<5	1st	SDF	Class D-1	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	20C	20		yes	9708755-21	19	3rd	SDF	Class D-1	9/16/97	ESI															
Stout E.S.	50 Darien Way, 94127	22	22			9708755-22	<5	Duplicate	SDF	Class D-3	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	23A	23			9708755-23	<5	1st	SDF	Class D-4	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	23B	23			9708755-24	<5	2nd	SDF	Class D-4	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	23C	23			9708755-25	<5	3rd	SDF	Class D-4	8/29/97	ESI															
Stout E.S.	50 Darien Way, 94127	23C	23			9708755-26	<5	Duplicate	SDF	Class D-4	9/16/97	ESI															
Stout E.S.	50 Darien Way, 94127	23C	23			9708755-27	<5	3rd	SDF	Class D-4	9/16/97	ESI															
Stout E.S.	50 Darien Way, 94127	10	10			9708755-28	6	1st	SDF	Pod B Lounge	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	12	12			9708755-29	<5	1st	SF	Class B-2	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	13	13			9708755-30	5	1st	SF	Class B-3	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	14	14			9708755-31	<5	1st	SDF	Class B-4	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	15	15			9708755-32	15	1st	SDF	Pod C Lounge	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	16	16		yes	9708755-33	19	1st	SDF	Class C-1	8/14/97	ESI			12												
Stout E.S.	50 Darien Way, 94127	17	17			9708755-34	<5	1st	SDF	Class C-2	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	18	18			9708755-35	13	1st	SDF	Class C-3	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	19	19			9708755-36	13	1st	SDF	Class C-4	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	2	2		yes	9708755-37	86	1st	DF	Corr Opposite Cafeteria	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	20	20			9708755-38	<5	1st	SDF	Class D-1	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	21	21			9708755-39	10	1st	SDF	Class D-2	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	22	22			9708755-40	11	1st	SDF	Class D-3	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	23	23		yes	9708755-41	17	1st	SDF	Class D-4	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	24	24			9708755-42	6	1st	SF	Media Rm	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	25	25			9708755-43	<5	1st	MDF	Playground	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	26	26			9708755-44	<5	1st	MDF	Playground	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	27	27			9708755-45	6	1st	MDF	Playground	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	3	3			9708755-46	<5	1st	SF	Lounge	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	4	4			9708755-47	9	1st	SF	Teacher's Rm	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	5	5		yes	9708755-48	13	1st	SDF	Pod A Lounge	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	6	6			9708755-49	7	1st	SDF	Class A-1	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	7	7		yes	9708755-50	18	1st	SDF	Class A-2	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	8	8			9708755-51	7	1st	SDF	Class A-3	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	9	9			9708755-52	<5	1st	SDF	Class A-4	8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	28	na			9708755-53	<5	Blank			8/14/97	ESI															
Stout E.S.	50 Darien Way, 94127	BL	na			9708755-54	<5	Blank			9/16/97	ESI				Blank											
Stout E.S.	50 Darien Way, 94127	BL	na			9708755-55	<5	Blank			8/29/97	ESI															





Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary													
Summer / Fall 1997 SCA Project B1243													
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
Spring Valley E.S.	1451 Jackson St., 94109	1			47526-01	10	1st	WCDF	C90	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	2	2	yes	47526-02	36	1st	SDF	071A	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	2A	2		9710485-01	7	1st	SDF	071A	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	2B	2		9710485-02	<5	2nd	SDF	071A	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	2C	2	yes	9710485-03	43	3rd	SDF	071A	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	3	3		47526-03	12	1st	WCDF	C91	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	4	4	yes	47526-04	20	1st	SDF	19	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	4A	4		9710485-04	<5	1st	SDF	19	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	4B	4		9710485-05	<5	2nd	SDF	19	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	4C	4		9710485-06	7	3rd	SDF	19	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	5	5	yes	47526-05	61	1st	SDF	20	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	5A	5		9710485-07	<5	1st	SDF	20	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	5B	5		9710485-08	<5	2nd	SDF	20	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	5C	5	yes	9710485-09	14	3rd	SDF	20	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	5C	5	yes	9710485-10	13	Duplicate	SDF	20	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	6	6		47526-06	<5	1st	SDF	011A	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	7	7	yes	47526-07	14	1st	SDF	013A	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	7A	7		9710485-11	<5	1st	SDF	013A	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	7B	7		9710485-12	<5	2nd	SDF	013A	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	7C	7		9710485-13	<5	3rd	SDF	013A	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	8	8		47526-08	7	1st	SDF	014A	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	9	9	yes	47526-09	39	1st	WCDF	C90	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	9A	9		9710485-14	<5	1st	WCDF	C90	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	9B	9		9710485-15	6	2nd	WCDF	C90	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	9C	9	yes	9710485-16	14	3rd	WCDF	C90	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	10	10		47526-10	5	1st	SDF	021A	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	11	11		47526-11	<5	1st	SDF	023A	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	12	12	yes	47526-12	58	1st	SDF	024A	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	12A	12		9710485-17	<5	1st	SDF	024A	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	12B	12		9710485-18	<5	2nd	SDF	024A	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	12C	12		9710485-19	<5	3rd	SDF	024A	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	13	13		9710485-20	<5	Duplicate	SDF	024A	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	14	14		47526-13	5	1st	DF	C90	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	15	15	yes	47526-14	<5	1st	SDF	005A	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	15A	15		9710485-21	65	1st	WCDF	C91	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	15B	15	yes	9710485-22	9	2nd	WCDF	C91	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	15C	15		9710485-23	26	3rd	WCDF	C91	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	16	16	yes	47526-16	36	1st	WCDF	C91	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	16A	16		9710485-25	11	1st	WCDF	C91	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	16B	16		9710485-26	13	2nd	WCDF	C91	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	16C	16	yes	9710485-27	77	3rd	WCDF	C91	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	17	17		47526-17	<5	1st	SDF	006A	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	18	18		47526-18	<5	1st	SDF	001A	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	19	19		47526-19	8	1st	SDF	4	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	20	20	yes	47526-20	13	1st	SDF	3	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	20A	20		9710485-28	<5	1st	SDF	3	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	20B	20		9710485-29	<5	2nd	SDF	3	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	20C	20		9710485-30	<5	3rd	SDF	3	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	20C	20		9710485-31	<5	Duplicate	SDF	3	10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	21	21		47526-21	6	1st	SP	C91	8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	22	na		47526-22	28	Spike			8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	23	na		47526-23	<5	Blank			8/1997	SCA	MAL	
Spring Valley E.S.	1451 Jackson St., 94109	15D	na		9710485-24	13	Spike			10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	BL	na		9710485-32	<5	Blank			10/397	SCA	SEQ	
Spring Valley E.S.	1451 Jackson St., 94109	N01	na			NO	SF		Room 009A	SCA	SEQ		
Spring Valley E.S.	1451 Jackson St., 94109	N02	na			NO	SDF		Room 015A	SCA	SEQ		
Spring Valley E.S.	1451 Jackson St., 94109	N03	na			NO	SDF		Room 017A	SCA	SEQ		





**SFUSD Lead In Drinking Water Survey - Results Summary**  
**Summer / Fall 1997**  
**SCA Project B2243**

SPRUSD Lead in Drinking Water Survey - Results Summary																					
Summer / Fall 1997																					
SCA Project B2243																					
Sample ID	Address	Site	Final Interim Report					Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (Inch)	Fill Time (second)	Follow-Up
			Source ID	12 to 15 ppb	>15 ppb	Lab ID	47850-01														
1	100 Masonic Ave., 94118	St. Elizabeth Pregnancy Ctr.	1	na			47850-01	<5	1st	SF	FACILITY ROOM	8/26/97	RGA	MAL							
2	100 Masonic Ave., 94118	St. Elizabeth Pregnancy Ctr.	2	na			47850-02	<5	Blank			8/26/97	RGA	MAL							



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveys	Lab	Spike ID #
Stevenson E.S.	2051 34th Ave. 94116	3	3		47726-01	<5	1st	DF	HALLWAY	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	7	7		47726-02	<5	1st	DF	HALL	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	8	8		47726-03	<5	1st	DF	HALL	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	9	9		47726-04	<5	1st	DF	ROOM 11	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	11	11		47726-05	8	1st	DF	ROOM 12	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	14	14		47726-06	<5	1st	DF	ROOM 13	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	16	16		47726-07	<5	1st	DF	ROOM 14	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	19	19		47726-08	<5	1st	DF	HALL	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	20	20		47726-09	<5	1st	DF	HALL	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	22	22		47726-10	<5	1st	DF	OUTSIDE	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	23	23		47726-11	<5	1st	SF	KITCHEN (NE)	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	24	24		47726-12	<5	1st	SF	KITCHEN (SE)	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	25	25	yes	47726-13	29	1st	SF	Kitchen NW	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	25A	25		49295-01	<5	1st	SF	Kitchen NW	10/2/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	25B	25		49295-02	<5	2nd	SF	Kitchen NW	10/2/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	25C	25		49295-03	<5	3rd	SF	Kitchen NW	10/2/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	26	26		47726-14	<5	1st	SF	KITCHEN (NW)	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	27	27		47726-15	<5	1st	DF	ROOM 25	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	33	33		47726-16	<5	1st	DF	OUTSIDE COURTYARD	8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	34	na		47726-17	<5	Blank			8/20/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	35	na		47726-18	50	Spike			8/20/97	RGA	MAL	50
Stevenson E.S.	2051 34th Ave. 94116	BL	na		49295-04	<5	Blank		Room 019	10/2/97	RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	NA1	na				NO	DF	Room 001		RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	NO1	na				NO	DF	Room 002		RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	NO2	na				NO	DF	Room 006		RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	NO3	na				NO	DF	Room 023		RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	NO4	na				NO	DF	Room T-52		RGA	MAL	
Stevenson E.S.	2051 34th Ave. 94116	NO5	na				NO	DF			RGA	MAL	



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243													
Site	Address	Sample ID	Final Interim Report			Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #
			Source ID	12 to 15 ppb	>15 ppb								
Stockton E.S.C.C.P.K. & Annex	950 Clay St., 94108	1	1			<5	1st	DF	Hall	8/23/97	RGA	SEQ	
Stockton E.S.C.C.P.K. & Annex	950 Clay St., 94108	1	1			<5	Duplicate	DF	Hall	8/23/97	RGA	SEQ	
Stockton E.S.C.C.P.K. & Annex	950 Clay St., 94108	2	2			8	1st	DF	Hall	8/23/97	RGA	SEQ	
Stockton E.S.C.C.P.K. & Annex	950 Clay St., 94108	3	3			<5	1st	MDF	Outside	8/23/97	RGA	SEQ	
Stockton E.S.C.C.P.K. & Annex	950 Clay St., 94108	BL	na			<5	Blank			8/23/97	RGA	SEQ	
Stockton E.S.C.C.P.K. & Annex	950 Clay St., 94108	NO1	na				NO	DF	outside Room 302		RGA	SEQ	
Stockton E.S.C.C.P.K. & Annex	950 Clay St., 94108	NO2	na				NO	DF	outside Room 314A		RGA	SEQ	
												non-operational	
												non-operational	





SFUSD Lead in Drinking Water Survey - Results Summary													
Summer / Fall 1997													
SCA Project B2243													
Site	Address	Sample ID	Source ID	12 to 15 ppb	15 to 19 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab
Sunnyside E.S.	250 Forester St., 94112	I				47785-01	15	1st	SF	008B	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	1A	1	yes		9710492-01	<5	1st	SF	008B	10/7/97	SCA	SEQ
Sunnyside E.S.	250 Forester St., 94112	1B	1			9710492-02	<5	2nd	SF	008B	10/7/97	SCA	SEQ
Sunnyside E.S.	250 Forester St., 94112	1C	1			9710492-03	10	3rd	SF	008B	10/7/97	SCA	SEQ
Sunnyside E.S.	250 Forester St., 94112	2	2			47785-02	<5	1st	SF	004B	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	3	3			47785-03	5	1st	SF	003B	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	4	4			47785-04	16	1st	SF	021B	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	4A	4	yes		9710492-04	6	1st	SF	021B	10/7/97	SCA	SEQ
Sunnyside E.S.	250 Forester St., 94112	4B	4			9710492-05	<5	2nd	SF	021B	10/7/97	SCA	SEQ
Sunnyside E.S.	250 Forester St., 94112	4C	4			9710492-06	8	3rd	SF	021B	10/7/97	SCA	SEQ
Sunnyside E.S.	250 Forester St., 94112	5	5			47785-05	5	1st	SF	018B	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	6	6			47785-06	10	1st	SF	016B	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	7	7	yes		47785-07	15	1st	SF	015B	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	7A	7			9710492-07	<5	1st	SF	015B	10/7/97	SCA	SEQ
Sunnyside E.S.	250 Forester St., 94112	7B	7			9710492-08	<5	2nd	SF	015B	10/7/97	SCA	SEQ
Sunnyside E.S.	250 Forester St., 94112	7C	7			9710492-09	<5	3rd	SF	015B	10/7/97	SCA	SEQ
Sunnyside E.S.	250 Forester St., 94112	7C	7			9710492-10	<5	Duplicate	SF	015B	10/7/97	SCA	SEQ
Sunnyside E.S.	250 Forester St., 94112	8	8			47785-08	<5	1st	SF	014B	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	9	9			47785-09	<5	1st	SF	013B	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	10	10			47785-10	<5	1st	SF	TEACHERS LOUNGE	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	11	11	yes		47785-11	12	1st	MDF	EXT. YARD	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	12	12			47785-12	6	1st	MDF	EXT. YARD	8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	13	na			47785-13	<5	Blank			8/23/97	SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	BL	na			9710492-11	<5	Blank			10/7/97	SCA	SEQ
Sunnyside E.S.	250 Forester St., 94112	NA1	na					NA				SCA	MAL
Sunnyside E.S.	250 Forester St., 94112	NO1	na					NO	DF	Room 017B outside Room 207		SCA	MAL



SFUSD Lead in Drinking Water Survey - Results Summary																			
Summer / Fall 1997																			
SCA Project B2243																			
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (Inch)	Fill Time (second)	Follow-Up
Sunset E.S.	3045 Santiago Ave., 94116	1	1		47578-01	<5	1st	SF	SMALL KITCHEN AREA - 0	8/20/97	SFUSD	MAL							
Sunset E.S.	3045 Santiago Ave., 94116	2	2		47578-02	<5	1st	DF	CORRIDOR C-92/FIRST FLO	8/20/97	SFUSD	MAL							
Sunset E.S.	3045 Santiago Ave., 94116	3	3		47578-03	7	1st	SF	KITCHEN AREA - 015A	8/20/97	SFUSD	MAL							
Sunset E.S.	3045 Santiago Ave., 94116	4	4	yes	47578-04	20	1st	DF	CLASSROOM 014	8/20/97	SFUSD	MAL							
Sunset E.S.	3045 Santiago Ave., 94116	5	5		47578-05	11	1st	DF	CLASSROOM 012	8/20/97	SFUSD	MAL							
Sunset E.S.	3045 Santiago Ave., 94116	6	6		47578-06	10	1st	DF	OUTSIDE BY ROOM 12 DOOR	8/20/97	SFUSD	MAL							
Sunset E.S.	3045 Santiago Ave., 94116	7	7	yes	47578-07	89	1st	DF	CLASSROOM 005	8/20/97	SFUSD	MAL							
Sunset E.S.	3045 Santiago Ave., 94116	8	8	yes	47578-08	100	1st	DF	CLASSROOM 004	8/20/97	SFUSD	MAL							
Sunset E.S.	3045 Santiago Ave., 94116	9	9		47578-09	10	1st	DF	CLASSROOM 003	8/20/97	SFUSD	MAL							
Sunset E.S.	3045 Santiago Ave., 94116	10	10	yes	47578-10	50	1st	DF	CLASSROOM 001	8/20/97	SFUSD	MAL							
Sunset E.S.	3045 Santiago Ave., 94116	11	11	yes	47578-11	33	1st		OUTSIDE YARD BY ROOM	8/20/97	SFUSD	MAL							
Sunset E.S.	3045 Santiago Ave., 94116	12	na		47578-12	<5	Blank			8/20/97	SFUSD	MAL							



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary																					
Summer / Fall 1997																					
SCA Project B2243																					
Site	Address	Sample ID	Final Interim Report		Source ID	12 to 15 ppb	>15 ppb	Results (ppb)	Sample Type	Source	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
			Source ID	12 to 15 ppb																	
Sunshine H.S.		1	1					7	1st	SF	KITCHEN - 1ST FLOOR NO	8/26/97	ATC	MAL							
Sunshine H.S.		2	2					<5	1st	SF	KITCHEN - ROOM 4	8/26/97	ATC	MAL							
Sunshine H.S.		3	3					<5	1st	SF	ROOM 15 "POOL"	8/26/97	ATC	MAL							
Sunshine H.S.		4	4					<5	1st	SF	KITCHEN OF SEWING ROOM	8/26/97	ATC	MAL							
Sunshine H.S.		5	5					<5	1st	SF	2ND FLOOR HALL SW COR	8/26/97	ATC	MAL							
Sunshine H.S.		6	6					<5	1st	DF	2ND FLOOR HALL NE COR	8/26/97	ATC	MAL							
Sunshine H.S.		7	7					<5	1st	DF		8/26/97	ATC	MAL							
Sunshine H.S.		3	na						Blank		1st Fl, Hall (NE)		ATC	MAL				non-operational			
Sunshine H.S.		N01	na						NO	DF	1st Fl, Hall (NW)		ATC	MAL				non-operational			
Sunshine H.S.		N02	na						NO	DF	1st Fl, Hall (SE)		ATC	MAL				non-operational			
Sunshine H.S.		N03	na						NO	DF	2nd Fl, Hall (SE)		ATC	MAL				non-operational			
Sunshine H.S.		N04	na						NO	DF	2nd Fl, Hall (NW)		ATC	MAL				non-operational			





Page 120 of 128. Printed 10/29/97



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary																			
Summer / Fall 1997																			
SCA Project B2243																			
Site	Address	Sample ID	Source ID	Final Interim Report	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	1	1		47577-01	<5	1st	DF	CAFE ROOM 110	8/20/97	SFUSD	MAL							
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	2	2		47577-02	6	1st	SDF	KITCHEN ROOM 112	8/20/97	SFUSD	MAL							
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	3	3		47577-03	<5	1st	DF	PRE-K ROOM 111	8/20/97	SFUSD	MAL							
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	4	4		47577-04	6	1st	DF	PRE-K C92	8/20/97	SFUSD	MAL							
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	5	5		47577-05	10	1st	DF	1ST FLOOR C90	8/20/97	SFUSD	MAL							
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	6	6		47577-06	5	1st	DF	2ND FLOOR C90	8/20/97	SFUSD	MAL							
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	7	7		47577-07	5	1st	DF	BASEMENT C90	8/20/97	SFUSD	MAL							
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	8	8		47577-08	11	1st	DF	BASEMENT K-1 ROOM 001	8/20/97	SFUSD	MAL							
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	9	9		47577-09	6	1st	DF	BASEMENT K-2, ROOM 002	8/20/97	SFUSD	MAL							
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	10	10		47577-10	6	1st	MDF	YARD E - SIDE OF BLDG	8/20/97	SFUSD	MAL							
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	11	11		47577-11	5	1st	MDF	YARD W - SIDE OF BLDG	8/20/97	SFUSD	MAL							
Sweet E.S./P.K.	727 Golden Gate Ave., 94102	12	na		47577-12	<5	Blank			8/20/97	SFUSD	MAL							





Page 122 of 126, Printed 10/20/97





Table 2. Final Interim Results

USEPA Lead in Drinking Water Survey - Results Summary										Final Interim Report		Spike Level (ppb)		Inter-lab Results (ppb)		Comments & Field ID's		Arch Height (inches)		Fill Time (seconds)		Follow-Up																	
Sample ID		Address		Source ID		12 to 15 ppb		>15 ppb		Lab ID		Results		Sample Type		Source Type		Room		Sample Date		Surveys		Lab		Spike ID #		Spike Level (ppb)		Inter-lab Results (ppb)		Comments & Field ID's		Arch Height (inches)		Fill Time (seconds)		Follow-Up	
1		13th & E St., T. I., 94130		1						9708884-01		6		1st		SDF		Rm 23		8/20/97		SCA		SEQ															
2		13th & E St., T. I., 94130		2				yes		9708884-02		5		Duplicate		SDF		Rm 26		8/20/97		SCA		SEQ															
3		13th & E St., T. I., 94130		3						9708884-03		24		1st		SDF		Rm 26		8/20/97		SCA		SEQ														20	
4		13th & E St., T. I., 94130		4				yes		9710474-01		17		1st		SDF		Rm 26		10/7/97		SCA		SEQ														20	
5		13th & E St., T. I., 94130		5						9710474-02		11		2nd		SDF		Rm 26		10/7/97		SCA		SEQ														20	
6		13th & E St., T. I., 94130		6						9710474-03		43		3rd		SDF		Rm 26		10/7/97		SCA		SEQ														20	
7		13th & E St., T. I., 94130		7				yes		9708884-04		13		1st		SDF		Rm 28		8/20/97		SCA		SEQ														15	
8		13th & E St., T. I., 94130		8						9710474-04		5		1st		SDF		Rm 28		10/7/97		SCA		SEQ														15	
9		13th & E St., T. I., 94130		9						9710474-05		5		2nd		SDF		Rm 28		10/7/97		SCA		SEQ														15	
10		13th & E St., T. I., 94130		10						9710474-06		9		3rd		SDF		Rm 28		10/7/97		SCA		SEQ														15	
11		13th & E St., T. I., 94130		11						9708884-05		7		1st		SDF		Rm 29		8/20/97		SCA		SEQ															
12		13th & E St., T. I., 94130		12				yes		9708884-06		13		1st		SDF		Rm 30		8/20/97		SCA		SEQ														25	
13		13th & E St., T. I., 94130		13						9710474-07		6		1st		SDF		Rm 30		10/7/97		SCA		SEQ														25	
14		13th & E St., T. I., 94130		14						9710474-08		5		2nd		SDF		Rm 30		10/7/97		SCA		SEQ														25	
15		13th & E St., T. I., 94130		15						9710474-09		8		3rd		SDF		Rm 30		10/7/97		SCA		SEQ														25	
16		13th & E St., T. I., 94130		16						9710474-10		8		Duplicate		SDF		Rm 30		10/7/97		SCA		SEQ														25	
17		13th & E St., T. I., 94130		17						9708884-07		7		1st		SDF		Rm 33		8/20/97		SCA		SEQ															
18		13th & E St., T. I., 94130		18						9708884-08		6		1st		SDF		Rm 33		8/20/97		SCA		SEQ															
19		13th & E St., T. I., 94130		19						9708884-09		7		1st		SDF		Rm 34		8/20/97		SCA		SEQ															
20		13th & E St., T. I., 94130		20						9708884-10		8		1st		SDF		Rm 31		8/20/97		SCA		SEQ															
21		13th & E St., T. I., 94130		21						9708884-11		5		1st		SDF		Rm 16		8/20/97		SCA		SEQ															
22		13th & E St., T. I., 94130		22						9708884-12		5		1st		SDF		Rm 16		8/20/97		SCA		SEQ															
23		13th & E St., T. I., 94130		23						9708884-13		5		Duplicate		SDF		Rm 15		8/20/97		SCA		SEQ															
24		13th & E St., T. I., 94130		24				yes		9708884-14		90		1st		SDF		Rm 21		8/20/97		SCA		SEQ															
25		13th & E St., T. I., 94130		25						9710474-11		9		1st		SDF		Rm 21		10/7/97		SCA		SEQ														30	
26		13th & E St., T. I., 94130		26				yes		9710474-12		33		2nd		SDF		Rm 21		10/7/97		SCA		SEQ														30	
27		13th & E St., T. I., 94130		27						9710474-13		33		3rd		SDF		Rm 21		10/7/97		SCA		SEQ														30	
28		13th & E St., T. I., 94130		28						9708884-16		77		1st		SDF		Rm 22		8/20/97		SCA		SEQ														25	
29		13th & E St., T. I., 94130		29				yes		9710474-15		6		1st		SDF		Rm 22		10/7/97		SCA		SEQ														25	
30		13th & E St., T. I., 94130		30						9710474-16		5		2nd		SDF		Rm 22		10/7/97		SCA		SEQ														25	
31		13th & E St., T. I., 94130		31				yes		9710474-17		26		3rd		SDF		Rm 22		10/7/97		SCA		SEQ														25	
32		13th & E St., T. I., 94130		32						9708884-17		39		1st		SDF		Rm 20		8/20/97		SCA		SEQ														35	
33		13th & E St., T. I., 94130		33						9710474-18		7		1st		SDF		Rm 20		10/7/97		SCA		SEQ														35	
34		13th & E St., T. I., 94130		34				yes		9710474-19		7		2nd		SDF		Rm 20		10/7/97		SCA		SEQ														35	
35		13th & E St., T. I., 94130		35						9710474-20		7		Duplicate		SDF		Rm 20		10/7/97		SCA		SEQ														35	
36		13th & E St., T. I., 94130		36						9710474-21		15		3rd		SDF		Rm 19		8/20/97		SCA		SEQ														45	
37		13th & E St., T. I., 94130		37				yes		9708884-18		25		1st		SDF		Rm 19		10/7/97		SCA		SEQ														45	
38		13th & E St., T. I., 94130		38						9710474-22		5		1st		SDF		Rm 19		10/7/97		SCA		SEQ														45	
39		13th & E St., T. I., 94130		39				yes		9710474-23		6		2nd		SDF		Rm 19		10/7/97		SCA		SEQ														45	
40		13th & E St., T. I., 94130		40						9710474-24		24		3rd		SDF		Rm 19		10/7/97		SCA		SEQ														45	
41		13th & E St., T. I., 94130		41						9708884-19		5		1st		SDF		Rm 13		8/20/97		SCA		SEQ														35	
42		13th & E St., T. I., 94130		42						9708884-20		5		1st		SDF		Rm 12		8/20/97		SCA		SEQ														35	
43		13th & E St., T. I., 94130		43						9708884-21		5		1st		SDF		Rm 11		8/20/97		SCA		SEQ														35	
44		13th & E St., T. I., 94130		44						9708884-22		5		1st		WF		C92		8/20/97		SCA		SEQ														35	
45		13th & E St., T. I., 94130		45						9708884-23		5		1st		MDF		Ext North		8/20/97		SCA		SEQ														45	
46		13th & E St., T. I., 94130		46						9708884-24		5		Duplicate		MDF		Ext North		8/20/97		SCA		SEQ														45	
47		13th & E St., T. I., 94130		47						9708884-25		5		1st		MDF		Ext by Rm 10		8/20/97		SCA		SEQ														45	
48		13th & E St., T. I., 94130		48						9708884-26		8		1st		SDF		Rm 1		8/20/97		SCA		SEQ															
49		13th & E St., T. I., 94130		49				yes		9708884-28		8		1st		SDF		Rm 3		8/20/97		SCA		SEQ															
50		13th & E St., T. I., 94130		50						9708884-29		5		1st		SDF		Rm 5		8/20/97		SCA		SEQ															
51		13th & E St., T. I., 94130		51						9708884-30		8		1st		SDF		Rm 7		8/20/97		SCA		SEQ															
52		13th & E St., T. I., 94130		52						9708884-31		7		1st		SDF		Rm 9		8/20/97		SCA		SEQ															
53		13th & E St., T. I., 94130		53						9708884-32		21		1st		SDF		Rm 10		8/20/97		SCA		SEQ															
54		13th & E St., T. I., 94130		54				yes		9710474-25		5		1st		SDF		Rm 10		10/7/97		SCA		SEQ														40	
55		13th & E St., T. I., 94130		55						9710474-26		5		2nd		SDF		Rm 10		10/7/97		SCA		SEQ														40	
56		13th & E St., T. I., 94130		56						9710474-27		7		3rd		SDF		Rm 10		10/7/97		SCA		SEQ														40	
57		13th & E St., T. I., 94130		57						9708884-33		7		1st		SDF		Rm 8		8/20/97		SCA		SEQ															
58		13th & E St., T. I., 94130		58																																			



Table 2 - Final Interim Results

SFUSD Lead in Drinking Water Survey - Results Summary										Final Interim Report												Follow-Up													
Summer / Fall 1997 SCA Project B2243										Sample ID	Source ID	12 in 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (Inch)	Fill Time (second)								
Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex Treasure Island E.S. & Annex										36				9708B84-40	<5	1st	MDF	Exit by Rm 9	8/20/97	SCA	SEQ														
										37				9708B84-41	<5	1st	SDF	Rm 17	8/20/97	SCA	SEQ														
										38				9708B84-42	<5	1st	SDF	Rm 18	8/20/97	SCA	SEQ														
										24				9708B84-27	19	Spike			8/20/97	SCA	SEQ	97-W00753-17	20												
										39				9708B84-43	18	Spike			8/20/97	SCA	SEQ	97-W00753-8	20												
										40				9708B84-44	<5	Blank			8/20/97	SCA	SEQ														
										13D				9710474-14	10	Spike			10/7/97	SCA	SEQ														
										81				9710474-32	<5	Blank			10/7/97	SCA	SEQ														
										N01					NO	NO	SDF	Room 24		10/7/97	SCA	SEQ													
										N02					NO	NO	SDF	Room 25			SCA	SEQ													
										N03					NO	NO	SDF	Room 32			SCA	SEQ													
										N04					NO	NO	SDF	Room 35			SCA	SEQ													
										N05					NO	NO	SDF	Room 100			SCA	SEQ													
										N06					NO	NO	SDF	outside Room 170			SCA	SEQ													





SFUSD Lead in Drinking Water Survey - Results Summary										Final Interim Report																				
Summer / Fall 1997 SCA Project B2243										Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results	Sample Type	Source	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up		
Tule Elk Park E.S.										1	1			9708A92-01	<3	1st	SF	Kitchen Left Sink	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										1	1			9708A92-02	<3	Duplicate	SF	Kitchen Left Sink	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										2	2			9708A92-03	<3	1st	SF	Kitchen Right Sink	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										2	2			9708A92-04	<3	Duplicate	SF	Kitchen Right Sink	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										3	3			9708A92-05	<3	1st	SF	2nd Flr Janitor's Closet	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										4	4			9708A92-06	<3	1st	SF	Kitchen RR	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										5	5			9708A92-07	<3	1st	SF	Rm 1	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										6	6			9708A92-08	<3	1st	SF	Rm 1 Storage	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										7	7			9708A92-10	23	1st	SF	Rm 2	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										8A	8		yes	9708A92-10	23	1st	SF	Rm 2	8/14/97	N Tower	SEQ							2-1		
Tule Elk Park E.S.										8B	8			9708A92-02	5	2nd	SF	Rm 2	9/17/97	ESI	SEQ							2-2		
Tule Elk Park E.S.										8C	8			9708A92-01	<3	3rd	SF	Rm 2	9/17/97	ESI	SEQ							3-1		
Tule Elk Park E.S.										9	9			9708A92-11	<3	1st	SF	1st Flr RR South	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										10	10			9708A92-12	<3	1st	SF	1st Flr RR Center	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										11	11			9708A92-13	<3	1st	SF	1st Flr RR North	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										12	12			9708A92-14	<3	1st	SF	Admin Kitchen	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										13	13			9708A92-15	<3	1st	SF	Bungalow 4	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										14	14		yes	9708A92-16	26	1st	SF	Bungalow 3	8/14/97	N Tower	SEQ			24						
Tule Elk Park E.S.										14A	14			9708A92-03	8	1st	SF	Bungalow 3	9/17/97	ESI	SEQ						2-3			
Tule Elk Park E.S.										14B	14			9708A92-04	8	2nd	SF	Bungalow 3	9/17/97	ESI	SEQ						2-4			
Tule Elk Park E.S.										14C	14			9708A92-02	11	3rd	SF	Bungalow 3	9/17/97	ESI	SEQ						3-2			
Tule Elk Park E.S.										15	15		yes	9708A92-17	19	1st	SF	Bungalow 2	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										15A	15			9708A92-05	5	1st	SF	Bungalow 2	9/17/97	ESI	SEQ						2-5			
Tule Elk Park E.S.										15B	15			9708A92-06	<3	2nd	SF	Bungalow 2	9/17/97	ESI	SEQ						2-6			
Tule Elk Park E.S.										15B	15			9708A92-07	<3	Duplicate	SF	Bungalow 2	9/17/97	ESI	SEQ						2-6 Duplicate			
Tule Elk Park E.S.										15C	15			9708A92-03	<3	3rd	SF	Bungalow 2	9/17/97	ESI	SEQ						3-3			
Tule Elk Park E.S.										15C	15			9708A92-04	<3	Duplicate	SF	Bungalow 2	9/17/97	ESI	SEQ						3-3 Duplicate			
Tule Elk Park E.S.										16	16			9708A92-18	<3	1st	SDF	Bungalow 1	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										17	17			9708A92-19	8	1st	MDF	Outside Bungalows	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										7	na			9708A92-09	<3	Blank		Outside Bungalows	8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										18	na			9708A92-20	31	Spike			8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			8/14/97	N Tower	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL	na			9708A92-08	<3	Blank			9/17/97	ESI	SEQ									
Tule Elk Park E.S.										BL																				



SFUSD Lead in Drinking Water Survey - Results Summary																				
Summer / Fall 1997																				
SCA Project B2243																				
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up
Ulloa E.S.	2650 42nd Ave.94116	2	2			9708B71-02	<5	1st	DF	Hall by Rm 105	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	2	2			9708B71-03	<5	Duplicate	DF	Hall by Rm 105	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	3	3			9708B71-04	<5	1st	DF	Hall by Rm 104	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	3	3			9708B71-05	<5	Duplicate	DF	Hall by Rm 104	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	4	4			9708B71-06	<5	1st	DF	North Cafeteria 1st Flr	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	4	4			9708B71-07	<5	Duplicate	DF	North Cafeteria 1st Flr	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	5	5			9708B71-08	<5	1st	DF	Rm 39	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	6	6			9708B71-09	<5	1st	DF	Rm 22	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	7	7			9708B71-10	10	1st	DF	Rm 40	8/16/97	QST	SEQ			12				
Ulloa E.S.	2650 42nd Ave.94116	8	8			9708B71-11	<5	1st	DF	Rm 21	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	9	9					1st	DF	Rm 41		QST								
Ulloa E.S.	2650 42nd Ave.94116	11	11		yes	9708B71-14	12	1st	DF	Rm 1	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	11A	11			49184-01	<5	1st	DF	Room 021	10/29/97	QST	MAL							
Ulloa E.S.	2650 42nd Ave.94116	11B	11			49184-02	<5	2nd	DF	Room 021	10/29/97	QST	MAL							
Ulloa E.S.	2650 42nd Ave.94116	11C	11			49184-03	<5	3rd	DF	Room 021	10/29/97	QST	MAL							
Ulloa E.S.	2650 42nd Ave.94116	12	12			9708B71-15	9	1st	DF	Rm 17	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	13	13			9708B71-16	9	1st	DF	Rm 3	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	14	14			9708B71-17	<5	1st	DF	Rm 3	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	16	16			9708B71-18	<5	1st	DF	Rm 12	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	17	17		yes	9708B71-19	17	1st	DF	Rm 5	8/16/97	QST	SEQ			21				
Ulloa E.S.	2650 42nd Ave.94116	17A	17			49184-04	<5	1st	DF	Room 001	10/29/97	QST	MAL							
Ulloa E.S.	2650 42nd Ave.94116	17B	17			49184-05	<5	2nd	DF	Room 001	10/29/97	QST	MAL							
Ulloa E.S.	2650 42nd Ave.94116	17C	17			49184-06	<5	3rd	DF	Room 001	10/29/97	QST	MAL							
Ulloa E.S.	2650 42nd Ave.94116	18	18			9708B71-20	5	1st	SF	Rm 5	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	19	19			9708B71-21	<5	1st	DF	Rm 6	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	20	20			9708B71-22	<5	1st	DF	Rm 7	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	21	21			9708B71-23	6	1st	SF	Rm 7	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	22	22			9708B71-24	<5	1st	DF	Rm 11	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	24	24			9708B71-25	<5	1st	DF	Rm 10	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	25	25			9708B71-26	<5	1st	DF	Rm 33	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	26	26			9708B71-27	6	1st	DF	Rm 34	8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	1	na			9708B71-01	<5	Blank			8/16/97	QST	SEQ							
Ulloa E.S.	2650 42nd Ave.94116	10	na			9708B71-13	8	Spike			8/16/97	QST	SEQ	97-W00752-10	10					
Ulloa E.S.	2650 42nd Ave.94116	1BL	na			49184-07	<5	Blank			10/29/97	QST	MAL							





## SFUSD Lead in Drinking Water Survey - Results Summary

Page 127 of 128, Printed 10/29/97



## **SFUSD Lead in Drinking Water Survey - Results Summary** **Summer / Fall 1997** **SCA Project B2243**

Page 128 of 128. Printed 10/29/97



SPUSD Lead in Drinking Water Survey - Results Summary

Page 120 of 128. Printed 10/29/97






**CSFUSD Lead in Drinking Water Survey - Results Summary**  
**Summer / Fall 1997**  
**SCA Project B2243**

SFUSD Lead in Drinking Water Survey - Results Summary										Final Interim Report												
				Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-Lab Results (ppb)	Comments & Field ID's	Arch Height (inches)	Fill Time (second)	Follow-Up
Summer / Fall 1997 NSCA Project B243	Address	Site	1	465 Missouri St., 94107	1			47483-01	<5	1st	DF	HALL - ADMIN BLDG.	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	2	465 Missouri St., 94107	2		yes	47483-02	23	1st	SDF	LOUNGE - ADMIN BLDG.	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	3	465 Missouri St., 94107	3			47483-03	14	1st	SDF	LHS SINK AUD. KIT.	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	6	465 Missouri St., 94107	6	yes		47483-05	17	1st	SDF	2ND FLOOR - ROOM 16	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	7	465 Missouri St., 94107	7			47483-06	10	1st	SDF	ROOM 17	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	8	465 Missouri St., 94107	8		yes	47483-07	29	1st	SDF	ROOM 14	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	9	465 Missouri St., 94107	9		yes	47483-08	41	1st	SDF	ROOM 15	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	10	465 Missouri St., 94107	10		yes	47483-09	19	1st	SDF	ROOM 11	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	11	465 Missouri St., 94107	11		yes	47483-10	6	1st	SDF	ROOM 10	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	12	465 Missouri St., 94107	12		yes	47483-11	31	1st	SDF	ROOM 12	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	13	465 Missouri St., 94107	13		yes	47483-12	40	1st	SDF	2ND FLOOR - ROOM 13	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	14	465 Missouri St., 94107	14	yes		47483-13	12	1st	SDF	1ST FLOOR - ROOM 5	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	15	465 Missouri St., 94107	15			47483-14	8	1st	SDF	ROOM 8	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	16	465 Missouri St., 94107	16			47483-15	6	1st	SDF	ROOM 9	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	17	465 Missouri St., 94107	17			47483-16	8	1st	SDF	ROOM 6	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	18	465 Missouri St., 94107	18			47483-17	5	1st	SDF	ROOM 7	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	19	465 Missouri St., 94107	19			47483-18	<5	1st	DF	1ST FLOOR CENTER N.S.H.	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	20	465 Missouri St., 94107	20			47483-19	5	1st	SDF	ROOM 4	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	21	465 Missouri St., 94107	21			47483-20	<5	1st	SDF	ROOM 3	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	22	465 Missouri St., 94107	22		yes	47483-21	16	1st	SDF	ROOM 1	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	23	465 Missouri St., 94107	23			47483-22	11	1st	SDF	ROOM 2	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	24	465 Missouri St., 94107	24			47483-23	<5	1st	MDF	EXTERIOR OF ROOM 6	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	25	465 Missouri St., 94107	25			47483-24	<5	1st	MDF	EXTERIOR OF ROOM 2 RES	8/1/797	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	82201	465 Missouri St., 94107	82201	na		47007-01	<5	FOLLOW	DF	ROOM 3	8/2/97	ATC	MAL							
	465 Missouri St., 94107	Webster E.S.	5	465 Missouri St., 94107	5	na		47483-04	10	Spike			8/1/797	ATC	MAL	97-W00752-8						
	465 Missouri St., 94107	Webster E.S.	26	465 Missouri St., 94107	26	na		47483-25	<5	Blank			8/1/797	ATC	MAL							
465 Missouri St., 94107	Webster E.S.	NO1	465 Missouri St., 94107	NO1	na		47483-25	<5	NO	DF	2nd Fl. South Hall Restroom	8/1/797	ATC	MAL				non-operational				



SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report														
Site	Address	Sample ID	Source ID	12 to 15 ppb	>15 ppb	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Lab	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (Inch)	Fill Time (second)	Follow-Up					
Well E.S.	1501 OFarell St., 94115	1	1			9708B85-01	1st	SF	Rm 32	8/21/97	SCA	SEQ												
Well E.S.	1501 OFarell St., 94115	1	1			9708B85-02	11	Duplicate	Rm 32	8/21/97	SCA	SEQ												
Well E.S.	1501 OFarell St., 94115	2	2			9708B85-03	<5	1st	DF	Dining Area Basement	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	3	3			9708B85-04	<5	1st	DF	South Hall 1st Flr	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	4	4			9708B85-05	<5	1st	DF	North Hall 1st Flr	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	5	5			9708B85-06	<5	1st	DF	North Hall 2nd Flr	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	6	6			9708B85-07	<5	1st	DF	South Hall 2nd Flr	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	7	7			9708B85-08	<5	1st	DF	Roof	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	8	8			9708B85-09	<5	1st	DF	South Hall 3rd Flr	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	9	9			9708B85-10	5	1st	DF	North Hall 3rd Flr	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	10	10			9708B85-11	<5	1st	SDF	Rm 100	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	11	11			9708B85-12	<5	1st	DF	Rm 100	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	11	11			9708B85-13	<5	Duplicate	Rm 100	8/21/97	SCA	SEQ												
Well E.S.	1501 OFarell St., 94115	12	12			9708B85-14	<5	1st	SDF	Rm 103	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	13	13			9708B85-15	<5	1st	SDF	Rm 102	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	14	14			9708B85-16	<5	1st	SDF	Rm 14	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	15	15			9708B85-17	<5	1st	SDF	Rm 15	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	16	16			9708B85-18	<5	1st	SDF	Rm 16	8/21/97	SCA	SEQ											
Well E.S.	1501 OFarell St., 94115	17	na			9708B85-19	25	Spike					97-W00761-15	30										
Well E.S.	1501 OFarell St., 94115	BL	na			9708B85-20		Blank																
Well E.S.	1501 OFarell St., 94115	NO1	na				NO	DF	Room 101		SCA	SEQ				non-operational								
Well E.S.	1501 OFarell St., 94115	NO2	na				NO	DF	outside Room 002		SCA	SEQ				non-operational								
Well E.S.	1501 OFarell St., 94115	NO3	na				NO	DF	outside Room 17		SCA	SEQ				non-operational								
Well E.S.	1501 OFarell St., 94115	NO4	na				NO	DF	outside Room 100		SCA	SEQ				non-operational								
Well E.S.	1501 OFarell St., 94115	NO5	na				NO	DF	outside Room 101		SCA	SEQ				non-operational								



SFUSD Lead in Drinking Water Survey - Results Summary  
Summer / Fall 1997  
SSCA Project B2243Page 132 of 128, Printed 10/29/97





Table 2 - Final Interim Results

SPUSD Lead in Drinking Water Survey - Results Summary										Final Interim Report		SPUSD Lead in Drinking Water Survey - Results Summary										Final Interim Report		SPUSD Lead in Drinking Water Survey - Results Summary										Final Interim Report																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
Summer / Fall 1997										Source ID		12 to 15 >15 ppb		Summer / Fall 1997										Source ID		12 to 15 >15 ppb		Summer / Fall 1997										Source ID		12 to 15 >15 ppb																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																										
SCSA Project B2243										Sample ID		Source ID		12 to 15 >15 ppb		SCSA Project B2243										Sample ID		Source ID		12 to 15 >15 ppb		SCSA Project B2243										Sample ID		Source ID		12 to 15 >15 ppb																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																				
Site										Address		Sample ID		Source ID		12 to 15 >15 ppb		Site										Address		Sample ID		Source ID		12 to 15 >15 ppb		Site										Address		Sample ID		Source ID		12 to 15 >15 ppb																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
West Portal E.S.										5 Lennox Way, 94127		1	1	47788-01	< 3	1st	SDF	ROOM 11	8/23/97	SCA	MAL																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													</





SFUSD Lead in Drinking Water Survey - Results Summary Summer / Fall 1997 SCA Project B2243										Final Interim Report		Source		Sample ID		Lab ID		Results (ppb)		Sample Type		Source Type		Room		Sample Date		Surveyor		Spike ID #		Spike Level (ppb)		Inter-lab Results (ppb)		Comments & Field ID's		Arch Height (inch)		Fill Time (second)		Follow-Up	
Site		Address		Sample ID	Source ID	12 to 15 ppb	>15 ppb	Lab ID	Results (ppb)	Sample Type	Source Type	Room	Sample Date	Surveyor	Spike ID #	Spike Level (ppb)	Inter-lab Results (ppb)	Comments & Field ID's	Arch Height (inch)	Fill Time (second)	Follow-Up																						
W.E.S.	2245 Jones St, 94123	1	1				yes	47729-01	45	1st	SDF	104	8/19/97	RGA						16																							
W.E.S.	2245 Jones St, 94123	1A	1					49293-05	6	1st	SDF	Room 104	10/5/97	RGA						16																							
W.E.S.	2245 Jones St, 94123	1B	1					49293-06	5	2nd	SDF	Room 104	10/5/97	RGA						16																							
W.E.S.	2245 Jones St, 94123	1C	1			yes		49293-07	16	3rd	SDF	Room 104	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	2	2			yes		47729-02	14	1st	SDF	RM 103	10/5/97	RGA						13																							
W.E.S.	2245 Jones St, 94123	2A	2					49293-08	<5	1st	SDF	Room 103	10/5/97	RGA						13																							
W.E.S.	2245 Jones St, 94123	2B	2					49293-09	<5	2nd	SDF	Room 103	10/5/97	RGA						13																							
W.E.S.	2245 Jones St, 94123	2C	2					49293-10	5	3rd	SDF	Room 103	10/5/97	RGA						13																							
W.E.S.	2245 Jones St, 94123	3	3					47729-03	<5	1st	SDF	Room 102	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	4	4					47729-04	8	1st	SDF	101	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	5	5					47729-05	10	1st	SDF	FACULTY	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	6	6					47729-06	5	1st	SF	NURSE'S	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	7	7			yes		47729-07	13	1st	SDF	HALL	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	7A	7					49293-11	8	1st	SDF	Hall	10/5/97	RGA						43																							
W.E.S.	2245 Jones St, 94123	7B	7					49293-12	<5	2nd	SDF	Hall	10/5/97	RGA						43																							
W.E.S.	2245 Jones St, 94123	7C	7					49293-13	8	3rd	SDF	Hall	10/5/97	RGA						43																							
W.E.S.	2245 Jones St, 94123	8	8			yes		47729-08	16	1st	SDF	Room 202	8/19/97	RGA						70																							
W.E.S.	2245 Jones St, 94123	8A	8					49293-01	7	1st	SDF	Room 202	10/5/97	RGA						70																							
W.E.S.	2245 Jones St, 94123	8B	8					49293-02	<5	2nd	SDF	Room 202	10/5/97	RGA						70																							
W.E.S.	2245 Jones St, 94123	8C	8					49293-03	7	3rd	SDF	Room 202	10/5/97	RGA						70																							
W.E.S.	2245 Jones St, 94123	9	9					47729-09	7	1st	SDF	MULTI - PURPOSE	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	10	10					47729-10	7	1st	SDF	KITCHEN	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	11	11					47729-11	10	1st	SF	OUTSIDE	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	12	12					47729-12	7	1st	SDF	Room 201	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	14	14			yes		47729-14	25	1st	SDF	Room 201	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	14A	14					49293-14	<5	1st	SDF	Room 201	10/5/97	RGA						32																							
W.E.S.	2245 Jones St, 94123	14B	14					49293-15	<5	2nd	SDF	Room 201	10/5/97	RGA						32																							
W.E.S.	2245 Jones St, 94123	14C	14					49293-16	11	3rd	SDF	Room 201	10/5/97	RGA						32																							
W.E.S.	2245 Jones St, 94123	15	15			yes		47729-15	13	1st	SDF	Room 210	8/19/97	RGA						53																							
W.E.S.	2245 Jones St, 94123	15A	15					49293-17	<5	1st	SDF	Room 210	10/5/97	RGA						53																							
W.E.S.	2245 Jones St, 94123	15B	15					49293-18	<5	2nd	SDF	Room 210	10/5/97	RGA						53																							
W.E.S.	2245 Jones St, 94123	15C	15					49293-19	6	3rd	SDF	Room 210	10/5/97	RGA						53																							
W.E.S.	2245 Jones St, 94123	16	16			yes		47729-16	18	1st	SDF	Room 209	8/19/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	16A	16					49293-20	<5	1st	SDF	Room 209	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	16B	16					49293-21	6	2nd	SDF	Room 209	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	16C	16					49293-22	6	3rd	SDF	Room 209	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	17	17			yes		47729-17	12	1st	SDF	Room 208	8/19/97	RGA						18																							
W.E.S.	2245 Jones St, 94123	17A	17					49293-23	<5	1st	SDF	Room 208	10/5/97	RGA						18																							
W.E.S.	2245 Jones St, 94123	17B	17					49293-24	5	2nd	SDF	Room 208	10/5/97	RGA						18																							
W.E.S.	2245 Jones St, 94123	17C	17					49293-25	10	3rd	SDF	Room 208	10/5/97	RGA						18																							
W.E.S.	2245 Jones St, 94123	18	18			yes		47729-18	19	1st	SDF	Room 207	8/19/97	RGA						38																							
W.E.S.	2245 Jones St, 94123	18A	18					49293-26	<5	1st	SDF	Room 207	10/5/97	RGA						38																							
W.E.S.	2245 Jones St, 94123	18B	18					49293-27	<5	2nd	SDF	Room 207	10/5/97	RGA						38																							
W.E.S.	2245 Jones St, 94123	18C	18			yes		49293-28	13	3rd	SDF	Room 207	10/5/97	RGA						38																							
W.E.S.	2245 Jones St, 94123	19	19			yes		47729-19	37	1st	SDF	Room 206	8/19/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	19A	19					49293-29	<5	1st	SDF	Room 206	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	19B	19					49293-30	<5	2nd	SDF	Room 206	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	19C	19			yes		49293-31	18	3rd	SDF	Room 206	8/19/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	20	20			yes		47729-20	49	1st	SDF	Room 205	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	20A	20					49293-32	5	1st	SDF	Room 205	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	20B	20					49293-33	<5	2nd	SDF	Room 205	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	20C	20			yes		49293-34	17	3rd	SDF	Room 205	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	21	21			yes		47729-21	27	1st	SDF	Room 204	8/19/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	21A	21					49293-35	<5	1st	SDF	Room 204	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	21B	21					49293-36	<5	2nd	SDF	Room 204	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	21C	21					49293-37	12	3rd	SDF	Room 204	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	22	22			yes		47729-22	13	1st	SDF	Room 203	8/19/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	22A	22					49293-38	<5	1st	SDF	Room 203	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	22B	22					49293-39	<5	2nd	SDF	Room 203	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	22C	22					49293-40	5	3rd	SDF	Room 203	10/5/97	RGA						30																							
W.E.S.	2245 Jones St, 94123	13	na					47729-13	<5	Blank		Room 203	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	23	na					47729-23	47	Spike		Room 203	8/19/97	RGA																													
W.E.S.	2245 Jones St, 94123	BL	na					49293-04	<5	Blank		Room 203	10/5/97	RGA																													
W.E.S.	2245 Jones St, 94123	SP	na					49293-42	21	Spike		Room 203	10/5/97	RGA																													
W.E.S.	2245 Jones St, 94123	SP	na					49293-44	21	Spike		Room 203	10/5/97	RGA																													
W.E.S.	2245 Jones St, 94123	SP	na					49293-41	21	Spike		Room 203	10/5/97	RGA																													
W.E.S.	2245 Jones St, 94123	SP	na					49293-43	22	Spike		Room 203	10/5/97	RGA																													



Table 2 - Final Interim Results

[illegible]



**Table 3**  
**Interim Spike Results**





Table 3 Interim Spike Results

Summer / Fall 1997 SCA Project B2243		Spike Samples		Outside 15%?		25%?		Change Interpretation?		Within 15%?		Percent Difference		Lab		Spike ID #		Inter-lab Results	
Summary		Spike Samples		Outside 15%?		25%?		Change Interpretation?		Within 15%?		Percent Difference		Lab		Spike ID #		Inter-lab Results	
Total Numbers Percentages		95		22 23%		14 15%		0 0%											
* For samples below the detection limit (DL), the value used for subsequent calculations was DL*(1/1.414)																			
Site		Sample ID	Lab ID	Results (ppb)*	Spike Level (ppb)	Sample Date	Change Interpretation?	Within 15%?	Percent Difference	Lab	Spike ID #	Inter-lab Results							
Alamo E.S.		30	48023-21	34	20	8/27/97		no	70%	MAL	97-W00753-10								
Aptos M.S.		11	48826-11	20	20	9/20/97			0%	MAL	97-W00774-13								
Argonne C.C.		4	47497-04	21	20	8/16/97			7%	MAL	97-W00760-5								
Balboa H.S.		1	48578-01	20	20	9/17/97			2%	MAL	97-W00760-19								
Bryant E.S.		14	47482-14	9	10	8/17/97			7%	MAL	97-W00752-3								
Buena Vista E.S.		23	47484-23	14	10	8/17/97		no	41%	MAL	97-W00752-4								
Burton H.S.		30A	49186-10	106	100	10/2/97			6%	MAL	97-W00776-3								
Burton H.S.		30B	49186-11	103	100	10/2/97			3%	MAL	97-W00776-10								
Burton H.S.		30C	49186-12	13	10	10/2/97		no	26%	MAL	97-W00771-18								
Carver E.S.		39	47728-34	64	50	8/19/97		no	28%	MAL	97-W00765-1								
Chavez E.S.		11	48025-11	21	20	8/26/97			5%	MAL	97-W00753-14								
Clarendon E.S.		30	47608-30	21	30	8/17/97		no	32%	MAL	97-W00761-16								
Cleveland E.S.		97-W007	47844-21	18	20	8/22/97			8%	MAL	97-W00753-5								
Cooper C.C.		8	47743-08	47	50	8/21/97			7%	MAL	97-W00765-3								
De Avila E.S.		14	47421-14	11	10	8/15/97			14%	MAL	97-W00752-9								
Denman M.S.		13	48577-13	21	20	9/17/97			7%	MAL	97-W00760-14								
Everett M.S.		6	48519-06	11	10	9/15/97			13%	MAL	97-W00771-5								
Excelsior C.C.		97-W007	47561-15	12	10	8/18/97		no	22%	MAL	97-W00752-2								
Fairmont E.S.		45	49248-16	100	100	10/6/97			0%	MAL	97-W00776-8								
Fairmont E.S.		97-W007	47846-12	21	20	8/26/97			5%	MAL	97-W00760-4								
Filipino Education Ctr		12	47739-13	57	50	8/16/97			14%	MAL	97-W00765-16								
Flynn E.S.		11	47524-11	22	20	8/17/97			10%	MAL	97-W00753-18								
Garfield E.S.		25	47730-07	57	50	8/17/97			13%	MAL	97-W00765-13								
Giannini J.H.		6	47642-06	36	30	8/21/97		no	19%	MAL	97-W00671-19								
Giannini J.H.		27	47642-26	28	30	8/21/97			7%	MAL	97-W00671-14								
Grattan E. S./C.C.		40	47364-39	8	10	8/14/97		no	23%	MAL	97-W00752-13								
Guadalupe E.S.		18	47740-19	54	50	8/21/97			9%	MAL	97-W00765-2								
Harte E.S.		33	48092-33	104	100	8/26/97			4%	MAL	97-W00776-7								
Hillcrest E.S.		9	47783-09	33	30	8/23/97			11%	MAL	97-W00761-11								
Hoover M.S.		18	48051-18	11	10	8/27/97			14%	MAL	97-W00771-4								



Table 3 Interim Spike Results

Summer / Fall 1997 SCA Project B2243		Spike Samples		Outside 15%?		25%?		Change Interpretation?		Within 15%?		Percent Difference		Lab		Spike ID #		Inter-lab Results	
Summary		Spike Samples		Outside 15%?		25%?		Change Interpretation?		Within 15%?		Percent Difference		Lab		Spike ID #		Inter-lab Results	
Total Numbers		95		22		14		0											
Percentages				23%		15%		0%											
* For samples below the detection limit (DL), the value used for subsequent calculations was DL*(1/1.414)																			
Site	Sample ID	Lab ID	Results (ppb)*	Spike Level (ppb)	Sample Date	Change Interpretation?	Within 15%?	Percent Difference	Lab	Spike ID #	Inter-lab Results								
Jefferson C.C.	8	47786-08	31	30	8/22/97			5%	MAL	97-W00761-9	21								
Jefferson E.S.	27	47525-29	21	20	8/19/97			6%	MAL	97-W00753-7									
Jefferson E.S.	28	47525-14	21	20	8/18/97			6%	MAL	97-W00753-11									
Key E.S. &Annex	8	47742-08	57	50	8/19/97			15%	MAL	97-W00765-6									
King E.S.	13	47523-13	21	20	8/16/97			5%	MAL	97-W00753-6									
Larkin Street Youth Center	9	49456-09	97	100	10/9/97			3%	MAL	97-W00776-12									
Lick M.S.	16	47942-16	11	10	8/23/97			6%	MAL	97-W00771-6									
Longfellow E.S.	11	47741-12	58	50	8/22/97		no	15%	MAL	97-W00765-8									
Mann MS	12	48520-12	21	20	9/15/97			4%	MAL	97-W00774-2									
Marina J.H.	21	47744-20	16	30	8/23/97		no	47%	MAL	97-W00761-17									
Marshall H.S.	18	48050-18	21	20	8/26/97			7%	MAL	97-W00774-1									
McAteer HS	16	48240-15	21	20	9/6/97			6%	MAL	97-W00753-16									
McCoppin E.S.	26	47943-26	19	20	8/24/97			3%	MAL	97-W00774-6									
Mission Annex	7	48242-05	22	20	9/5/97			8%	MAL	97-W00753-9									
Monroe E.S.	97-W007	47845-37	20	20	8/24/97			2%	MAL	97-W00753-4									
Newcomer H.S.	11	47691-09	21	20	8/22/97			7%	MAL	97-W00760-18									
Noriega C.C.	15	47499-15	<5	20	8/16/97		no	83%	MAL	97-W00760-13									
O'Connel H. S.	19	47475-19	21	20	8/15/97			3%	MAL	97-W00760-8									
Peabody E.S./C.C.	20	47939-20	97	100	8/23/97			3%	MAL	97-W00776-5									
Potrero Hill J.H.	24	47745-24	40	30	8/23/97		no	33%	MAL	97-W00761-7									
Presidio CC	20	47782-20	21	20	8/23/97			5%	MAL	97-W00760-1									
Presidio M.S.	16	47904-16	181	100	8/26/97		no	81%	MAL	97-W00776-2									
Redding E.S./P.K./C.C.	11	47848-11	47	50	8/25/97			6%	MAL	97-W00765-4									
Revere E.S. & Annex	35	47847-35	50	50	8/26/97			1%	MAL	97-W00765-11									
Rooftop E.S.	11	48049-11	21	20	9/1/97			7%	MAL	97-W00760-2									
Serra E.S.	97-W007	47766-22	21	20	8/21/97			6%	MAL	97-W00753-2									
Serra S.A.	97-W007	47765-21	21	20	8/20/97			3%	MAL	97-W00753-1									
Sheridan E.S.	25	47474-25	21	20	8/15/97			7%	MAL	97-W00760-9									
Sherman E.S.	27	47727-15	55	50	8/20/97			10%	MAL	97-W00765-15									
Spring Valley E.S.	22	47526-22	28	20	8/19/97		no	39%	MAL	97-W00753-19									
														48					





Summer / Fall 1997 SCA Project B2243		Spike Samples		Outside 15%?		25%?		Change Interpretation?		Within 15%?		Percent Difference		Spike ID #		Inter-lab Results	
Summary		Sample ID	Lab ID	Results (ppb)*		Spike Level (ppb)		Sample Date		Change Interpretation?				Lab			
Total Numbers		95		22	14	0											
Percentages				23%	15%	0%											
* For samples below the detection limit (DL), the value used for subsequent calculations was DL*(1/1.414)																	
Stevenson E.S.		35	47726-18	50		50		8/20/97						MAL	97-W00765-14		
Sutro E.S./C.C.		23	47940-23	11		10		8/24/97						MAL	97-W00771-10		
Visitation Valley M.S.		5	47521-05	16		20		8/16/97			no			MAL	97-W00753-15		
Wallenberg H.S.		8	48559-08	22		20		9/14/97						MAL	97-W00774-3		
Washington H.S.		39	47849-39	49		50		8/26/97						MAL	97-W00765-9		
Webster E.S.		5	47483-04	10		10		8/17/97						MAL	97-W00752-8		
West Portal E.S.		26	47788-26	32		30		8/23/97						MAL	97-W00761-12		
Wo E.S.		23	47729-23	47		50		8/19/97						MAL	97-W00765-7		
Alvarado E.S.		8	9708C97-09	44		50		8/24/97						SEQ	97-W00765-10		
Burton H.S.		24	9708B65-23	20		20		8/20/97						SEQ	97-W00760-16		
Cobb E.S.		7	9708D00-08	11		10		8/24/97						SEQ	97-W00752-5		
Davis M.S. (Evans)		5	9708B58-06	26		30		8/18/97						SEQ	97-W00761-13		
Edison E.S.		39	9708D36-29	43		50		8/20/97						SEQ	97-W00765-5		
Golden Gate Annex		9	9708B64-10	28		30		8/19/97						SEQ	97-W00761-3		
Golden Gate E.S.		20	9708B62-22	20		20		8/18/97						SEQ	97-W00760-12		
Golden Gate E.S.		28	9708B62-30	17		20		8/18/97						SEQ	97-W00760-3		
Harte E.S.		7D	9710472-07	95		10		10/4/97			no			SEQ	97-W00771-19		
Hilltop Pregnancy Svcs. Ctr		11	9708D10-12	44		50		8/25/97						SEQ	97-W00765-12		
Lakeshore E.S.		11	9708B83-11	<5		20		8/16/97			no			SEQ	97-W00760-7		
Lilienthal E.S.		25	9708A93-27	32		30		8/21/97						SEQ	97-W00761-4		
Marshall E.S.		19	9708D25-22	48		50		8/23/97						SEQ	97-W00765-17		
Marshall H.S.		18D	9710514-27	10		10		10/7/97						SEQ	97-W00771-3		
Martin C.C.		4	9708B59-05	18		20		8/18/97						SEQ	97-W00760-10		
McKinley E.S.		11	9708B70-12	27		30		8/19/97						SEQ	97-W00761-18		
Milk E.S.		4	9708B61-05	9		10		8/16/97						SEQ	97-W00752-11		
Moscone E.S.		15	9709158-16	13		10		9/5/97			no			SEQ	97-W00771-1		
Parker E.S.		28	9708D15-32	51		50		8/24/97						SEQ	97-W00765-19		
San Miguel C.C.		11	9708D01-12	43		50		8/25/97						SEQ	97-W00765-18		
Spring Valley E.S.		15D	9710485-24	13		10		10/3/97			no			SEQ	97-W00771-13		
Treasure Island E.S. & Ann		24	9708B84-27	19		20		8/20/97						SEQ	97-W00753-17		





### Table 3 Interim Spike Results

Summer / Fall 1997 SCA Project B2243		Spike Samples		Outside 15%?	25%?	Change Interpretation?		Within 15%?	Percent Difference	Lab	Spike ID #	Inter-lab Results
Total Numbers	95			22	14	0						
Percentages				23%	15%	0%						
* For samples below the detection limit (DL), the value used for subsequent calculations was DL*(1/1.414)												
Treasure Island E.S. & Ann	39	9708B84-43	18	20	8/20/97		10%	SEQ	97-W00753-8			
Treasure Island E.S. & Ann	13D	9710474-14	10	10	10/7/97		0%	SEQ	97-W00771-14			
Tule Elk Park E.S.	18	9708A92-20	31	30	8/14/97		3%	SEQ	97-W00761-10			
Ulloa E.S.	10	9708B71-13	8	10	8/16/97		19%	SEQ	97-W00752-10			
Weill E.S.	17	9708B85-19	25	30	8/21/97		17%	SEQ	97-W00761-15			



Table 3 Interim Spike Results

Summer / Fall 1997 SCA Project B2243		Spike Samples		Outside 15%?		25%?		Change Interpretation?		Within 15%?		Percent Difference		Lab		Spike ID #		Inter-lab Results	
Summary		95		22		14		0											
Total Numbers Percentages				23%		15%		0%											
* For samples below the detection limit (DL), the value used for subsequent calculations was DL*(1/1.414)																			
Site		Sample ID	Lab ID	Results (ppb)*	Spike Level (ppb)	Sample Date	Change Interpretation?	Within 15%?	Percent Difference	Lab	Spike ID #	Inter-lab Results							
Complete Data Not Recorded																			
Carver E.S.	S		49292-07	11		10/5/97				MAL	No. not recorded								
Grattan E. S./C.C.	21		47364-21	13	???	8/14/97				MAL	97-W00750-13								
Intl. Studies Academy	5		47412-05	10	???	8/13/97				MAL	97-W0075?-?								
Lowell H.S.	15		48769-15	20		9/22/97				MAL	No. not recorded								
Miraloma E.S.	19		47609-19	12	???	8/17/97				MAL	97-W007??-17								
Ortega E.S.	30		47476-30	23	???	8/15/97				MAL	No. not recorded								
School of the Arts	23		48768-23	20		9/17/97				MAL	No. not recorded								
Sherman E.S.	SP		49294-05	95		9/30/97				MAL	No. not recorded								
Wo E.S.	SP		49293-43	22		10/5/97				MAL	No. not recorded								
Wo E.S.	SP		49293-41	21		10/5/97				MAL	No. not recorded								
Wo E.S.	SP		49293-44	21		10/5/97				MAL	No. not recorded								
Wo E.S.	SP		49293-42	21		10/5/97				MAL	No. not recorded								
21st Century Academy	20		9708754-20	10	???	8/14/97				SEQ	No. not recorded								
Argonne ES (Sampled by E37)	37		9709987-40	21		9/17/97				SEQ	No. not recorded								
Davis M.S. (Hudson)	11		9708B69-12	18	???	8/17/97				SEQ	97-W0075?-15								
Drew E.S.	21		9708757-21	5	???	8/14/97				SEQ	No. not recorded								
El Dorado E.S.	24		9708760-24	10	???	8/13/97				SEQ	No. not recorded								
Taylor E.S./P.K.	18		9708756-18	10	???	8/13/97				SEQ	No. not recorded								



**Table 4**  
**Interim Inter-lab Results**





## SFUSD Lead in Drinking Water Survey - Interim Inter-Lab Results

Summer / Fall 1997  
SCA Project B2243

\* For samples below the detection limit (DL), the value used to calculate the mean was DL\*(1/1.414)

Sample Information		Lab 1		Lab 1 Results		Lab 2		Lab 2 Results		Comments		Special		Spike ID #
Site	Sample ID	Lab 1	Lab 1 ID	Lab 1 Results (ppb)	Lab 2	Lab 2	Lab 2	Lab 2 Results (ppb)	Lab 2	Both within 15% of mean*	Comments	Comments	Comments	
Alamo E.S.	16	MAL	48043-03	<5	FOR	FOR	FOR	<5	FOR					
Alamo E.S.	22	MAL	48023-16	8	FOR	FOR	FOR	7	FOR					
Alamo E.S.	26	MAL	48023-18	6	FOR	FOR	FOR	5	FOR					
Alamo E.S.	28	MAL	48023-20	<5	FOR	FOR	FOR	<5	FOR					
Carver E.S.	4	MAL	47728-03	<5	FOR	FOR	FOR	7	FOR	no				
Carver E.S.	12	MAL	47728-10	34	FOR	FOR	FOR	158	FOR	no				
Chavez E.S.	2	MAL	48025-02	<5	FOR	FOR	FOR	<5	FOR					
Chavez E.S.	13	MAL	48025-13	<5	FOR	FOR	FOR	<5	FOR					
Clarendon E.S.	6	MAL	47608-06	<5	FOR	FOR	FOR	<5	FOR					
Clarendon E.S.	10	MAL	47608-10	<5	FOR	FOR	FOR	<5	FOR					
Cleveland E.S.	3	MAL	47844-03	<5	FOR	FOR	FOR	<5	FOR					
Cleveland E.S.	5	MAL	47844-05	<5	FOR	FOR	FOR	<5	FOR					
Cleveland E.S.	9	MAL	47844-09	<5	FOR	FOR	FOR	<5	FOR					
Cooper C.C.	8	MAL	47743-08	47	FOR	FOR	FOR	49	FOR					
De Avila E.S.	5	MAL	47421-05	<5	FOR	FOR	FOR	<5	FOR					Both above 15. 97-W00765-3
Filipino Ed. Ctr.	2	MAL	47739-02	6	FOR	FOR	FOR	7	FOR					
Franklin M.S.	2	MAL	47692-02	<5	FOR	FOR	FOR	<5	FOR					
Garfield E.S.	4	MAL	47730-03	22	FOR	FOR	FOR	28	FOR					
Garfield E.S.	9	MAL	47730-10	25	FOR	FOR	FOR	28	FOR					
Giannini J.H.	20	MAL	47642-19	<5	FOR	FOR	FOR	5	FOR	no				
Giannini J.H.	22	MAL	47642-21	<5	FOR	FOR	FOR	7	FOR	no				
Grattan E. S./C.C.	19	MAL	47364-19	52	FOR	FOR	FOR	586	FOR	no				
Grattan E. S./C.C.	23	MAL	47364-23	5	FOR	FOR	FOR	10	FOR	no				
Grattan E. S./C.C.	32	MAL	47364-31	12	FOR	FOR	FOR	32	FOR	no				
Guadalupe E.S.	16	MAL	47740-17	5	FOR	FOR	FOR	17	FOR	no				
Harte E.S.	12	MAL	48092-12	<5	FOR	FOR	FOR	<5	FOR					
Jefferson C.C.	2	MAL	47786-02	<5	FOR	FOR	FOR	<5	FOR					
Jefferson E.S.	4	MAL	47525-04	5	FOR	FOR	FOR	7	FOR	no				



SFUSD Lead in Drinking Water Survey - Interim Inter-Lab Results									
Summer / Fall 1997 SCA Project B2243									
* For samples below the detection limit (DL), the value used to calculate the mean was DL*(1/1.414)									
Sample Information		Lab 1		Lab 1 Results (ppb)		Lab 2		Lab 2 Results (ppb)	
Site	Sample ID	Lab 1	Lab 1 ID	Lab 1 Results (ppb)		Lab 2	Lab 2 ID	Lab 2 Results (ppb)	
Jefferson E.S.	28	MAL	47525-14	21		FOR		21	
Kennedy C.C.	14	MAL	48028-03	<5		FOR		<5	
Lick M.S.	14	MAL	47942-14	<5		FOR		9	
Marina J.H.	14	MAL	47744-13	<5		FOR		<5	
Marina J.H.	17	MAL	47744-16	13		FOR		13	
Marina J.H.	20	MAL	47744-19	<5		FOR		<5	
Marshall H.S.	2	MAL	48050-02	13		FOR		16	
Marshall H.S.	6	MAL	48050-06	5		FOR		6	
Marshall H.S.	9	MAL	48050-09	18		FOR		18	
McCoppin E.S.	22	MAL	47943-22	6		FOR		6	
McLaren C.C.	3	MAL	47784-03	<5		FOR		<5	
Miraloma E.S.	13	MAL	47609-13	<5		FOR		6	
Miraloma E.S.	14	MAL	47609-14	21		FOR		27	
Mission H.S.	11	MAL	47836-11	<5		FOR		<5	
Monroe E.S.	18	MAL	47845-18	<5		FOR		<5	
Monroe E.S.	19	MAL	47845-19	<5		FOR		<5	
Monroe E.S.	23	MAL	47845-23	<5		FOR		<5	
Newcomer H.S.	8	MAL	47691-06	29		FOR		29	
Newcomer H.S.	8A	MAL	48372-01	<5		FOR		29	
Ortega E.S.	18	MAL	47476-18	17		FOR		45	
Ortega E.S.	20	MAL	47476-20	15		FOR		6	
Potrero Hill J.H.	14	MAL	47745-14	14		FOR		15	
Potrero Hill J.H.	24	MAL	47745-24	40		FOR		29	
Presidio CC	18	MAL	47782-18	5		FOR		5	
Presidio CC	19	MAL	47782-19	12		FOR		13	
Presidio M.S.	9	MAL	47904-09	<5		FOR		<5	
Revere E.S. & Annex	27	MAL	47847-27	<5		FOR		8	
Revere E.S. & Annex	34	MAL	47847-34	5		FOR		6	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	
								Both above 15.	





SFUSD Lead in Drinking Water Survey - Interim Inter-Lab Results						
Summer / Fall 1997						
SCA Project B2243						
* For samples below the detection limit (DL), the value used to calculate the mean was DL*(1/1.414)						
Sample Information	Sample ID	Lab 1	Lab 1 ID	Lab 1 Results (ppb)	Lab 2	Lab 2 Results (ppb)
San Francisco Communi	6	MAL	47410-06	<5	FOR	<5
Sanchez E.S.	11	MAL	48026-02	5	FOR	<5
Serra Annex C.C.	15	MAL	47764-15	<5	FOR	<5
Serra E.S.	15	MAL	47766-15	<5	FOR	<5
Serra E.S.	21	MAL	47766-21	<5	FOR	<5
Sheridan E.S.	8	MAL	47474-08	<5	FOR	<5
Sherman E.S.	27	MAL	47727-15	55	FOR	48
Spring Valley E.S.	8	MAL	47526-08	7	FOR	9
Stevenson E.S.	33	MAL	47726-16	<5	FOR	<5
Sunnyside E.S.	3	MAL	47785-03	5	FOR	<5
Sutro E.S./C.C.	18	MAL	47940-18	<5	FOR	<5
Washington H.S.	3	MAL	47849-03	9	FOR	22
21st Century Academy	8	SEQ	9708754-08	<5	FOR	8
Alvarado E.S.	8	SEQ	9708C97-09	44	FOR	49
Burton H.S.	3	SEQ	9708B65-04	13	FOR	13
Burton H.S.	26	SEQ	9708B65-25	6	FOR	8
Drew E.S.	19	SEQ	9708757-19	14	FOR	21
Drew E.S.	6	SEQ	9708757-06	9	FOR	31
El Dorado E.S.	22	SEQ	9708760-22	100	FOR	89
Golden Gate E.S.	4	SEQ	9708B62-04	<5	FOR	6
Golden Gate E.S.	17	SEQ	9708B62-19	6	FOR	8
Hilltop Pregnancy Svc	4	SEQ	9708D10-05	8	FOR	19
McKinley E.S.	2	SEQ	9708B70-02	12	FOR	14
McKinley E.S.	9	SEQ	9708B70-10	6	FOR	9
Milk E.S.	7	SEQ	9708B61-08	9	FOR	15
Parker E.S.	8	SEQ	9708D15-11	<5	FOR	<5
Sloat E.S.	16	SEQ	9708755-16	7	FOR	12
Sloat E.S.	3	SEQ	9708755-03	<5	FOR	6
					Both above 15.	97-W00765-15
					Both above 15.	97-W00765-10
					Both above 15.	





SFUSD Lead in Drinking Water Survey - Interim Inter-Lab Results										
Summer / Fall 1997										
SCA Project B2243										
* For samples below the detection limit (DL), the value used to calculate the mean was DL*(1/1.414)										
Sample Information		Sample ID	Lab 1	Lab 1 ID	Lab 1 Results (ppb)	Lab 2	Lab 2 Results (ppb)	Comments Both within 15% of mean*	Special Comments	Spike ID #
Taylor E.S./P.K. Treasure Island E.S. & Treasure Island E.S. & Tule Elk Park E.S. Ulloa E.S. Ulloa E.S.		1	SEQ	9708756-01	24	FOR	22		Both above 15.	
		3	SEQ	9708B84-04	13	FOR	17			
		14	SEQ	9708B84-16	77	FOR	87		Both above 15.	
		14	SEQ	9708A92-16	26	FOR	24		Both above 15.	
		7	SEQ	9708B71-10	10	FOR	12			
		17	SEQ	9708B71-19	17	FOR	21		Both above 15.	











